

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/24/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155740	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED R 10/20/2023
NAME OF PROVIDER OR SUPPLIER TIMBERCREST CHURCH OF THE BROTHERS HOME			STREET ADDRESS, CITY, STATE, ZIP CODE 2201 EAST ST NORTH MANCHESTER, IN 46962		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{E 000}	Initial Comments A Post Survey Revisit (PSR) to the Emergency Preparedness Survey conducted on 09/05/23 was conducted by the Indiana Department of Health in accordance with 42 CFR 483.73. Survey Date: 10/20/23 Facility Number: 000448 Provider Number: 155740 AIM Number: 100275140 At this PSR Survey, Timbercrest Church of the Brethren Home, was found in compliance with Emergency Preparedness Requirements for Medicare and Medicaid Participating Providers and Suppliers, 42 CFR 483.475. The facility has 65 certified beds. At the time of the survey, the census was 51.	{E 000}			
{K 000}	Quality Review completed on 10/23/23 INITIAL COMMENTS A Post Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure Survey conducted on 09/05/23 was conducted by the Indiana Department of Health in accordance 42 CFR Subpart 483.90(a). Survey Date: 10/20/23 Facility Number: 000448 Provider Number: 155740 AIM Number: 100275140 At this Life Safety Code Survey, Timbercrest Church of the Brethren Home was found in	{K 000}			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/24/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155740	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED R 10/20/2023
NAME OF PROVIDER OR SUPPLIER TIMBERCREST CHURCH OF THE BROTHERS HOME			STREET ADDRESS, CITY, STATE, ZIP CODE 2201 EAST ST NORTH MANCHESTER, IN 46962		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{K 000}	<p>Continued From page 1</p> <p>compliance with the Requirements for Medicare and Medicaid Participating Providers and Suppliers, 42 CFR 483.90(a) and the 2012 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2.</p> <p>This one-story facility was determined to be of Type V (111) construction and the basement was determined to be of Type II (222). The facility was fully sprinklered, has a fire alarm system with hard wired smoke detection in the corridors, areas open to the corridor, and in 16 resident rooms in rehabilitation. Battery operated smoke detectors were installed in 45 health care resident rooms.</p> <p>The facility has 65 certified beds. At the time of survey the census was 51.</p> <p>Quality Review completed on 10/23/23</p>	{K 000}			