

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 05/21/2015
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155355	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01, 02, 03 B. WING _____		(X3) DATE SURVEY COMPLETED R 05/14/2015
NAME OF PROVIDER OR SUPPLIER WEST BEND NURSING AND REHABILITATION			STREET ADDRESS, CITY, STATE, ZIP CODE 4600 W WASHINGTON AVE SOUTH BEND, IN 46619		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{K 000}	<p>INITIAL COMMENTS</p> <p>A Post Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure Survey conducted on 03/31/15 was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.70(a).</p> <p>Survey Date: 05/14/15</p> <p>Facility Number: 000246 Provider Number: 155355 AIM Number: 100275420</p> <p>At this Life Safety Code survey, West Bend Nursing and Rehabilitation was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.70(a), Life Safety from Fire and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC) and 410 IAC 16.2. Building 01 was surveyed with Chapter 19, Existing Health Care Occupancies.</p> <p>This facility consists of three connected buildings: Building 01, a two story, fully sprinklered building of Type II (222) construction; Building 02, a one story, fully sprinklered building of Type V (000) construction with a partial basement and Building 03, a one story, fully sprinklered building of Type V (111) construction. The facility has a fire alarm system with smoke detection in the corridors, in spaces open to the corridors and battery operated smoke detectors in all resident rooms. The facility has a capacity of 157 and had a census of 91 at the time of this survey.</p> <p>All areas where residents have customary access were sprinklered. All areas providing facility</p>	{K 000}			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 05/21/2015
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155355	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01, 02, 03 B. WING _____		(X3) DATE SURVEY COMPLETED R 05/14/2015
NAME OF PROVIDER OR SUPPLIER WEST BEND NURSING AND REHABILITATION			STREET ADDRESS, CITY, STATE, ZIP CODE 4600 W WASHINGTON AVE SOUTH BEND, IN 46619		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{K 000}	<p>Continued From page 1 services were sprinklered. A Post Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure Survey conducted on 03/31/15 was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.70(a).</p> <p>Survey Date: 05/14/15</p> <p>Facility Number: 000246 Provider Number: 155355 AIM Number: 100275420</p> <p>At this Life Safety Code survey, West Bend Nursing and Rehabilitation was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.70(a), Life Safety from Fire and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC) and 410 IAC 16.2. Building 02 was surveyed with Chapter 19, Existing Health Care Occupancies.</p> <p>This facility consists of three connected buildings: Building 01, a two story, fully sprinklered building of Type II (222) construction; Building 02, a one story, fully sprinklered building of Type V (000) construction with a partial basement and Building 03, a one story, fully sprinklered building of Type V (111) construction. The facility has a fire alarm system with smoke detection in the corridors, in spaces open to the corridors and battery operated smoke detectors in all resident rooms. The facility has a capacity of 157 and had a census of 91 at the time of this survey.</p> <p>All areas where residents have customary access were sprinklered. All areas providing facility services were sprinklered.</p>	{K 000}			

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 05/21/2015
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155355	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01, 02, 03 B. WING _____		(X3) DATE SURVEY COMPLETED R 05/14/2015
NAME OF PROVIDER OR SUPPLIER WEST BEND NURSING AND REHABILITATION			STREET ADDRESS, CITY, STATE, ZIP CODE 4600 W WASHINGTON AVE SOUTH BEND, IN 46619		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{K 000}	<p>INITIAL COMMENTS</p> <p>A Post Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure Survey conducted on 03/31/15 was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.70(a).</p> <p>Survey Date: 05/14/15</p> <p>Facility Number: 000246 Provider Number: 155355 AIM Number: 100275420</p> <p>At this Life Safety Code survey, West Bend Nursing and Rehabilitation was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.70(a), Life Safety from Fire and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC) and 410 IAC 16.2. Building 03 was surveyed with Chapter 18, New Health Care Occupancies.</p> <p>This facility consists of three connected buildings: Building 01, a two story, fully sprinklered building of Type II (222) construction; Building 02, a one story, fully sprinklered building of Type V (000) construction with a partial basement and Building 03, a one story, fully sprinklered building of Type V (111) construction. The facility has a fire alarm system with smoke detection in the corridors, in spaces open to the corridors and battery operated smoke detectors in all resident rooms. The facility has a capacity of 157 and had a census of 91 at the time of this survey.</p> <p>All areas where residents have customary access were sprinklered. All areas providing facility</p>	{K 000}			

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 05/21/2015
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155355	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01, 02, 03 B. WING _____		(X3) DATE SURVEY COMPLETED R 05/14/2015
NAME OF PROVIDER OR SUPPLIER WEST BEND NURSING AND REHABILITATION			STREET ADDRESS, CITY, STATE, ZIP CODE 4600 W WASHINGTON AVE SOUTH BEND, IN 46619		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{K 000}	Continued From page 3 services were sprinklered.	{K 000}			