

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/18/2022  
FORM APPROVED  
OMB NO. 0938-0391

|  |   |   |   |   |
|--|---|---|---|---|
| STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION                       |   | (X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:<br><br><b>155580</b> | (X2) MULTIPLE CONSTRUCTION<br>A. BUILDING <b>01</b><br><br>B. WING _____  | (X3) DATE SURVEY COMPLETED<br><br><b>R</b><br><b>10/11/2022</b> |
| NAME OF PROVIDER OR SUPPLIER<br><br><b>APERION CARE TOLLESTON PARK</b> |   |   | STREET ADDRESS, CITY, STATE, ZIP CODE<br><b>2350 TAFT ST</b><br><b>GARY, IN 46404</b>                           |   |
| (X4) ID PREFIX TAG   | SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)  | ID PREFIX TAG   | PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY) | (X5) COMPLETION DATE  |
| {E 000}  | Initial Comments<br><br>A Post Survey Revisit (PSR) to the Emergency Preparedness Survey conducted on 08/29/2022 was conducted by the Indiana Department of Health in accordance with 42 CFR 483.73.<br><br>Survey Date: 10/11/2022<br><br>Facility Number: 008505<br>Provider Number: 155580<br>AIM Number: 200064830<br><br>At this PSR to the Emergency Preparedness survey, Aperion Care Tolleston Park, was found in compliance with Emergency Preparedness Requirements for Medicare and Medicaid Participating Providers and Suppliers, 42 CFR 483.73<br><br>The facility has 180 certified beds. 152 beds are dually certified for Medicare and Medicaid; 28 beds are certified for Medicare only. At the time of the survey, the census was 135.<br><br>Quality Review completed on 10/14/22 | {E 000}   |   |   |
| {K 000}  | INITIAL COMMENTS<br><br>A Post Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure Survey conducted on 08/29/2022 was conducted by the Indiana Department of Health in accordance with 42 CFR 483.90(a).<br><br>Survey Date: 10/11/2022<br><br>Facility Number: 008505<br>Provider Number: 155580<br>AIM Number: 200064830   | {K 000}   |   |   |

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/18/2022  
FORM APPROVED  
OMB NO. 0938-0391

| STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION                       |  | (X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:<br><br><b>155580</b> | (X2) MULTIPLE CONSTRUCTION<br>A. BUILDING <b>01</b><br><br>B. WING _____  |                      | (X3) DATE SURVEY COMPLETED<br><br><b>R</b><br><b>10/11/2022</b> |
|--|--|---|---|----------------------|---|
| NAME OF PROVIDER OR SUPPLIER<br><br><b>APERION CARE TOLLESTON PARK</b> |  |   | STREET ADDRESS, CITY, STATE, ZIP CODE<br><b>2350 TAFT ST</b><br><b>GARY, IN 46404</b>                           |                      |   |
| (X4) ID PREFIX TAG   | SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)   | ID PREFIX TAG   | PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY) | (X5) COMPLETION DATE |   |
| {K 000}  | <p>Continued From page 1</p> <p>At this PSR to the Life Safety Code survey, Aperion Care Tolleston Park was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.90(a), Life Safety from Fire and the 2012 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2.</p> <p>This one-story facility with a partial basement was determined to be of Type V (111) construction and fully sprinklered. The facility has a fire alarm system with smoke detection in the corridors, spaces open to the corridors. Battery powered smoke detectors are located in the North and South wing resident rooms; the PCU resident rooms are equipped with hard wired smoke detectors.</p> <p>The facility is protected by a 30-kW natural gas generator and a 45-kW diesel generator.</p> <p>The facility has 180 certified beds. 152 beds are dually certified for Medicare and Medicaid; 28 beds are certified for Medicare only. At the time of the survey, the census was 135.</p> <p>All areas where the residents have customary access were sprinklered. A detached wood equipment storage shed was unsprinklered.</p> <p>Quality Review completed on 10/14/22</p> | {K 000}   |   |                      |   |