

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 12/17/2015
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155556	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01, 02 B. WING _____		(X3) DATE SURVEY COMPLETED R 12/16/2015
NAME OF PROVIDER OR SUPPLIER MILLER'S MERRY MANOR			STREET ADDRESS, CITY, STATE, ZIP CODE 300 FAIRGROUNDS RD TIPTON, IN 46072		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{K 000}	INITIAL COMMENTS Paper compliance to the Life Safety Code Recertification and State Licensure Survey conducted on 12/02/15 was completed on 12/16/15. Review Date: 12/16/15 Facility Number: 000505 Provider Number: 155556 AIM Number: 100266350 Miller's Merry Manor was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.70(a), Life Safety from Fire and the 2000 edition of the (NFPA) National Fire Protection Association 101, (LSC) Life Safety Code and 410 IAC 16.2. The original building consisting of first floor Meadows hall south, Orchard hall excluding the elevator mechanical room and Terrace hall north and south was surveyed with Chapter 19, Existing Health Care Occupancies	{K 000}			
{K 000}	INITIAL COMMENTS Paper compliance to the Life Safety Code Recertification and State Licensure Survey conducted on 12/02/15 was completed on 12/16/15. Review Date: 12/16/15 Facility Number: 000505 Provider Number: 155556 AIM Number: 100266350 Miller's Merry Manor was found in compliance with Requirements for Participation in	{K 000}			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 12/17/2015
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155556	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01, 02 B. WING _____		(X3) DATE SURVEY COMPLETED R 12/16/2015
NAME OF PROVIDER OR SUPPLIER MILLER'S MERRY MANOR		STREET ADDRESS, CITY, STATE, ZIP CODE 300 FAIRGROUNDS RD TIPTON, IN 46072		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
{K 000}	Continued From page 1 Medicare/Medicaid, 42 CFR Subpart 483.70(a), Life Safety from Fire and the 2000 edition of the (NFPA) National Fire Protection Association 101, (LSC) Life Safety Code and 410 IAC 16.2. The first floor Meadows north including the elevator mechanical room, elevator mechanical room on Orchard south and the entire second floor consisting of the Vineyard, Aviary and Garden halls was surveyed with Chapter 18, New Health Care Occupancies.	{K 000}		