

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 12/08/2015  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>155356</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>01</b>  B. WING _____		(X3) DATE SURVEY COMPLETED  <b>12/04/2015</b>
NAME OF PROVIDER OR SUPPLIER  <b>TRANSITIONAL CARE UNIT OF ST JOSEPH</b>			STREET ADDRESS, CITY, STATE, ZIP CODE <b>700 BROADWAY TRANSITIONAL CARE UNIT FORT WAYNE, IN 46802</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 000	<p>INITIAL COMMENTS</p> <p>A Life Safety Code Recertification and State Licensure Survey was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.70(a).</p> <p>Survey Date: 12/04/15</p> <p>Facility Number: 000247 Provider Number: 155356 AIM Number: N/A</p> <p>At this Life Safety Code survey, Transitional Care Unit of St. Joseph was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.70(a), Life Safety from Fire and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2. The facility has elected to utilize a Categorical Waiver pertaining to electric motor driven fire pump assemblies and is in compliance.</p> <p>The Transitional Care Unit was fully sprinklered and located on the ninth floor of an ten story partially sprinklered hospital of Type I (332) construction. The facility has a fire alarm system with smoke detection in the areas open to the corridors and hard wired smoke detectors in the resident rooms. The facility has a capacity of 20 and had a census of 16 at the time of this survey.</p> <p>Quality Review completed 12/07/15 - DA</p>	K 000			
LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE			TITLE		(X6) DATE

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.