



Pipeline Safety Division Investigation Report

Investigation regarding: **Atkinson Trenching**

UPPAC Database Record ID: 3107

Investigator: Mike Orr

Report Date: 1/2/2013

Damage Date: 5/25/2012 12:46:46 PM

Damage Address: 5121 / In Rt 61

City: Vern

County: Knox

The Parties

Excavator: **Atkinson Trenching**

Contact: Jessica Mieuse

Address: 1057 Atkinson Road, Vincennes, In 47591

Telephone:

Facility Owner: Vectren

Contact: Darlene Kulhanek

Address: 1 N Main Street, Evansville, IN 47702

Pipeline Facility

Facility Type: Natural Gas

Facility Function: Distribution

Investigation regarding: Atkinson Trenching

UPPAC Database Record ID: 3107

Damage Impact

Product release: Yes

Ignition: No

Service Interruption: False

Number of Customers Affected: 0

Injuries: 0

Fatalities: 0

Repair Cost (if known): \$4264.4300000000003

Excavator Activities/Cause of damage information:

Excavator request locates: Yes Indiana 811 ticket Number: 1205220826

Type of Equipment: Trencher

Type of work performed: Cable TV

Synopsis: Damage to a natural gas main occurred during a trenching procedure to install a cable TV line.

Findings: Reported by Indiana 811; excavator's response to initial notice was received on 7/24/2012. Excavator reports having a valid locate; however, the gas operator failed to locate or provided incorrect locate markings and was put on notice of such in a mailing from the IURC 8/1/2012.

Conclusion: The gas operator has self reported having failed to locate or provided incorrect locate markings resulting in a determination of an OPERATOR VIOLATION.

Violation: IC 8-1-26-18(f): Operator failed to locate or provided incorrect locate markings.



INDIANA UTILITY REGULATORY COMMISSION
101 W. WASHINGTON STREET, SUITE 1500E
INDIANAPOLIS, INDIANA 46204-3407

<http://www.in.gov/iurc>
Office: (317) 232-2701
Facsimile: (317) 232-6758

July 13, 2012

Ms. Darlene Kulhanek
Vectren
1 N Main Street
Evansville, IN 47702

Subject: Investigation Request for Information

Date of Event: 5/25/2012

Event Location: 5121 / In Rt 61, Vern

Facility Owner: Vectren

Excavator: Atkinson Trenching

Other Party: N/A

Pipeline Division Case No. 3107

Dear Ms. Kulhanek:

Pursuant to Indiana Code 8-1-26, the *Indiana Damage to Underground Facilities Act*, the Pipeline Safety Division of the Indiana Utility Regulatory Commission ("Pipeline Division") is required to investigate reported incidents of alleged statutory violations involving underground pipeline safety. The purpose of this statute is to promote excavation and pipeline safety and to reduce the imminent danger to life, health, property, or loss of service associated with unsafe digging practices. Please note that the investigation does not entail determining criminal liability or a civil determination of fault or damages; however, it does determine whether any statutory violations were committed regarding public safety.

The Pipeline Division received information regarding potential statutory violations regarding the date and location referenced above. You were identified as a person or entity that might have information that would assist the Pipeline Division in its investigation. Therefore, we have contacted you in order to receive the full account of information in order to make a fair determination related to the circumstances of this incident.

We have asked all involved parties, entities and witnesses to provide *written* information within *30 days* in order to meet legal deadlines to conclude our investigation. **Please consider this letter as a formal request to receive any and all information and evidence (including a narrative, documentation, maps, photographs or any other written information) you can access regarding anything you may know about the incident referenced above.**



DAMAGE INFORMATION REPORT – PIPELINE SAFETY DIVISION

State Form 54122 (R2 / 7-11)
INDIANA UTILITY REGULATORY COMMISSION

Submitted to IURC-Pipeline Safety on: 07-19-2012

Who is submitting this information?

Name of person providing this information: Darlene Kulhanek

Business address (*number and street*): 1 Main Street

City, State, and ZIP code: Evansville, IN 47711

Telephone number (*area code*): 812-491-4227

Fax number (*area code*): 812-491-4504

E-mail address: dkulhanek@vectren.com

Excavator Information, if known

Full name: Atkinson Trenching

Business address (*number and street*): 1057 Atkinson Road

City, State, and ZIP code: Vincennes, IN 47591

Telephone number (*area code*): 812-726-1306

Fax number (*area code*): 812-726-4426

E-mail address: Unknown

Excavation or Demolition Information

Excavator type: Contractor

Excavation or demolition equipment: Trencher

Type of work performed: Cable TV

Date and Location of DamageDate of damage (*month, day, year*): 5-25-2012County: KnoxCity: VincennesStreet address (*number and street, city, state, and ZIP code*):
5121 State Rd 61, Vincennes, INNearest intersection: UnknownRight of way where damage occurred: Dedicated Public Utility EasementWas there a release of product? YesIf yes, was there an ignition of product? NoWere evacuations necessary as a result of release? NoIf yes, how many evacuated? 0Was there a customer service interruption? NoIf yes, how many affected? 0Time to restore service (*in hours*): 0Enter number of injuries, if applicable and known: 0Enter number of fatalities, if applicable and known: 0Property damage, Estimate \$ 4,264.43

Affected Facility InformationWhat type of pipeline was damaged? Natural GasWhat was the affected facility? Distribution

What was the depth of the facility, in inches? _____

Notification, Locating, MarkingDid excavator request locates prior to commencing work? YesEnter Indiana 811 ticket number, if known: 1205220826

Was the locate request completed within two working days? Yes

If locates were performed, were they done so by a contractor or pipeline employee? Contract Locator

If a contractor locator, enter the company name, if known: USIC _____

Were facility marks visible in the area of excavation? No

Were facilities marked correctly? No

Type of markings used: Paint

If other, please specify: _____

Was site marked by "White Lining"? No

Were special instructions part of the locate request? Unknown/Other

Were maps used to complete the locate request? Unknown/Other

Were pipeline company representatives on site during excavation? No

Did the excavator notify the operator in the event of this damage? Yes

Did the excavator notify Indiana 811 in the event of this damage? Yes


Did the excavator notify 911 in the event of a release of product? Unknown/Other

Description of Cause

Select from the list the most accurate cause for the damage: --Facility marking or location not sufficient

Additional Comments

4" plastic main damaged by trencher. > 24"




1 VECTREN ENERGY DELIVERY OF INDIANA - SOUTH

NOW DUE
\$4,264.43

USIC INC
9045 N RIVER ROAD, SUITE 300
INDIANAPOLIS, IN 46240

Type: GAS
Invoice: FDS0016291
BillToID: 31983
Billing Date: 7/11/2012
Date of Loss: 5/25/2012
5857 103.0509

Please return this portion with your remittance.



Mail Payment To:
Vectren Utilities Holding Group, Inc.
VECTREN ENERGY DELIVERY OF INDIANA - SOUTH
1239 Reliable Parkway
Chicago, IL 60686-0012
Inquiries: 1-877-902-2934, Mon.-Fri., 8-5
Risk Management/Claims Department

NOW DUE
\$4,264.43

USIC INC
9045 N RIVER ROAD, SUITE 300
INDIANAPOLIS, IN 46240

Type: GAS
Invoice: FDS0016291
BillToID: 31983
Billing Date: 7/11/2012
Date of Loss: 5/25/2012

Invoice For Costs to Repair and Reconstruct Damaged Property

Address: 5121 STATE RD 61, VINCENNES
4" PLASTIC MAIN CUT BY TRENCHER. > 24".

Material:	\$117.93
Company Labor:	\$1,101.93
Contract Labor:	\$0.00
Transportation/Equipment:	\$173.19
Misc:	\$0.00
Gas Loss:	\$2,871.38
Adjustments:	\$0.00
Payments:	\$0.00
Total:	\$4,264.43

5857 103.0509

Remember, call two (2) working days before digging. Contact I.U.P.P.S. at 1-800-382-5544.

West, Josh


From: Morgan Thompson <MorganThompson@usicinc.com>
Sent: Wednesday, July 11, 2012 3:25 PM
To: West, Josh
Cc: Morgan Thompson
Subject: RE: FDS0016291 - 5121 ST RD 61 - VINCENNES - 5/25/12

Josh,

I show this one as ours. Do you have the total on this one?

Thanks,

Morgan Thompson
Claims Coordinator
O: 317 776 1479 x109
C: 317 538 7301



From: West, Josh [<mailto:jawest@Vectren.com>]
Sent: Wednesday, July 11, 2012 4:21 PM
To: Morgan Thompson
Subject: FDS0016291 - 5121 ST RD 61 - VINCENNES - 5/25/12

Can you please send your report and photos?

Thanks

Josh West | Facility Damages Specialist | Vectren Energy Delivery
Desk 812.491.4586 | Cell 812.205.8251 | Fax 812.491.4504

DISCLAIMER: +++The information transmitted is intended only for designated recipient(s) and may contain confidential and/or privileged material. Any review, retransmission, dissemination or other use of, or taking of any action in reliance upon, this information by persons or entities other than the intended recipient is prohibited. If you received this in error, please contact the sender and do not retain but destroy any copies of this document.+++.



1 VECTREN ENERGY DELIVERY OF INDIANA - SOUTH

NOW DUE

\$4,264.43

ATKINSON TRENCHING
1057 N ATKINSON ROAD
VINCENNES, IN 47591

Type: GAS
Invoice: FDS0016291
BillToID: 31983
Billing Date: 7/6/2012
Date of Loss: 5/25/2012
5857 103.0509

Please return this portion with your remittance.



Mail Payment To:
Vectren Utilities Holding Group, Inc.
1239 Reliable Parkway
Chicago, IL 60686-0012
Inquiries: 1-877-902-2934, Mon.-Fri., 8-5
Risk Management/Claims Department

ATKINSON TRENCHING
1057 N ATKINSON ROAD
VINCENNES, IN 47591

Type: GAS
Invoice: FDS0016291
BillToID: 31983
Billing Date: 7/6/2012
Date of Loss: 5/25/2012

NOW DUE
\$4,264.43

Invoice For Costs to Repair and Reconstruct Damaged Property

Address: 5121 STATE RD 61, VINCENNES
4" PLASTIC MAIN CUT BY TRENCHER. DID NOT HAND EXPOSE.

Material:	\$117.93
Company Labor:	\$1,101.93
Contract Labor:	\$0.00
Transportation/Equipment:	\$173.19
Misc:	\$0.00
Gas Loss:	\$2,871.38
Adjustments:	\$0.00
Payments:	\$0.00
Total:	\$4,264.43

5857 103.0509

Remember, call two (2) working days before digging. Contact I.U.P.P.S. at 1-800-382-5544.

Vectren Claim Number: _____

FDS 0016291

Task No: 103,0509 Capital / O & M (circle one)

Police Report / MO #: _____

Date of Damage 5/25/12

Vectren Claims Camera:

Cost Center # 5857

FACILITIES DAMAGE REPORT

GAS

VE02034
7763205 4

Time Occurred 12:30 am / pm

Time Found 1:30 am / pm

Latitude 38.37556 Longitude: -87.269050

DAMAGE SITE:

Address 5121 SR 61 Lot # _____

FACILITY TYPE:

- Distribution Propane
- Service Storage
- Transmission: (include supplemental report)

County KNX City Vincennes State IN Township Palmyra

FACILITIES DAMAGED:

ORIFICE SIZE(S):	(1)	(2)	(3)
0.50 inch	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5/8 inch	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
0.75 inch	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.00 inch	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.25 inch	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.00 inch	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.00 inch	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.00 inch	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5.00 inch	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6.00 inch	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10.00 inch	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
12.00 inch	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
16.00 inch	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
20.00 inch	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Other _____			

- Farm Tap
- Heater
- Main
- Meter (Residential)
- Meter (Industrial / Commercial)
- Odorizer
- Regulator Station
- Relief Valve
- Riser
- Service Line
- Valve
- Other _____

VISUAL OBSERVATION AT DAMAGE SITE:

- Visual Observation: Above Ground Below Ground
- Locate Applicable: Yes No N/S
- Facilities Properly Marked: Yes No N/S
- Marking Methods: Conventional Flags None Whiskers
- Offset Paint Stakes N/S
- Locate Marking Faded: Yes No N/S
- Wrong Address Requested: Yes No N/S

Facilities Improperly Located:

- Qualified Locator Could Not Have Accurately Located
- Inaccurate Maps / Cards
- Broken or No Tracer Wire (Plastic)
- Insulation Preventing Accurate Locate

Locator Error:

- Failure to Follow Policy
- Inappropriate Site Markings
- Incomplete Locate
- No Locates Performed
- Qualified Locator Could Have Accurately Located
- Wrong Address Located
- Marking Off By: 24" (Feet / Inches)

- Were Facility Marks Visible: Yes No
- Was Area White Lined: Yes No Destroyed
- Positive Response: Yes No Destroyed
- Tolerance Zone Violated: Yes No
- Part of Project: Yes No
- Company Representative On-Site: Yes No

TYPE OF MATERIAL:

- Cast Iron
- Plastic (HDPE)
- Plastic (MDPE)
- Steel
- Other cast

DAMAGE TYPE:

- Severed Puncture
- Not Cut
- Severed
- Size 9" x 2"

PRESSURE:

- 25 PSIG
- 40 PSIG
- 50 PSIG
- 55 PSIG
- 60 PSIG
- 6 WC (.2163)
- 7 WC (252)
- Other 45#

PROTECTION IN PLACE:

- Building Fence None
- Post Rail Vault N/A
- Other _____

DURATION OF ESCAPING GAS:

Minutes: 120

LEAK REPORT

NUMBER: 20177

EFV Activated Yes No N/S

FEED TYPE:

- One-Way Feed
- Two-Way Feed

Number of Customers Affected: 0

Total Hours Service Was Off: 0

SERVICE ORDER NUMBER: 2064707

DAMAGED BY:

- Company Crew
- Contractor
- County
- Developer
- Farmer
- Municipality
- Property Owner/ Tenant
- Railroad
- State
- Unknown
- Utility
- Vehicle Accident
- Other _____

TYPE OF CONSTRUCTION:

- Agriculture
- Building Construction
- Building Demolition
- Cable TV
- Curbs / Sidewalk
- Drainage
- Driveway
- Electric
- Engineering / Surveying
- Fencing
- Grading
- Irrigation
- Landscaping
- Liquid Pipeline
- Milling
- Pole
- Natural Gas
- Public Transit Authority
- Railroad Maintenance
- Other _____

NOTIFICATIONS AND OTHER DETAILS OF LOCATE: 5-9-12

Locate Ticket: 1205220826 9:38 AM

Date: 5-24-12 Time: 9:30 am / pm

TYPE OF REQUEST:

- Regular Request Emergency Request
- Locate Company Notified
- Contact Name: _____
- Time Called: _____ am / pm
- Time Locator Arrived at the Site: _____ am / pm

Company Notified of Locate Near Critical Facilities Yes No N/S

Copy of Mark Out Request Provided Within 2 Working Days Yes No N/S

ONE-CALL CENTER:

- IUPPS
- OUPS
- Unknown

Vectren Claim Number: _____

TYPE OF EQUIPMENT:

- Auger
- Backhoe / Track hoe
- Boring
- Drilling
- Explosives
- Farm Equipment
- Grader / Scraper
- Hand Tools
- Milling Equipment
- Plow
- Probing Device
- Trencher
- Vacuum Equipment
- Vehicle
- Other _____

ROOT DAMAGING CAUSE:

- Abandoned Facility
- Deteriorated Facility
- Facility Could Not be Found/ Located
- Facility Was Not Located / Marked
- Failure to Maintain Clearance
- Failure to Maintain Marks
- Failure to Support Exposed Facility
- Failure to Use Hand Tools Where Required
- Improper Backfilling
- Incorrect Records / Maps
- Marking or Location Not Sufficient
- No Notification Made to One-Call
- One-Call Notification Error
- Previous Damage
- Wrong Information Provided
- Other _____

CONTRACTOR REPAIRS:

- Contractor Working for Vectren Made Repairs at Own Expense
 Yes No N/S
- Contractor Repaired Damage
 Yes No N/S

Name of Contractor: _____
 # of Regular Hours; _____
 # of Overtime Hours; _____
 # of Regular Hours; _____
 Crew Type: _____

MATERIALS OR ROAD WORK:

- Meter was replaced _____ (Stores Code)
- Regulator Was Replaced _____ (Stores Code)
- Temporary Asphalt Repair: _____ (sq. ft.)
- Permanent Asphalt Repair: _____ (sq. ft.)

RIGHT OF WAY:

- Dedicated Utility Easement
- Federal Utility Easement
- Pipeline
- Power / Transmission Line
- Private - Business
- Private - Easement
- Private - Land Owner
- Public - County Road
- Public - Interstate Highway
- Public - Other
- Public - State Highway
- Public - City Street
- Unknown

- Did Excavator Notify You Yes No
- Excavation Required Yes No
- Media at Site Yes No
- Was There Ignition of Gas? Yes No
- INVOICE: Yes No N/S

DAMAGING PARTY:

Name: Atkinson Trenching

Address: 1057 N. Atkinson Rd.

City/ State/ Zip: Vincennes

Phone: (812) 726-1306

Thomas J. Lambert 5-25-12

Prepared / Investigated By: _____ Date: _____

PARTY TO INVOICE:

Name: Atkinson Trenching

Address: 1057 N. Atkinson Rd.

City/ State/ Zip: Vincennes

Phone: (812) 726-1306

Gregg J. ... 5-29-12

Reviewed by Field Supervisor: _____ Date: _____

NORMAL NOTICE REMARK

Ticket : 1205220826 Date: 05/22/2012 Time: 09:13 Oper: SLUCAS Chan:060

State: IN Cnty: KNOX Twp: PALMYRA
 Cityname: VERN Inside: N Near: Y
 Subdivision:

Address : 5121
 Street : IN RT 61
 Cross 1 : NUGENT RD Within 1/4 mile: Y
 Location: AREA IS MARKED LOCATE ENTIRE NEW STATE RIGHT AWAY IN FRONT OF PROPERTY
 ROUTE IS FLAGGED
 ***Boring Where = IN RT 61 AT STATE RIGHT WAY
 :
 Grids : 3838B8726B 3838A8726B 3838B8726A 3838A8726A

Work type : MOVING CABLE TV LINE
 Done for : NEW WAVE COMMUNICATIONS
 Start date: 05/24/2012 Time: 09:30 Hours notice: 48/048 Priority: NORM
 Ug/Oh/Both: U Blasting: N Boring: Y Railroad: N Emergency: N
 Duration : 1 DAY Depth: 5 FEET

Company : ATKINSON TRENCHING Type: CONT
 Co addr : 1057 ATKINSON ROAD
 City : VINCENNES State: IN Zip: 47591
 Caller : JESSICA MIEURE Phone: (812)726-1306
 Contact : BILL ATKINSON--CELL Phone:
 BestTime:
 Mobile : (812)890-1634
 Fax : (812)726-4426
 Email : ATKINSON1057@YAHOO.COM

Remarks : All tickets are taken and processed on Eastern Daylight Time
 REMARK AS NEEDED - DUE TO CONSTRUCTION / MOWING - PREVIOUS TICKET NUMBER IS
 1205090849 - THANK YOU

Will you be white-lining the dig site area? YES

:

Submitted date: 05/22/2012 Time: 09:13

Members: ID0577 ID1880 ID5330 ID5845 ID8000 ID8502 SBCIN SM

Member Name	Facility Types
AT&T - DISTRIBUTION	COMMUNICATIONS
BP PIPELINE CO	PIPELINE
FRONTIER	TELEPHONE
KNOX COUNTY WATER, INC.	WATER
NEW WAVE COMMUNICATIONS / VINCENNES	CABLE TV
VECTREN - VINCENNES	GAS & ELECTRIC
WIN ENERGY REMC	ELECTRIC

[View Map](#)
[Close Map](#)

NORMAL NOTICE JOB EXTENSION

Ticket : 1205181080 Date: 05/18/2012 Time: 10:33 Oper: SARAH.HEMINGER Chan:000
 Old Tkt: 1205022335 Date: 05/02/2012 Time: 13:21 Oper: SARAH.HEMINGER Rev: 00A

State: IN Cnty: KNOX Twp: PALMYRA
 Cityname: VINCENNES Inside: N Near: Y
 Subdivision:

Address : 5121
 Street : IN RT 61
 Cross 1 : NUGENT RD Within 1/4 mile: Y
 Location: PAINT AND FLAG ENTIRE PROPERTY OF 5121 IN RT 61 AND BOTH SIDE OF IN RT 61
 ***Boring Where = IN RT 61
 :
 Grids : 3838B8726B 3838B8726A

Work type : INSTALL GAS SERVICE
 Done for : VECTREN
 Start date: 05/22/2012 Time: 10:45 Hours notice: 96/48 Priority: NORM
 Ug/Oh/Both: U Blasting: N Boring: Y Railroad: N Emergency: N
 Duration : 1 DAY Depth: 3FT TO 4FT

Company : MILLER PIPE LINE Type: CONT
 Co addr : 8850 CRAWFORDSVILLE RD
 City : INDIANAPOLIS State: IN Zip: 46234
 Caller : SARAH HEMINGER Phone: (317)295-6417
 Contact : WILLIE HODGES - CELL Phone:
 BestTime:
 Mobile : (502)376-9081
 Fax : (317)295-6418
 Email : SARAH.HEMINGER@MILLERPIPELINE.COM

Remarks : All tickets are taken and processed on Eastern Daylight Time
 NEED ALL UTILITIES TO RETURN AND REMARK PREVIOUS TICKET 1205022335
 Will you be white-lining the dig site area? NO
 :

Submitted date: 05/18/2012 Time: 10:33
 Members: ID0577 ID1880 ID5330 ID5845 ID8000 ID8502 SBCIN SM

Member Name	Facility Types
AT&T - DISTRIBUTION	COMMUNICATIONS
BP PIPELINE CO	PIPELINE
FRONTIER	TELEPHONE
KNOX COUNTY WATER, INC.	WATER
NEW WAVE COMMUNICATIONS / VINCENNES	CABLE TV
VECTREN - VINCENNES	GAS & ELECTRIC
WIN ENERGY REMC	ELECTRIC

[View Map](#)

[Close Map](#)

NORMAL NOTICE

Ticket : 1205090849 Date: 05/09/2012 Time: 09:38 Oper: JESSICA.MIEURE Chan:000

State: IN Cnty: KNOX Twp: PALMYRA
 Cityname: VERN Inside: N Near: Y
 Subdivision:

Address : 5121
 Street : IN RT 61
 Cross 1 : NUGENT RD Within 1/4 mile: Y
 Location: AREA IS MARKED LOCATE ENTIRE NEW STATE RIGHT AWAY IN FRONT OF PROPERTY
 ROUTE IS FLAGGED
 ***Boring Where = IN RT 61 AT STATE RIGHT WAY

Grids : 3838B8726B 3838A8726B 3838B8726A 3838A8726A

Work type : MOVING CABLE TV LINE
 Done for : NEW WAVE COMMUNICATIONS
 Start date: 05/11/2012 Time: 10:00 Hours notice: 48/48 Priority: NORM
 Ug/Oh/Both: U Blasting: N Boring: Y Railroad: N Emergency: N
 Duration : 1 DAY Depth: 5 FEET

Company : ATKINSON TRENCHING Type: CONT
 Co addr : 1057 ATKINSON ROAD
 City : VINCENNES State: IN Zip: 47591
 Caller : JESSICA MIEURE Phone: (812)726-1306
 Contact : BILL ATKINSON--CELL Phone:
 BestTime:
 Mobile : (812)890-1634
 Fax : (812)726-4426
 Email : ATKINSON1057@YAHOO.COM

Remarks : All tickets are taken and processed on Eastern Daylight Time
 Will you be white-lining the dig site area? YES

Submitted date: 05/09/2012 Time: 09:38
 Members: ID0577 ID1880 ID5330 ID5845 ID8000 ID8502 SBCIN SM

Member Name	Facility Types
AT&T - DISTRIBUTION	COMMUNICATIONS
BP PIPELINE CO	PIPELINE
FRONTIER	TELEPHONE
KNOX COUNTY WATER, INC.	WATER
NEW WAVE COMMUNICATIONS / VINCENNES	CABLE TV
VECTREN - VINCENNES	GAS & ELECTRIC
WIN ENERGY REMC	ELECTRIC

[View Map](#) [Close Map](#)

DAMAGE DAMAGE-SEE REMARKS

Ticket : 1205251688 Date: 05/25/2012 Time: 12:42 Oper: CALEVI Chan:031

State: IN Cnty: KNOX Twp: PALMYRA
 Cityname: VERN Inside: N Near: Y
 Subdivision:

Address : 5121
 Street : IN RT 61
 Cross 1 : NUGENT RD Within 1/4 mile: Y
 Location: AREA IS MARKED LOCATE ENTIRE NEW STATE RIGHT AWAY IN FRONT OF PROPERTY
 ROUTE IS FLAGGED
 ***Boring Where = IN RT 61 AT STATE RIGHT WAY
 :
 Grids : 3838B8726B 3838A8726B 3838B8726A 3838A8726A

Work type : MOVING CABLE TV LINE
 Done for : NEW WAVE COMMUNICATIONS
 Start date: 05/25/2012 Time: 12:43 Hours notice: 0/000 Priority: EMER
 Ug/Oh/Both: U Blasting: N Boring: Y Railroad: N Emergency: Y
 Duration : 1 DAY Depth: 5 FEET

Company : ATKINSON TRENCHING Type: CONT
 Co addr : 1057 ATKINSON ROAD
 City : VINCENNES State: IN Zip: 47591
 Caller : JESSICA MIEURE Phone: (812)726-1306
 Contact : BILL ATKINSON--CELL Phone:
 BestTime:
 Mobile : (812)890-1634
 Fax : (812)726-4426
 Email : ATKINSON1057@YAHOO.COM

Remarks : All tickets are taken and processed on Eastern Daylight Time
 PER BILL --HAVE CUT A GAS MAIN-IT IS LEAKING GAS-IN THE FRONT OF THE
 PROPERTY-CAN SMELL GAS-3 INCH YELLOW PLASTIC LINE-CREW IS ON SITE-WILL CALL
 911-WILL CALL VECTREN-PREVIOUS TICKET NUMBER -1205220826
 Will you be white-lining the dig site area? YES

Submitted date: 05/25/2012 Time: 12:42
 Members: ID0577 ID1880 ID5330 ID5845 ID8000 ID8502 SBCIN SM

Member Name	Facility Types
AT&T - DISTRIBUTION	COMMUNICATIONS
BP PIPELINE CO	PIPELINE
FRONTIER	TELEPHONE
KNOX COUNTY WATER, INC.	WATER
NEW WAVE COMMUNICATIONS / VINCENNES	CABLE TV
VECTREN - VINCENNES	GAS & ELECTRIC
WIN ENERGY REMC	ELECTRIC

[View Map](#) | [Close Map](#)

Service Order Status

Friday, June 8, 2012

Enter Service Order Number:

2064707



Banner Instance: CS03PROD CS01PROD CS02PROD

Order Number: S2064707
Order Type: LEAK
Order Status: Completed

Customer: 300244697 - NIBEL DAVID M
Prem: 1243515 - 5121 E STATE ROAD 61

Technician: 0381 - Cardinal, Thomas

Order Dates and Times

Need Date: 5/25/2012 1:04:00 PM
Time Created: 5/25/2012 12:56:58 PM
Time Dispatched: 5/25/2012 12:56:58 PM
Time In Route: 5/25/2012 4:33:36 PM
Time On-Site: 5/25/2012 4:33:42 PM
Tech Complete: 5/25/2012 2:25:00 PM
Time Closed: 5/25/2012 5:55:04 PM

Events Performed/Completion Code

LKOT - CMP

Meter Information

Current ReadStatus

Old Meter: 9157 **Active**
New Meter:

Completion Notes

squeezed off main and made repairs

Request Notes

05/25/12 cut line blowing per Bill Atkinson....xst Lemmons Rd...tx 812-890-1634....crew on site...line was located...advised precautions...

MDSI Event Dates and Times

Event	Date/Time	User
AsnAssignmentEnRoute_evt	5/25/2012 4:33:36 PM	Cardinal, Thomas
AsnAssignmentOnSite_evt	5/25/2012 4:33:42 PM	Cardinal, Thomas
AsnAssignmentManualAck_evt	5/25/2012 4:33:43 PM	Cardinal, Thomas
OrdOrderComplete_evt	5/25/2012 5:55:04 PM	Cardinal, Thomas

NOTE: The Reporting database replicates in near real-time; it has been approximately 1 minute(s) since the last transaction replicated.



INDIANA UTILITY REGULATORY COMMISSION
101 W. WASHINGTON STREET, SUITE 1500E
INDIANAPOLIS, INDIANA 46204-3407

<http://www.in.gov/iurc>
Office: (317) 232-2701
Facsimile: (317) 232-6758

July 13, 2012

Ms. Darlene Kulhanek
Vectren
1 N Main Street
Evansville, IN 47702

Subject: Investigation Request for Information

Date of Event: 5/25/2012

Event Location: 5121 / In Rt 61, Vern

Facility Owner: Vectren

Excavator: Atkinson Trenching

Other Party: N/A

Pipeline Division Case No. 3107

Dear Ms. Kulhanek:

Pursuant to Indiana Code 8-1-26, the *Indiana Damage to Underground Facilities Act*, the Pipeline Safety Division of the Indiana Utility Regulatory Commission ("Pipeline Division") is required to investigate reported incidents of alleged statutory violations involving underground pipeline safety. The purpose of this statute is to promote excavation and pipeline safety and to reduce the imminent danger to life, health, property, or loss of service associated with unsafe digging practices. Please note that the investigation does not entail determining criminal liability or a civil determination of fault or damages; however, it does determine whether any statutory violations were committed regarding public safety.

The Pipeline Division received information regarding potential statutory violations regarding the date and location referenced above. You were identified as a person or entity that might have information that would assist the Pipeline Division in its investigation. Therefore, we have contacted you in order to receive the full account of information in order to make a fair determination related to the circumstances of this incident.

We have asked all involved parties, entities and witnesses to provide *written* information within *30 days* in order to meet legal deadlines to conclude our investigation. **Please consider this letter as a formal request to receive any and all information and evidence (including a narrative, documentation, maps, photographs or any other written information) you can access regarding anything you may know about the incident referenced above.**



DAMAGE INFORMATION REPORT – PIPELINE SAFETY DIVISION

State Form 54122 (R2 / 7-11)
INDIANA UTILITY REGULATORY COMMISSION

Submitted to IURC-Pipeline Safety on: 07-19-2012

Who is submitting this information?

Name of person providing this information: Darlene Kulhanek

Business address (*number and street*): 1 Main Street

City, State, and ZIP code: Evansville, IN 47711

Telephone number (*area code*): 812-491-4227

Fax number (*area code*): 812-491-4504

E-mail address: dkulhanek@vectren.com

Excavator Information, if known

Full name: Atkinson Trenching

Business address (*number and street*): 1057 Atkinson Road

City, State, and ZIP code: Vincennes, IN 47591

Telephone number (*area code*): 812-726-1306

Fax number (*area code*): 812-726-4426

E-mail address: Unknown

Excavation or Demolition Information

Excavator type: Contractor

Excavation or demolition equipment: Trencher

Type of work performed: Cable TV

Date and Location of Damage

Date of damage (*month, day, year*): 5-25-2012

County: Knox

City: Vincennes

Street address (*number and street, city, state, and ZIP code*):
5121 State Rd 61, Vincennes, IN

Nearest intersection: Unknown

Right of way where damage occurred: Dedicated Public Utility Easement

Was there a release of product? Yes

If yes, was there an ignition of product? No

Were evacuations necessary as a result of release? No

If yes, how many evacuated? 0

Was there a customer service interruption? No

If yes, how many affected? 0

Time to restore service (*in hours*): 0

Enter number of injuries, if applicable and known: 0

Enter number of fatalities, if applicable and known: 0

Property damage, Estimate \$ 4,264.43

Affected Facility Information

What type of pipeline was damaged? Natural Gas

What was the affected facility? Distribution

What was the depth of the facility, in inches? _____

Notification, Locating, Marking

Did excavator request locates prior to commencing work? Yes

Enter Indiana 811 ticket number, if known: 1205220826

Was the locate request completed within two working days? Yes

If locates were performed, were they done so by a contractor or pipeline employee? Contract Locator

If a contractor locator, enter the company name, if known: USIC _____

Were facility marks visible in the area of excavation? No

Were facilities marked correctly? No

Type of markings used: Paint

If other, please specify: _____

Was site marked by "White Lining"? No

Were special instructions part of the locate request? Unknown/Other

Were maps used to complete the locate request? Unknown/Other

Were pipeline company representatives on site during excavation? No

Did the excavator notify the operator in the event of this damage? Yes

Did the excavator notify Indiana 811 in the event of this damage? Yes


Did the excavator notify 911 in the event of a release of product? Unknown/Other

Description of Cause

Select from the list the most accurate cause for the damage: --Facility marking or location not sufficient

Additional Comments

4" plastic main damaged by trencher. > 24"




1 VECTREN ENERGY DELIVERY OF INDIANA - SOUTH

NOW DUE
\$4,264.43

USIC INC
9045 N RIVER ROAD, SUITE 300
INDIANAPOLIS, IN 46240

Type: GAS
Invoice: FDS0016291
BillToID: 31983
Billing Date: 7/11/2012
Date of Loss: 5/25/2012
5857 103.0509

Please return this portion with your remittance.



Mail Payment To:
Vectren Utilities Holding Group, Inc.
VECTREN ENERGY DELIVERY OF INDIANA - SOUTH
1239 Reliable Parkway
Chicago, IL 60686-0012
Inquiries: 1-877-902-2934, Mon.-Fri., 8-5
Risk Management/Claims Department

NOW DUE
\$4,264.43

USIC INC
9045 N RIVER ROAD, SUITE 300
INDIANAPOLIS, IN 46240

Type: GAS
Invoice: FDS0016291
BillToID: 31983
Billing Date: 7/11/2012
Date of Loss: 5/25/2012

Invoice For Costs to Repair and Reconstruct Damaged Property

Address: 5121 STATE RD 61, VINCENNES
4" PLASTIC MAIN CUT BY TRENCHER. > 24".

Material:	\$117.93
Company Labor:	\$1,101.93
Contract Labor:	\$0.00
Transportation/Equipment:	\$173.19
Misc:	\$0.00
Gas Loss:	\$2,871.38
Adjustments:	\$0.00
Payments:	\$0.00
<hr/> Total:	\$4,264.43

5857 103.0509

Remember, call two (2) working days before digging. Contact I.U.P.P.S. at 1-800-382-5544.

West, Josh


From: Morgan Thompson <MorganThompson@usicinc.com>
Sent: Wednesday, July 11, 2012 3:25 PM
To: West, Josh
Cc: Morgan Thompson
Subject: RE: FDS0016291 - 5121 ST RD 61 - VINCENNES - 5/25/12

Josh,

I show this one as ours. Do you have the total on this one?

Thanks,

Morgan Thompson
Claims Coordinator
O: 317 776 1479 x109
C: 317 538 7301



From: West, Josh [<mailto:jawest@Vectren.com>]
Sent: Wednesday, July 11, 2012 4:21 PM
To: Morgan Thompson
Subject: FDS0016291 - 5121 ST RD 61 - VINCENNES - 5/25/12

Can you please send your report and photos?

Thanks

Josh West | Facility Damages Specialist | Vectren Energy Delivery
Desk 812.491.4586 | Cell 812.205.8251 | Fax 812.491.4504

DISCLAIMER: +++The information transmitted is intended only for designated recipient(s) and may contain confidential and/or privileged material. Any review, retransmission, dissemination or other use of, or taking of any action in reliance upon, this information by persons or entities other than the intended recipient is prohibited. If you received this in error, please contact the sender and do not retain but destroy any copies of this document.+++.



1 VECTREN ENERGY DELIVERY OF INDIANA - SOUTH

NOW DUE

\$4,264.43

ATKINSON TRENCHING
1057 N ATKINSON ROAD
VINCENNES, IN 47591

Type: GAS
Invoice: FDS0016291
BillToID: 31983
Billing Date: 7/6/2012
Date of Loss: 5/25/2012
5857 103.0509

Please return this portion with your remittance.



Mail Payment To:
Vectren Utilities Holding Group, Inc.
VECTREN ENERGY DELIVERY OF INDIANA - SOUTH
1239 Reliable Parkway
Chicago, IL 60686-0012
Inquiries: 1-877-902-2934, Mon.-Fri., 8-5
Risk Management/Claims Department

NOW DUE
\$4,264.43

ATKINSON TRENCHING
1057 N ATKINSON ROAD
VINCENNES, IN 47591

Type: GAS
Invoice: FDS0016291
BillToID: 31983
Billing Date: 7/6/2012
Date of Loss: 5/25/2012

Invoice For Costs to Repair and Reconstruct Damaged Property

Address: 5121 STATE RD 61, VINCENNES
4" PLASTIC MAIN CUT BY TRENCHER. DID NOT HAND EXPOSE.

Material:	\$117.93
Company Labor:	\$1,101.93
Contract Labor:	\$0.00
Transportation/Equipment:	\$173.19
Misc:	\$0.00
Gas Loss:	\$2,871.38
Adjustments:	\$0.00
Payments:	\$0.00
Total:	\$4,264.43

5857 103.0509

Remember, call two (2) working days before digging. Contact I.U.P.P.S. at 1-800-382-5544.

Vectren Claim Number: _____

FDS 0016291

Task No: 103,0509 Capital / O & M (circle one)

Police Report / MO #: _____

Date of Damage 5/25/12

Vectren Claims Camera:

Cost Center # 5857

FACILITIES DAMAGE REPORT

GAS

VE02034
7763205 4

Time Occurred 12:30 am / pm

Time Found 1:30 am / pm

Latitude 38.37556 Longitude: -87.269050

DAMAGE SITE:

Address 5121 SR 61 Lot # _____

FACILITY TYPE:

- Distribution Propane
- Service Storage
- Transmission: (include supplemental report)

County KNX City Vincennes State IN Township Palmyra

FACILITIES DAMAGED:

ORIFICE SIZE(S):	(1)	(2)	(3)
0.50 inch	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5/8 inch	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
0.75 inch	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.00 inch	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1.25 inch	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2.00 inch	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3.00 inch	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4.00 inch	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5.00 inch	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6.00 inch	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10.00 inch	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
12.00 inch	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
16.00 inch	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
20.00 inch	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Other _____			

- Farm Tap
- Heater
- Main
- Meter (Residential)
- Meter (Industrial / Commercial)
- Odorizer
- Regulator Station
- Relief Valve
- Riser
- Service Line
- Valve
- Other _____

VISUAL OBSERVATION AT DAMAGE SITE:

- Visual Observation: Above Ground Below Ground
- Locate Applicable: Yes No N/S
- Facilities Properly Marked: Yes No N/S
- Marking Methods: Conventional Flags None Whiskers
- Offset Paint Stakes N/S
- Locate Marking Faded: Yes No N/S
- Wrong Address Requested: Yes No N/S

Facilities Improperly Located:

- Qualified Locator Could Not Have Accurately Located
- Inaccurate Maps / Cards
- Broken or No Tracer Wire (Plastic)
- Insulation Preventing Accurate Locate

Locator Error:

- Failure to Follow Policy
- Inappropriate Site Markings
- Incomplete Locate
- No Locates Performed
- Qualified Locator Could Have Accurately Located
- Wrong Address Located
- Marking Off By: 24" (Feet / Inches)

- Were Facility Marks Visible: Yes No
- Was Area White Lined: Yes No Destroyed
- Positive Response: Yes No Destroyed
- Tolerance Zone Violated: Yes No
- Part of Project: Yes No
- Company Representative On-Site: Yes No

TYPE OF MATERIAL:

- Cast Iron
- Plastic (HDPE)
- Plastic (MDPE)
- Steel
- Other cast

DAMAGE TYPE:

- Severed Puncture
- Not Cut
- Severed
- Size 9" x 2"

PRESSURE:

- 25 PSIG
- 40 PSIG
- 50 PSIG
- 55 PSIG
- 60 PSIG
- 6 WC (.2163)
- 7 WC (252)
- Other 45#

PROTECTION IN PLACE:

- Building Fence None
- Post Rail Vault N/A
- Other _____

DURATION OF ESCAPING GAS:

Minutes: 120

LEAK REPORT

NUMBER: 20177

EFV Activated Yes No N/S

FEED TYPE:

- One-Way Feed
- Two-Way Feed

Number of Customers Affected: 0

Total Hours Service Was Off: 0

SERVICE ORDER NUMBER: 2064707

DAMAGED BY:

- Company Crew
- Contractor
- County
- Developer
- Farmer
- Municipality
- Property Owner/ Tenant
- Railroad
- State
- Unknown
- Utility
- Vehicle Accident
- Other _____

TYPE OF CONSTRUCTION:

- Agriculture
- Building Construction
- Building Demolition
- Cable TV
- Curbs / Sidewalk
- Drainage
- Driveway
- Electric
- Engineering / Surveying
- Fencing
- Grading
- Irrigation
- Landscaping
- Liquid Pipeline
- Milling
- Pole
- Natural Gas
- Public Transit Authority
- Railroad Maintenance
- Other _____

NOTIFICATIONS AND OTHER DETAILS OF LOCATE: 5-9-12

Locate Ticket: 1205220826 9:38 AM

Date: 5-24-12 Time: 9:30 am / pm

TYPE OF REQUEST:

- Regular Request Emergency Request
- Locate Company Notified
- Contact Name: _____
- Time Called: _____ am / pm
- Time Locator Arrived at the Site: _____ am / pm

Company Notified of Locate Near Critical Facilities Yes No N/S

Copy of Mark Out Request Provided Within 2 Working Days Yes No N/S

ONE-CALL CENTER:

- IUPPS
- OUPS
- Unknown

Vectren Claim Number: _____

TYPE OF EQUIPMENT:

- Auger
- Backhoe / Track hoe
- Boring
- Drilling
- Explosives
- Farm Equipment
- Grader / Scraper
- Hand Tools
- Milling Equipment
- Plow
- Probing Device
- Trencher
- Vacuum Equipment
- Vehicle
- Other _____

ROOT DAMAGING CAUSE:

- Abandoned Facility
- Deteriorated Facility
- Facility Could Not be Found/ Located
- Facility Was Not Located / Marked
- Failure to Maintain Clearance
- Failure to Maintain Marks
- Failure to Support Exposed Facility
- Failure to Use Hand Tools Where Required
- Improper Backfilling
- Incorrect Records / Maps
- Marking or Location Not Sufficient
- No Notification Made to One-Call
- One-Call Notification Error
- Previous Damage
- Wrong Information Provided
- Other _____

CONTRACTOR REPAIRS:

- Contractor Working for Vectren Made Repairs at Own Expense
 Yes No N/S
- Contractor Repaired Damage
 Yes No N/S

Name of Contractor: _____
 # of Regular Hours; _____
 # of Overtime Hours; _____
 # of Regular Hours; _____
 Crew Type: _____

MATERIALS OR ROAD WORK:

- Meter was replaced _____ (Stores Code)
- Regulator Was Replaced _____ (Stores Code)
- Temporary Asphalt Repair: _____ (sq. ft.)
- Permanent Asphalt Repair: _____ (sq. ft.)

RIGHT OF WAY:

- Dedicated Utility Easement
- Federal Utility Easement
- Pipeline
- Power / Transmission Line
- Private - Business
- Private - Easement
- Private - Land Owner
- Public - County Road
- Public - Interstate Highway
- Public - Other
- Public - State Highway
- Public - City Street
- Unknown

- Did Excavator Notify You Yes No
- Excavation Required Yes No
- Media at Site Yes No
- Was There Ignition of Gas? Yes No
- INVOICE: Yes No N/S

DAMAGING PARTY:

Name: Atkinson Trenching

Address: 1057 N. Atkinson Rd.

City/ State/ Zip: Vincennes

Phone: (812) 726-1306

Thomas J. Lambert 5-25-12

Prepared / Investigated By: _____ Date: _____

PARTY TO INVOICE:

Name: Atkinson Trenching

Address: 1057 N. Atkinson Rd.

City/ State/ Zip: Vincennes

Phone: (812) 726-1306

Gregg J. ... 5-29-12

Reviewed by Field Supervisor: _____ Date: _____

NORMAL NOTICE REMARK

Ticket : 1205220826 Date: 05/22/2012 Time: 09:13 Oper: SLUCAS Chan:060

State: IN Cnty: KNOX Twp: PALMYRA
 Cityname: VERN Inside: N Near: Y
 Subdivision:

Address : 5121
 Street : IN RT 61
 Cross 1 : NUGENT RD Within 1/4 mile: Y
 Location: AREA IS MARKED LOCATE ENTIRE NEW STATE RIGHT AWAY IN FRONT OF PROPERTY
 ROUTE IS FLAGGED
 ***Boring Where = IN RT 61 AT STATE RIGHT WAY
 :
 Grids : 3838B8726B 3838A8726B 3838B8726A 3838A8726A

Work type : MOVING CABLE TV LINE
 Done for : NEW WAVE COMMUNICATIONS
 Start date: 05/24/2012 Time: 09:30 Hours notice: 48/048 Priority: NORM
 Ug/Oh/Both: U Blasting: N Boring: Y Railroad: N Emergency: N
 Duration : 1 DAY Depth: 5 FEET

Company : ATKINSON TRENCHING Type: CONT
 Co addr : 1057 ATKINSON ROAD
 City : VINCENNES State: IN Zip: 47591
 Caller : JESSICA MIEURE Phone: (812)726-1306
 Contact : BILL ATKINSON--CELL Phone:
 BestTime:
 Mobile : (812)890-1634
 Fax : (812)726-4426
 Email : ATKINSON1057@YAHOO.COM

Remarks : All tickets are taken and processed on Eastern Daylight Time
 REMARK AS NEEDED - DUE TO CONSTRUCTION / MOWING - PREVIOUS TICKET NUMBER IS
 1205090849 - THANK YOU
 Will you be white-lining the dig site area? YES
 :

Submitted date: 05/22/2012 Time: 09:13
 Members: ID0577 ID1880 ID5330 ID5845 ID8000 ID8502 SBCIN SM

Member Name	Facility Types
AT&T - DISTRIBUTION	COMMUNICATIONS
BP PIPELINE CO	PIPELINE
FRONTIER	TELEPHONE
KNOX COUNTY WATER, INC.	WATER
NEW WAVE COMMUNICATIONS / VINCENNES	CABLE TV
VECTREN - VINCENNES	GAS & ELECTRIC
WIN ENERGY REMC	ELECTRIC

[View Map](#) | [Close Map](#)

NORMAL NOTICE JOB EXTENSION

Ticket : 1205181080 Date: 05/18/2012 Time: 10:33 Oper: SARAH.HEMINGER Chan:000
 Old Tkt: 1205022335 Date: 05/02/2012 Time: 13:21 Oper: SARAH.HEMINGER Rev: 00A

State: IN Cnty: KNOX Twp: PALMYRA
 Cityname: VINCENNES Inside: N Near: Y
 Subdivision:

Address : 5121
 Street : IN RT 61
 Cross 1 : NUGENT RD Within 1/4 mile: Y
 Location: PAINT AND FLAG ENTIRE PROPERTY OF 5121 IN RT 61 AND BOTH SIDE OF IN RT 61
 ***Boring Where = IN RT 61
 :
 Grids : 3838B8726B 3838B8726A

Work type : INSTALL GAS SERVICE
 Done for : VECTREN
 Start date: 05/22/2012 Time: 10:45 Hours notice: 96/48 Priority: NORM
 Ug/Oh/Both: U Blasting: N Boring: Y Railroad: N Emergency: N
 Duration : 1 DAY Depth: 3FT TO 4FT

Company : MILLER PIPE LINE Type: CONT
 Co addr : 8850 CRAWFORDSVILLE RD
 City : INDIANAPOLIS State: IN Zip: 46234
 Caller : SARAH HEMINGER Phone: (317)295-6417
 Contact : WILLIE HODGES - CELL Phone:
 BestTime:
 Mobile : (502)376-9081
 Fax : (317)295-6418
 Email : SARAH.HEMINGER@MILLERPIPELINE.COM

Remarks : All tickets are taken and processed on Eastern Daylight Time
 NEED ALL UTILITIES TO RETURN AND REMARK PREVIOUS TICKET 1205022335
 Will you be white-lining the dig site area? NO
 :

Submitted date: 05/18/2012 Time: 10:33
 Members: ID0577 ID1880 ID5330 ID5845 ID8000 ID8502 SBCIN SM

Member Name	Facility Types
AT&T - DISTRIBUTION	COMMUNICATIONS
BP PIPELINE CO	PIPELINE
FRONTIER	TELEPHONE
KNOX COUNTY WATER, INC.	WATER
NEW WAVE COMMUNICATIONS / VINCENNES	CABLE TV
VECTREN - VINCENNES	GAS & ELECTRIC
WIN ENERGY REMC	ELECTRIC

[View Map](#)

[Close Map](#)

NORMAL NOTICE

Ticket : 1205090849 Date: 05/09/2012 Time: 09:38 Oper: JESSICA.MIEURE Chan:000

State: IN Cnty: KNOX Twp: PALMYRA
 Cityname: VERN Inside: N Near: Y
 Subdivision:

Address : 5121
 Street : IN RT 61
 Cross 1 : NUGENT RD Within 1/4 mile: Y
 Location: AREA IS MARKED LOCATE ENTIRE NEW STATE RIGHT AWAY IN FRONT OF PROPERTY
 ROUTE IS FLAGGED
 ***Boring Where = IN RT 61 AT STATE RIGHT WAY

Grids : 3838B8726B 3838A8726B 3838B8726A 3838A8726A

Work type : MOVING CABLE TV LINE
 Done for : NEW WAVE COMMUNICATIONS
 Start date: 05/11/2012 Time: 10:00 Hours notice: 48/48 Priority: NORM
 Ug/Oh/Both: U Blasting: N Boring: Y Railroad: N Emergency: N
 Duration : 1 DAY Depth: 5 FEET

Company : ATKINSON TRENCHING Type: CONT
 Co addr : 1057 ATKINSON ROAD
 City : VINCENNES State: IN Zip: 47591
 Caller : JESSICA MIEURE Phone: (812)726-1306
 Contact : BILL ATKINSON--CELL Phone:
 BestTime:
 Mobile : (812)890-1634
 Fax : (812)726-4426
 Email : ATKINSON1057@YAHOO.COM

Remarks : All tickets are taken and processed on Eastern Daylight Time
 Will you be white-lining the dig site area? YES

Submitted date: 05/09/2012 Time: 09:38
 Members: ID0577 ID1880 ID5330 ID5845 ID8000 ID8502 SBCIN SM

Member Name	Facility Types
AT&T - DISTRIBUTION	COMMUNICATIONS
BP PIPELINE CO	PIPELINE
FRONTIER	TELEPHONE
KNOX COUNTY WATER, INC.	WATER
NEW WAVE COMMUNICATIONS / VINCENNES	CABLE TV
VECTREN - VINCENNES	GAS & ELECTRIC
WIN ENERGY REMC	ELECTRIC

[View Map](#) [Close Map](#)

DAMAGE DAMAGE-SEE REMARKS

Ticket : 1205251688 Date: 05/25/2012 Time: 12:42 Oper: CALEVI Chan:031

State: IN Cnty: KNOX Twp: PALMYRA
 Cityname: VERN Inside: N Near: Y
 Subdivision:

Address : 5121
 Street : IN RT 61
 Cross 1 : NUGENT RD Within 1/4 mile: Y
 Location: AREA IS MARKED LOCATE ENTIRE NEW STATE RIGHT AWAY IN FRONT OF PROPERTY
 ROUTE IS FLAGGED
 ***Boring Where = IN RT 61 AT STATE RIGHT WAY
 :
 Grids : 3838B8726B 3838A8726B 3838B8726A 3838A8726A

Work type : MOVING CABLE TV LINE
 Done for : NEW WAVE COMMUNICATIONS
 Start date: 05/25/2012 Time: 12:43 Hours notice: 0/000 Priority: EMER
 Ug/Oh/Both: U Blasting: N Boring: Y Railroad: N Emergency: Y
 Duration : 1 DAY Depth: 5 FEET

Company : ATKINSON TRENCHING Type: CONT
 Co addr : 1057 ATKINSON ROAD
 City : VINCENNES State: IN Zip: 47591
 Caller : JESSICA MIEURE Phone: (812)726-1306
 Contact : BILL ATKINSON--CELL Phone:
 BestTime:
 Mobile : (812)890-1634
 Fax : (812)726-4426
 Email : ATKINSON1057@YAHOO.COM

Remarks : All tickets are taken and processed on Eastern Daylight Time
 PER BILL --HAVE CUT A GAS MAIN-IT IS LEAKING GAS-IN THE FRONT OF THE
 PROPERTY-CAN SMELL GAS-3 INCH YELLOW PLASTIC LINE-CREW IS ON SITE-WILL CALL
 911-WILL CALL VECTREN-PREVIOUS TICKET NUMBER -1205220826
 Will you be white-lining the dig site area? YES

Submitted date: 05/25/2012 Time: 12:42
 Members: ID0577 ID1880 ID5330 ID5845 ID8000 ID8502 SBCIN SM

Member Name	Facility Types
AT&T - DISTRIBUTION	COMMUNICATIONS
BP PIPELINE CO	PIPELINE
FRONTIER	TELEPHONE
KNOX COUNTY WATER, INC.	WATER
NEW WAVE COMMUNICATIONS / VINCENNES	CABLE TV
VECTREN - VINCENNES	GAS & ELECTRIC
WIN ENERGY REMC	ELECTRIC

[View Map](#)

[Close Map](#)

Service Order Status

Friday, June 8, 2012

Enter Service Order Number:

2064707



Banner Instance: CS03PROD CS01PROD CS02PROD

Order Number: S2064707
Order Type: LEAK
Order Status: Completed

Customer: 300244697 - NIBEL DAVID M
Prem: 1243515 - 5121 E STATE ROAD 61

Technician: 0381 - Cardinal, Thomas

Order Dates and Times

Need Date: 5/25/2012 1:04:00 PM
Time Created: 5/25/2012 12:56:58 PM
Time Dispatched: 5/25/2012 12:56:58 PM
Time In Route: 5/25/2012 4:33:36 PM
Time On-Site: 5/25/2012 4:33:42 PM
Tech Complete: 5/25/2012 2:25:00 PM
Time Closed: 5/25/2012 5:55:04 PM

Events Performed/Completion Code

LKOT - CMP

Meter Information

Current ReadStatus
Old Meter: 9157 Active
New Meter:

Completion Notes

squeezed off main and made repairs

Request Notes

05/25/12 cut line blowing per Bill Atkinson....xst Lemmons Rd...tx 812-890-1634....crew on site...line was located...advised precautions...

MDSI Event Dates and Times

Event	Date/Time	User
AsnAssignmentEnRoute_evt	5/25/2012 4:33:36 PM	Cardinal, Thomas
AsnAssignmentOnSite_evt	5/25/2012 4:33:42 PM	Cardinal, Thomas
AsnAssignmentManualAck_evt	5/25/2012 4:33:43 PM	Cardinal, Thomas
OrdOrderComplete_evt	5/25/2012 5:55:04 PM	Cardinal, Thomas

NOTE: The Reporting database replicates in near real-time; it has been approximately 1 minute(s) since the last transaction replicated.

op 170



INFORMATION REQUEST

State Form 54909 (2-12)

INDIANA UTILITY REGULATORY COMMISSION - PIPELINE SAFETY DIVISION

RECEIVED

JUL 24 2012

INDIANA UTILITY
REGULATORY COMMISSION

Case Number: 3107

The Pipeline Safety Division of the Indiana Utility Regulatory Commission requests any and all information you can provide regarding the following criteria.

Upon completion of answers select email button for submission.

The Parties

Excavator Information:

Business Name: ATKINSON TRENCHING INC.

Responsible Party Personal Name: WILLIAM G ATKINSON "BILL"

Title (if any): OWNER/PRESIDENT

Address (number and street): 1057 N ATKINSON RD

City, State and ZIP Code: VINCENNES INDIANA 47591

Preferred Telephone Number (area code): 812.726.1306

Cellular Telephone Number (area code): 812.890.1634

Email Address: ATKINSON1057@YAHOO.COM

Facility Information:

Business Name: VECTREN

Responsible Party Personal Name: _____

Title (if any): _____

Address (number and street): 1239 RELIABLE PARKWAY

ATKINSON TRENCHING INC CASE # 3107



Atkinson Trenching Inc. Case # 3107






Atkinson Trenching Inc Case # 3107

Atkinson Trenching Inc. Case # 3107



Atkinson Trenching Inc Case # 3107



Case #3107

NORMAL NOTICE REMARK

Ticket : 1205220826 Date: 05/22/2012 Time: 09:13 Oper: SLUCAS Chan:060

State: IN Cnty: KNOX Twp: PALMYRA
 Cityname: VERN Inside: N Near: Y
 Subdivision:

Address : 5121
 Street : IN RT 61
 Cross 1 : NUGENT RD Within 1/4 mile: Y
 Location: AREA IS MARKED LOCATE ENTIRE NEW STATE RIGHT AWAY IN FRONT OF PROPERTY
 ROUTE IS FLAGGED
 ***Boring Where = IN RT 61 AT STATE RIGHT WAY
 :
 Grids : 3838B8726B 3838A8726B 3838B8726A 3838A8726A

Work type : MOVING CABLE TV LINE
 Done for : NEW WAVE COMMUNICATIONS
 Start date: 05/24/2012 Time: 09:30 Hours notice: 48/048 Priority: NORM
 Ug/Oh/Both: U Blasting: N Boring: Y Railroad: N Emergency: N
 Duration : 1 DAY Depth: 5 FEET

Company : ATKINSON TRENCHING Type: CONT
 Co addr : 1057 ATKINSON ROAD
 City : VINCENNES State: IN Zip: 47591
 Caller : JESSICA MIEURE Phone: (812)726-1306
 Contact : BILL ATKINSON--CELL Phone:
 BestTime:
 Mobile : (812)890-1634
 Fax : (812)726-4426
 Email : ATKINSON1057@YAHOO.COM

Remarks : All tickets are taken and processed on Eastern Daylight Time
 REMARK AS NEEDED - DUE TO CONSTRUCTION / MOWING - PREVIOUS TICKET NUMBER IS
 1205090849 - THANK YOU

Will you be white-lining the dig site area? YES

Submitted date: 05/22/2012 Time: 09:13
 Members: ID0577 ID1880 ID5330 ID5845 ID8000 ID8502 SBCIN SM

Member Name	Facility Types
AT&T - DISTRIBUTION	COMMUNICATIONS
BP PIPELINE CO	PIPELINE
FRONTIER	TELEPHONE
KNOX COUNTY WATER, INC.	WATER
NEW WAVE COMMUNICATIONS / VINCENNES	CABLE TV
VECTREN - VINCENNES	GAS & ELECTRIC
WIN ENERGY REMC	ELECTRIC

[View Map] [Close Map]