



Pipeline Safety Division Investigation Report

Investigation regarding: Lj Enterprises

UPPAC Database Record ID: **4191**

Report Date: 04/05/2013

Investigator: Howard Friend

Damage Date: 10/6/2012

Damage Address: 320 Sr 16, Roann, Wabash County

The Parties

Excavator: **Lj Enterprises** (Contractor)

Address: Po Box 161, Roann, In 46974

Facility Owner: **NIPSCO**

Pipeline Facility

Facility Type: Natural Gas

Facility Function: Service/Drop

Type of Equipment: Backhoe/Trackhoe

Type of Work Performed: Drainage

Damage Impact

Product Release: Yes

Ignition: No

Service Interruption: True

Number of Customers Affected: 1

Injuries: 0

Fatalities: 0

Repair Cost (if known): \$

Excavator Activities/Cause of Damage Information:

Excavator Request Locates: Yes
Date:

Indiana 811 Ticket Number: 1209141837 - EXPIRED Original Start

Locate Instructions:

Follow-Up Locate Instructions (if applicable):

Synopsis: A natural gas service was damaged during excavation for drainage.

Findings: The excavator provided notice of excavation on September 14th, 2012 and damaged the line twenty two (22) days later.

Conclusion: The excavator was working with expired locate notification.

Violation: 8-1-26-16(g)(expire) Failure to provide notice of excavation - expired ticket.



DAMAGE INFORMATION REPORT – PIPELINE SAFETY DIVISION

State Form 54122 (R2 / 7-11)

INDIANA UTILITY REGULATORY COMMISSION

Submitted to IURC-Pipeline Safety on: Nov 26, 2012

Who is submitting this information?

Name of person providing this information: Carrie Ludwig (NIPSCO)

Business address (*number and street*): 3511 East 15th Ave

City, State, and ZIP code: Gary, IN 46403

Telephone number (*area code*): 219 962 0422

Fax number (*area code*): 219 962 0404

E-mail address: cludwig@nisource.com

Excavator Information, if known

Full name: LJ Enterprises

Business address (*number and street*): PO Box 161

City, State, and ZIP code: Roann, IN 46974

Telephone number (*area code*): 260 416 7530

Fax number (*area code*): _____

E-mail address: _____

Excavation or Demolition Information

Excavator type: Contractor

Excavation or demolition equipment: Backhoe/Trackhoe

Type of work performed: Drainage

Date and Location of Damage

Date of damage (*month, day, year*): Oct 6, 2012

County: Wabash

City: Roann

Street address (*number and street, city, state, and ZIP code*):
320 SR 16

Nearest intersection: Arnold St

Right of way where damage occurred: Private - Business

Was there a release of product? Yes

If yes, was there an ignition of product? No

Were evacuations necessary as a result of release? No

If yes, how many evacuated? _____

Was there a customer service interruption? Yes

If yes, how many affected? 1

Time to restore service (*in hours*): 1.5

Enter number of injuries, if applicable and known: 0

Enter number of fatalities, if applicable and known: 0

Property damage, Estimate \$ _____

Affected Facility Information

What type of pipeline was damaged? Natural Gas

What was the affected facility? Service/Drop

What was the depth of the facility, in inches? 48

Notification, Locating, Marking

Did excavator request locates prior to commencing work? Yes

Enter Indiana 811 ticket number, if known: 1209141837

Was the locate request completed within two working days? Yes

If locates were performed, were they done so by a contractor or pipeline employee? Contract Locator

If a contractor locator, enter the company name, if known: USIC

Were facility marks visible in the area of excavation? Yes

Were facilities marked correctly? No

Type of markings used: Paint and Flags

If other, please specify: _____

Was site marked by "White Lining"? No

Were special instructions part of the locate request? Unknown/Other

Were maps used to complete the locate request? Unknown/Other

Were pipeline company representatives on site during excavation? No

Did the excavator notify the operator in the event of this damage? Yes

Did the excavator notify Indiana 811 in the event of this damage? No

Did the excavator notify 911 in the event of a release of product? Unknown/Other

Description of Cause

Select from the list the most accurate cause for the damage: --No notification made to the one-call center

Additional Comments

Part of the tracer wire was missing therefore the signal was lost 5' from catch basin where facility was hit.
Nipsco emergency repair ticket #: 1210060085

Excavator allowed the locate ticket to expire. Calling in a current locate could have provided the gas operator opportunity to supply complete facility markings. MAO 12/4/2012.



150 West Market Street, Suite 600
Indianapolis, IN 46204

March 6, 2013

Via Electronic Transmission – PipelineDamageCase@urc.in.gov

Pipeline Safety Division – Case No. 4191
Indiana Utility Regulatory Commission
101 West Washington Street, Suite 1500 East
Indianapolis, Indiana 46204

RE: Investigation Request for Information; Pipeline Division Case No. 4191

To Whom It May Concern:

Attached please find Northern Indiana Public Service Company's ("NIPSCO") written information, and supporting documentation, relating to the following event:

Date of Event: 10/6/2012

Event Location: 320 Sr 16

City: Roann

Facility Owner: Northern Indiana Public Service Company

Excavator: Lj Enterprises

Other Party: N/A

Pipeline Division Case No. 4191

NIPSCO has reviewed its recovery and damage prevention files for this matter and has provided answers, when known, to the list of questions set forth in the Information Request. To the extent available, NIPSCO is also providing a copy of the Damage Information Report – Pipeline Safety Division previously submitted by NIPSCO to IURC Pipeline Safety as well as additional documentation relating to this Event Location.

Upon completion of the investigation, NIPSCO requests that it be provided with a copy of the Pipeline Division's Investigation Report with findings that will be forwarded to the Underground Plant Protection Advisory Committee. If there are any additional questions, please contact the undersigned.

Very truly yours,

Christopher C. (Kit) Earle
NiSource Corporate Services - Legal
Phone: 317-684-4904
Fax: 317-684-4918
Email: cearle@nisource.com

IURC INFORMATION REQUEST	
Pipeline Safety Division Case No. 4191	
Date of Event	10/6/2012
Event Location	320 Sr 16
Event City	Roann
Facility Owner	Northern Indiana Public Service Company
Excavator	Lj Enterprises
Date of IURC Information Request	2/13/2013
THE PARTIES	
EXCAVATOR:	
BUSINESS NAME	LJ Enterprises
RESPONSIBLE PARTY PERSONAL NAME	Larry Rensberger
TITLE (IF ANY)	
ADDRESS	PO Box 161
CITY/ STATE/ZIP	Roann, IN 46974
PREFERRED TELEPHONE	260-416-7530
CELL PHONE TELEPHONE	260-416-7530
EMAIL ADDRESS	
FACILITY INFORMATION - OWNER/OPERATOR OF UTILITY LINE:	
BUSINESS NAME	NORTHERN INDIANA PUBLIC SERVICE COMPANY
RESPONSIBLE PARTY PERSONAL NAME	LUKE SELKING
TITLE	
ADDRESS	1501 HALE AVENUE
CITY/STATE/ZIP	FORT WAYNE, IN 46802
PREFERRED TELEPHONE	260/439-1290
SECONDARY TELEPHONE	
EMAIL ADDRESS	LSELKING@NISOURCE.COM
LOCATOR SERVICE INFORMATION	
BUSINESS NAME	USIC
RESPONSIBLE PARTY PERSONAL NAME	Morgan Thompson
TITLE (IF ANY)	Claims Coordinator
ADDRESS	9045 N. River Rd. Suite 300
CITY/ STATE/ZIP	Indianapolis, IN 46240
PREFERRED TELEPHONE	1-317-538-7301
CELL PHONE TELEPHONE	1-317-538-7301
EMAIL ADDRESS	morganthompson@usicinc.com
OTHER (WITNESS, POLICE, FIRE, OTHER) INFORMATION	
PERSONAL CONTACT	
BUSINESS/ORGANIZATION NAME	
TITLE (IF ANY)	

ADDRESS	
CITY/ STATE/ZIP	
PREFERRED TELEPHONE	
CELL PHONE TELEPHONE	
EMAIL ADDRESS	
UTILITY LINE IMPACT	
LOCATION OF DAMAGE	
ADDRESS	320 SR 16
CITY/STATE/ZIP	Roann, IN 46974
NEAREST INTERSECTION	Arnold St
PRODUCT TYPE (Select One)	
NATURAL GAS	X
LIQUID PIPELINE	
UNKNOWN/OTHER	
FACILITY TYPE (Select One)	
DISTRIBUTION	
GATHERING	
SERVICE/DROP	X
TRANSMISSION	
UNKNOWN/OTHER	
SIZE (DIAMETER/ETC.)	1 1/8
PRESSURE (PSIG/INCHES)	25
INTERRUPTION IN SERVICE (YES/NO)	YES
NUMBER OF CUSTOMERS AFFECTED	1
EVACUATION (YES/NO)	NO
IF YES, HOW MANY EVACUATED	0
REPAIR COST (IF KNOWN) (\$)	
CAUSE OF DAMAGE INFORMATION:	
TYPE OF EQUIPMENT (Select One)	
Auger	
Backhoe/Trackhoe	X
Boring/Drilling	
Directional Drilling	
Explosives	
Farm Equipment	
Grader/Scraper	
Hand Tools	
Milling Equipment	
Probing Device	

Trencher	
Vacuum Equipment	
Unknown/Other	
TYPE OF WORK PERFORMED (Select One)	
Agriculture	
Cable TV	
Curb/Sidewalk	
Bldg. Construction	
Bldg. Demolition	
Drainage	X
Driveway	
Electric	
Engineering/Surveying	
Fencing	
Grading	
Irrigation	
Landscaping	
Liquid Pipeline	
Milling	
Natural Gas	
Pole	
Public Transit Authority	
Railroad Maintenance	
Road Work	
Sewer (Sanitary/Storm)	
Site Development	
Steam	
Storm Drain/Culvert	
Street Light	
Telecommunications	
Traffic Signal	
Traffic Sign	
Water	
Waterway Improvement	
Unknown/Other	
RELEASE OF PRODUCT (YES/NO)	YES
IGNITION AND/OR FIRE (YES/NO)	NO
EXCAVATOR NOTIFY 811 (YES/NO)	NO
LOCATE INFORMATION:	
EXCAVATOR REQUEST LOCATE (YES/NO)	NO

INDIANA 811 LOCATE TICKET NUMBER	N/A
LOCATE MARKS VISIBLE (YES/NO)	YES
LOCATE MARKS CORRECT (YES/NO)	NO
EXCAVATOR "WHITE LINED" (YES/NO)	NO
MAPS USED TO MARK FACILITIES (YES/NO)	NO
OPERATOR EMPLOYEES ON-SITE DURING EXCAVATION (YES/NO)	NO
INCIDENT IMPACT INFORMATION	
NUMBER OF OUTPATIENT TREATED	0
NUMBER OF INPATIENT TREATED	0
NUMBER OF FATALITIES	0
FIRE DEPARTMENT RESPONSE (YES/NO)	
POLICE DEPARTMENT RESPONSE (YES/NO)	
AMBULANCE RESPONSE (YES/NO)	
ADDITIONAL INFORMATION/COMMENTS	
<p>Locates were not accurate, but excavator working under expired ticket. NIPSCO Emergency Repair Ticket# 1210060085</p>	

sewer. The service still runs but depth begins to get deep and signal starts to fade. This is a state road and the end of the locate. The tone makes since to go under the state road. After the damage it became evident the tracer wire is broken and missing, laying against some other pipe. The service turns angling E of the catch basin. The singal takes you E of the catch basin and the service angles on the W side of the catch basin. Pictures even 4 days after the damage show the tracer wire is missing even in the bank of the hole where the service was not cut.

NAMES OF UTILITY REPRESENTATIVES CONTACTED OR ON SITE AND STATEMENT:

LOA said we would just have to meet on it later if USIC receives a bill. Both he and the crew noted the false tone and the wire missing at the point of damage.

NAMES OF EXCAVATOR'S REPRESENTATIVES CONTACTED OR ON SITE AND STATEMENT:

Marks are between 2 and 3' off. I was only digging to the catch basin. This was the last scoop.

LIST ANY OTHER INDIVIDUALS ON SITE:

n/a-none

WERE ANY MARKINGS VISIBLE ON THE DAMAGE SITE UPON ARRIVAL? Yes

WERE ANY OTHER INDICATORS OF FACILITY PRESENT IN THE AREA? Yes

WAS THE EXCAVATION WITHIN THE TOLERANCE ZONE OF MARKS? No

EXTENT OF FACILITY DAMAGE 5/8 pl service cut

REPLACEMENT FOOTAGE 2'

WAS CONTRACTOR ASSISTANCE REQUIRED? IF YES, WHO? No n/a

WHAT CONTRACTOR EQUIPMENT WAS USED? none

IS THE FACILITY SHOWN ON THE UTILITY RECORDS? No

IF YES, PLEASE LIST RECORD #(S) n/a

Facility: Transmission Lines; Folder: N/A; Assigned To: N/A

NIPSCO 00625 IUPPSa 09/14/2012 12:25:33 1209141837-00A NORM NEW GRID

NORMAL NOTICE

Ticket : 1209141837 Date: 09/14/2012 Time: 12:17 Oper: AGRIGGS Chan:074

State: IN Cnty: WABASH Twp: PAW PAW
Cityname: ROANN Inside: Y Near: N
Subdivision:

Address : 320
Street : IN RT 16
Cross 1 : ARNOLD ST Within 1/4 mile: Y
Location: LOCATE FROM THE ROAD TO THE FIRE STATION IN THE FRONT OF THE PROPERTY
FOR 30 FEET OFF THE ROAD
:
Grids : 4054A8555D 4054A8555C
Boundary: n 40.914066 s 40.912956 w -85.923660 e -85.920265

Work type : DRAIN INSTALL
Done for : ROANN FIRE DEPT
Start date: 09/18/2012 Time: 12:30 Hours notice: 96/48 Priority: NORM
Ug/Oh/Both: U Blasting: N Boring: N Railroad: N Emergency: N
Duration : UNKNOWN Depth: 4 FEET

Company : LJ ENTERPRISES Type: CONT
Co addr : PO BOX 161
City : ROANN State: IN Zip: 46974
Caller : LARRY RENSBERGER Phone: (260)416-7530
Contact : LARRY RENSBERGER--CELL Phone:
BestTime:
Mobile : (260)416-7530

Remarks : All tickets are taken and processed on Eastern Daylight Time
Will you be white-lining the dig site area? NO
:

Submitted date: 09/14/2012 Time: 12:17
Members: ID0002 ID2034 ID6810 NIPSCO ID5857

Facility: Distribution Lines; Folder: On-Hold folder; Assigned To: N/A

NIPSCO 00024 IUPPSa 10/06/2012 10:40:18 1210060085-00A EMER NEW GRID

EMERGENCY

Ticket : 1210060085 Date: 10/06/2012 Time: 10:35 Oper: CSCOTT Chan:052

State: IN Cnty: WABASH Twp: PAW PAW
Cityname: ROANN Inside: Y Near: N
Subdivision:

Address : 320
Street : IN RT 16
Cross 1 : N ARNOLD ST Within 1/4 mile: Y
Location: LOCATE THE ENTIRE PROPERTY
:
Grids : 4054B8554A 4054A8554A 4054B8555D 4054A8555D 4054B8555C
Grids : 4054A8555C
Boundary: n 40.915817 s 40.910728 w -85.922661 e -85.915497

Work type : REPAIRING GAS LINE
Done for : NIPSCO
Start date: 10/06/2012 Time: 10:37 Hours notice: 0/0 Priority: EMER
Ug/Oh/Both: U Blasting: N Boring: N Railroad: N Emergency: Y
Duration : 1 DAY Depth: 3 FEET

Company : NIPSCO Type: MEMB
Co addr : 801 EAST 86TH AVENUE
City : MERRILLVILLE State: IN Zip: 46410
Caller : ANGELA STUBBS Phone: (219)647-4701
Contact : DIANA PALMER - CELL Phone:
BestTime:
Mobile : (765)470-1153

Remarks : All tickets are taken and processed on Eastern Daylight Time
CREW IS ON SITE
Will you be white-lining the dig site area? YES
:

Submitted date: 10/06/2012 Time: 10:35
Members: ID0002 ID2034 ID6810 NIPSCO ID5857

NORTHERN INDIANA PUBLIC SERVICE COMPANY
FACILITY DAMAGE REPORT

** COMPLETE FORM FOR ALL DAMAGES TO NIPSCO FACILITIES **

REPORTING OPERATING AREA: Peru MAXIMO WO #: M576867
OPERATING AREA CONTACT: Dana Palmer JOB ORDER #: JO 561315-18
TRACKING NUMBER: 01820121006001 LOCATE REF #:
Locate Performed By:

DATE AND TIME OF ACCIDENT: 10-6-2012, 11:00AM DATE OF REPORT: 10-6-12
PLACE OF DAMAGE (INCLUDE CITY): 320 SR 16 Roann

DAMAGE WAS TO:
ELECTRIC - POLE / TRANSFORMER: # SIZE YEAR INSTALLED BROKEN YES () NO ()

OTHER (DESCRIBE)

GAS: SERVICE MAIN () SIZE 1 1/8 MATERIAL: PLASTIC () STEEL () METER () REG STATION () STUB ()
OTHER (DESCRIBE)

DEPTH OF FACILITY (inches) 48" PRESSURE (PSI) 25 Lbs.

RELEASE OF GAS: YES () NO () IGNITION OF GAS: YES () NO () EVACUATION REQUIRED: YES () # NO ()

INTERRUPTION OF SERVICE: YES () NO () NUMBER OF CUSTOMERS LOST: 1

DURATION OF INTERRUPTION: TIME REPORTED 11:00 TIME SHUT OFF 11:30 TIME RESTORED 12:30

DIAMETER/MEASUREMENT OF HOLE IN GAS FACILITY: 1 1/8"

LOCATE MARKS ON SITE: YES () NO () DISTANCE BETWEEN FACILITY AND LOCATE MARKS 40" NO ()
HOW LOCATED: PAINT () FLAGS () BOTH () WHITE LINED ()

PARTY THAT CAUSED DAMAGES (NAME): Roann Fire Dept

ADDRESS OF PARTY (INCLUDE CITY): 320 SR 16 Roann

WHO WAS IN CHARGE OF THE WORK SITE AT TIME OF DAMAGE: Roann Fireman

WITNESS NAME AND ADDRESS

WITNESS REMARKS

AGENCIES NOTIFIED / ONSITE: POLICE () AGENCY REPORT #

FIRE AGENCY REPORT #

OTHER () Any Injuries? () YES # NO

PHOTOS TAKEN: YES () NO () TAKEN BY: (ATTACH PHOTOS TO REPORT)
MEDIA ON SITE YES () NO ()

- WORK IN PROGRESS WHEN FACILITY DAMAGED - CHECK APPROPRIATE CHOICE BELOW
() AGRICULTURE/FARMING () CABLE TV () CURB/SIDEWALK () TELECOMMUNICATIONS
() BLDG CONSTRUCTION () DEMOLITION () DRAINAGE () WATER
() DRIVEWAY () ELECTRIC () SURVEYING () DRAINS/CULVERTS
() FENCING () GRADING () IRRIGATION () MOWING
() LANDSCAPING () PIPELINE () MILLING () OTHER
() POLE/SIGN POST () ROAD WORK () SEWER

- TYPE OF EQUIPMENT USED - CHECK APPROPRIATE CHOICE BELOW
() AUGER () HAND TOOLS () BACKHOE/TRACKHOE
() MILLING EQUIPMENT () PROBING DEVICE () BORING / DRILLING
() EXPLOSIVES () TRENCHER () FARM EQUIPMENT
() VACCUUM EQUIPMENT () GRADER () OTHER

- REASON DAMAGE OCCURRED - CHECK APPROPRIATE CHOICE BELOW
() AUTOMOTIVE ACCIDENT () EXCAVATING BEFORE LOCATES DUE () CARELESS MACHINE OPERATOR
() NO NOTIFICATION () MARKS DISTURBED () STUB () OTHER: Mislabeled

COMMENTS: Called on another Leak R-4 Repair
locate wire - Approx 4' pulled out


PERSON PREPARING REPORT Alvest

FIELD SUPERVISOR D. Palmer

FIELD MANAGER D. Salmons

- ORIGINAL REPORT AND SUPPORTING INFORMATION IS TO BE SENT TO FACILITY DAMAGE RECOVERY
- COPY OF REPORT IS TO BE SENT TO DAMAGE PREVENTION

SKETCH: - Show position of all pertinent information



FOR OFFICE USE ONLY:

- | | | |
|---|-----|----|
| • DID EXCAVATION OCCUR BEFORE LOCATES WERE DUE | YES | NO |
| • NO IN 811 LOCATE CALLED IN | YES | NO |
| • DAMAGE CAUSED FROM EXCAVATION WITHIN 24" ZONE | YES | NO |
| • EXPIRED LOCATE | YES | NO |
| • WAS WHITE LINING INDICATED ON LOCATE REQUEST | YES | NO |

COMPLETED BY: _____ DATE: 10/6/12



DAMAGE INFORMATION REPORT – PIPELINE SAFETY DIVISION

State Form 54122 (R2 / 7-11)
INDIANA UTILITY REGULATORY COMMISSION

Submitted to IURC-Pipeline Safety on: Nov 26, 2012

Who is submitting this information?

Name of person providing this information: Carrie Ludwig

Business address (*number and street*): 3511 East 15th Ave

City, State, and ZIP code: Gary, IN 46403

Telephone number (*area code*): 219 962 0422

Fax number (*area code*): 219 962 0404

E-mail address: cludwig@nisource.com

Excavator Information, if known

Full name: LJ Enterprises

Business address (*number and street*): PO Box 161

City, State, and ZIP code: Roann, IN 46974

Telephone number (*area code*): 260 416 7530

Fax number (*area code*): _____

E-mail address: _____

Excavation or Demolition Information

Excavator type: Contractor

Excavation or demolition equipment: Backhoe/Trackhoe

Type of work performed: Drainage

Date and Location of Damage

Date of damage (month, day, year): Oct 6, 2012

County: Wabash

City: Roann

Street address (number and street, city, state, and ZIP code):
320 SR 16 Roann IN

Nearest intersection: Arnold St

Right of way where damage occurred: Private - Business

Was there a release of product? Yes

If yes, was there an ignition of product? No

Were evacuations necessary as a result of release? No

If yes, how many evacuated? _____

Was there a customer service interruption? Yes

If yes, how many affected? 1

Time to restore service (in hours): 1.5

Enter number of injuries, if applicable and known: 0

Enter number of fatalities, if applicable and known: 0

Property damage, Estimate \$ _____

Affected Facility Information

What type of pipeline was damaged? Natural Gas

What was the affected facility? Service/Drop

What was the depth of the facility, in inches? 48

Notification, Locating, Marking

Did excavator request locates prior to commencing work? Yes

Enter Indiana 811 ticket number, if known: 1209141837

Was the locate request completed within two working days? Yes

If locates were performed, were they done so by a contractor or pipeline employee? Contract Locator

If a contractor locator, enter the company name, if known: USIC

Were facility marks visible in the area of excavation? No

Were facilities marked correctly? Yes

Type of markings used: Paint and Flags

If other, please specify: _____

Was site marked by "White Lining"? No

Were special instructions part of the locate request? Unknown/Other

Were maps used to complete the locate request? Unknown/Other

Were pipeline company representatives on site during excavation? No

Did the excavator notify the operator in the event of this damage? Yes

Did the excavator notify Indiana 811 in the event of this damage? No

Did the excavator notify 911 in the event of a release of product? Unknown/Other

Description of Cause

Select from the list the most accurate cause for the damage: --Facility could not be found/located

Additional Comments

Part of the tracer wire was missing therefore the signal was lost 5' from catch basin where facility was hit.
Nipsco emergency repair ticket #: 1210060085

February 25, 2013

Pipe Line Safety Division

Re: Case No. 4191

RECEIVED

MAR 07 2013

INDIANA UTILITY
REGULATORY COMMISSION

To Whom it may Concern,

LJ Enterprises has received notice of a request for information concerning a damaged gas line.

The question of failure to provide notification is not correct. Indiana 811 was notified, a locate number of 1209141837 was received.

The Locate individual arrived on a Sunday and was shown the spot to be excavated, a white line was not needed.

When excavation work was performed, hand digging was done to the approximate depth of three to four feet or waist deep on my help. The line was not located in the two foot area in question, as the hand dug material was pulled away from the hole, out side the marked area the gas line was damaged by the bucket fingers.

A Nipsco truck happened by at the time of damage, he was flagged down and clamped of the line. Contact to Nipsco and Locate was made by Nipsco.

Locate personnel arrived to take photos and investigated the reason for the missed locate. We were informed at that time that there was a lost signal in the area. Possibly a broken trace wire.

If there is anymore information needed, please feel free to contact me
lrensberger@centurylink.net

Larry Rensberger
President of LJ. Enterprises