



## Pipeline Safety Division Investigation Report

### Investigation regarding: Custom Concrete

UPPAC Database Record ID: 4832

Report Date: 7/31/2013

Investigator: Mike Orr

Damage Date: 5/17/2013 1:53:10 PM

Damage Address: 708 Classic Ln, Pleasant, Johnson

### The Parties

Excavator: Custom Concrete

Address: 17241 Foundation Parkway, Westfield, In 46074

Facility Owner: Vectren

### Pipeline Facility

Facility Type: Natural Gas

Facility Function: Service/Drop

Type of Equipment: Backhoe/Trackhoe

Type of Work Performed: Curb / Sidewalk

### Damage Impact

Product Release: Yes

Ignition: No

Service Interruption: True

Number of Customers Affected: 1

Injuries: 0

Fatalities: 0

Repair Cost (if known): \$539

### Excavator Activities/Cause of Damage Information:

Excavator Request Locates: Yes  
5/9/2013

Indiana 811 Ticket Number: 1305072390

Original Start Date:

Locate Instructions: LOCATE ENTIRE PROPERTY

Follow-Up Locate Instructions (if applicable):

**Synopsis:** Excavator struck and damaged an underground natural gas service while performing curb/sidewalk work.

**Findings:** Reported by Indiana 811; excavator's response to initial notice was received on 7/24/2013. The excavator failed to maintain required clearance from the gas main with the backhoe. Excavator called for a locate for a sub-contractor. Excavator was informed at a required education training class to register each sub at 811 in order to get the sub assigned to a locate ticket.

**Conclusion:** There was a failure to maintain two (2) feet clearance.

**Violation:** IC 8-1-26-20(a)(2) Failure to maintain two (2) feet clearance with mechanized equipment.



# DAMAGE INFORMATION REPORT – PIPELINE SAFETY

State Form 54122 (R2 / 7-11)  
INDIANA UTILITY REGULATORY COMMISSION

INITIAL DOCUMENTS -  
OPERATOR  
CASE # 4832

Submitted to IURC-Pipeline Safety on: 07/31/2013

## Who is submitting this information?

Name of person providing this information: Darlene Kulhanek

Business address (number and street): 1 Main Street

City, State, and ZIP code: Evansville, IN 47711

Telephone number (area code): 812-491-4227

Fax number (area code): 812-491-4504

E-mail address: dkulhanek@vectren.com

## Excavator Information, if known

Full name: Custom Concrete

Business address (number and street): 17241 Foundation Pkwy

City, State, and ZIP code: Westfield, IN 46074

Telephone number (area code): 317-399-2288

Fax number (area code): 317-399-2388

E-mail address: Unknown

## Excavation or Demolition Information

Excavator type: Contractor

Excavation or demolition equipment: Backhoe/Trackhoe

Type of work performed: Curb/Sidewalk

**Date and Location of Damage**

Date of damage (month, day, year): 5-17-2013

County: Johnson

City: Greenwood

Street address (number and street, city, state, and ZIP code):  
708 Classic Ln, Greenwood, IN

Nearest intersection: Unknown

Right of way where damage occurred: Private - Land Owner

Was there a release of product? Yes

If yes, was there an ignition of product? No

Were evacuations necessary as a result of release? No

If yes, how many evacuated? 0

Was there a customer service interruption? Yes

If yes, how many affected? 1

Time to restore service (in hours): 1

Enter number of injuries, if applicable and known: 0

Enter number of fatalities, if applicable and known: 0

Property damage, Estimate \$ 538.56

**Affected Facility Information**

What type of pipeline was damaged? Natural Gas

What was the affected facility? Service/Drop

What was the depth of the facility, in inches? \_\_\_\_\_

**Notification, Locating, Marking**

Did excavator request locates prior to commencing work? Yes

Enter Indiana 811 ticket number, if known: 1305072390

Was the locate request completed within two working days? Yes

If locates were performed, were they done so by a contractor or pipeline employee? Contract Locator

If a contractor locator, enter the company name, if known: USIC \_\_\_\_\_

Were facility marks visible in the area of excavation? Yes

Were facilities marked correctly? Yes

Type of markings used: Paint and Flags

If other, please specify: None \_\_\_\_\_

Was site marked by "White Lining"? No

Were special instructions part of the locate request? Unknown/Other

Were maps used to complete the locate request? No

Were pipeline company representatives on site during excavation? No

Did the excavator notify the operator in the event of this damage? Yes

Did the excavator notify Indiana 811 in the event of this damage? Yes

Did the excavator notify 911 in the event of a release of product? Unknown/Other

### **Description of Cause**

Select from the list the most accurate cause for the damage: --Failure to use hand tools where required

### **Additional Comments**

1" plastic service severed by hoe. Not hand exposed.



2 VECTREN ENERGY DELIVERY OF INDIANA - NORTH


PAID

NOW DUE  
\$538.56

CUSTOM CONCRETE  
17241 FOUNDATION PARKWAY,  
WESTFIELD, IN 46074

Type: GAS  
Invoice: FDS0017791  
BillToID: 33272  
Billing Date: 6/14/2013  
Date of Loss: 5/17/2013  
5835 103.0510

Please return this portion with your remittance.



Mail Payment To:  
Vectren Utilities Holdings Group, INC  
1239 Reliable Parkway  
Chicago, IL 60688-0012  
Inquiries: 1-877-902-2934, Mon.-Fri., 8-5  
Risk Management/Claims Department

CUSTOM CONCRETE  
17241 FOUNDATION PARKWAY,  
WESTFIELD, IN 46074

Type: GAS  
Invoice: FDS0017791  
BillToID: 33272  
Billing Date: 6/14/2013  
Date of Loss: 5/17/2013

NOW DUE  
\$538.56

**Invoice For Costs to Repair and Reconstruct Damaged Property**

Address: 708 CLASSIC, GREENWOOD  
1" PLASTIC SERVICE SEVERED BY HOE. NOT HAND EXPOSED.

Material:	\$16.84
Company Labor:	\$456.59
Contract Labor:	\$0.00
Transportation/Equipment:	\$65.13
Misc:	\$0.00
Gas Loss:	\$0.00
Adjustments:	\$0.00
Payments:	\$0.00
<b>Total:</b>	<b>\$538.56</b>

5835 103.0510

Remember, call two (2) working days before digging. Contact I.U.P.P.S. at 1-800-382-5544.

Vectren Claim Number: \_\_\_\_\_

FDS 0017791

Task No: 103.0510 Capital / O & M (circle one)

Police Report / MO #: \_\_\_\_\_

Date of Damage 5 / 17 / 13

Cost Center # 5835

Time Occurred 2:10 am  pm

Time Found 2:16 am  pm

Latitude 39.60470 Longitude: -86.051060

# FACILITIES DAMAGE REPORT

## GAS

Vectren Claims Camera:

VE02651  
4

**DAMAGE SITE:**

Address 708 Classic Lot # 560  
County Johnson City Greenwood State IN Township Pleasant

**FACILITY TYPE:**

- Distribution
- Service
- Transmission: (include supplemental report)
- Propane
- Storage

**FACILITIES DAMAGED:**

	ORIFICE SIZE(S):	(1)	(2)	(3)
<input type="checkbox"/> Farm Tap	0.50 inch	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/> Heater	5/8 inch	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/> Main	0.75 inch	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/> Meter (Residential)	1.00 inch	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/> Meter (Industrial / Commercial)	1.25 inch	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/> Odorizer	2.00 inch	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/> Regulator Station	3.00 inch	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/> Relief Valve	4.00 inch	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/> Riser	5.00 inch	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/> Service Line	6.00 inch	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/> Valve	10.00 inch	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	12.00 inch	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	16.00 inch	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	20.00 inch	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/> Other _____	Other	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

**VISUAL OBSERVATION AT DAMAGE SITE:**

- Visual Observation:  Above Ground  Below Ground
- Locate Applicable:  Yes  No  N/S
- Facilities Properly Marked:  Yes  No  N/S
- Marking Methods:  Conventional  Offset  Flags  None  Stakes  Whiskers
- Locate Marking Faded:  Yes  No  N/S
- Wrong Address Requested:  Yes  No  N/S

**Facilities Improperly Located:**

- Qualified Locator Could Not Have Accurately Located
- Inaccurate Maps / Cards
- Broken or No Tracer Wire (Plastic)
- Insulation Preventing Accurate Locate

**Locator Error:**

- Failure to Follow Policy
- Inappropriate Site Markings
- Incomplete Locate
- No Locates Performed
- Qualified Locator Could Have Accurately Located
- Wrong Address Located
- Marking Off By: \_\_\_\_\_ (Feet / Inches)

**TYPE OF MATERIAL:**

- Cast Iron
- Plastic (HDPE)
- Plastic (MDPE)
- Steel
- Other \_\_\_\_\_

**DAMAGE TYPE:**

- Severed
- Not Cut
- Severed
- Size \_\_\_\_\_ x \_\_\_\_\_

**PRESSURE:**

- 25 PSIG
- 40 PSIG
- 50 PSIG
- 55 PSIG
- 60 PSIG
- 6 WC (.2163)
- 7 WC (.252)
- Other \_\_\_\_\_

**PROTECTION IN PLACE:**

- Building  Fence  None
- Post  Rail  Vault  N/A
- Other \_\_\_\_\_

**DURATION OF ESCAPING GAS:**

Minutes: 15 seeping

**LEAK REPORT NUMBER:**

EFV Activated  Yes  No  N/S

**FEED TYPE:**

- One-Way Feed
- Two-Way Feed

Number of Customers Affected: 1  
Total Hours Service Was Off: \_\_\_\_\_

SERVICE ORDER NUMBER: N 5648.336

**DAMAGED BY:**

- Company Crew
- Contractor
- County
- Developer
- Farmer
- Municipality
- Property Owner/ Tenant
- Railroad
- State
- Unknown
- Utility
- Vehicle Accident
- Other \_\_\_\_\_

**TYPE OF CONSTRUCTION:**

- Agriculture
- Building Construction
- Building Demolition
- Cable TV
- Curbs / Sidewalk
- Drainage
- Driveway
- Electric
- Engineering / Surveying
- Fencing
- Grading
- Irrigation
- Landscaping
- Liquid Pipeline
- Milling
- Pole
- Natural Gas
- Public Transit Authority
- Railroad Maintenance
- Other \_\_\_\_\_

**NOTIFICATIONS AND OTHER DETAILS OF LOCATE:**

Locate Ticket: \_\_\_\_\_  
Date: \_\_\_\_\_ Time: \_\_\_\_\_ am / pm

**TYPE OF REQUEST:**

- Regular Request  Emergency Request
- Locate Company Notified
- Contact Name: \_\_\_\_\_
- Time Called: \_\_\_\_\_ am / pm
- Time Locator Arrived at the Site: \_\_\_\_\_ am / pm

Company Notified of Locate Near Critical Facilities  Yes  No  N/S

Copy of Mark Out Request Provided Within 2 Working Days  Yes  No  N/S

**ONE-CALL CENTER:**

- IUPPS
- OUPS
- Unknown

Vectren Claim Number: \_\_\_\_\_

**TYPE OF EQUIPMENT:**

- Auger
- Backhoe / Track hoe
- Boring
- Drilling
- Explosives
- Farm Equipment
- Grader / Scraper
- Hand Tools
- Milling Equipment
- Plow
- Probing Device
- Trencher
- Vacuum Equipment
- Vehicle
- Other \_\_\_\_\_

**ROOT DAMAGING CAUSE:**

- Abandoned Facility
- Deteriorated Facility
- Facility Could Not be Found/ Located
- Facility Was Not Located / Marked
- Failure to Maintain Clearance
- Failure to Maintain Marks
- Failure to Support Exposed Facility
- Failure to Use Hand Tools Where Required
- Improper Backfilling
- Incorrect Records / Maps
- Marking or Location Not Sufficient
- No Notification Made to One-Call
- One-Call Notification Error
- Previous Damage
- Wrong Information Provided
- Other \_\_\_\_\_

**CONTRACTOR REPAIRS:**

- Contractor Working for Vectren Made Repairs at Own Expense  
 Yes  No  N/S
- Contractor Repaired Damage  
 Yes  No  N/S

Name of Contractor: Miller  
 # of Regular Hours; \_\_\_\_\_  
 # of Overtime Hours; 2  
 # of Regular Hours; \_\_\_\_\_  
 Crew Type: Const. Rough Grade

**MATERIALS OR ROAD WORK:**

- Meter was replaced \_\_\_\_\_ (Stores Code)
- Regulator Was Replaced \_\_\_\_\_ (Stores Code)
- Temporary Asphalt Repair: \_\_\_\_\_ (sq. ft.)
- Permanent Asphalt Repair: \_\_\_\_\_ (sq. ft.)

**RIGHT OF WAY:**

- Dedicated Utility Easement
- Federal Utility Easement
- Pipeline
- Power / Transmission Line
- Private - Business
- Private - Easement
- Private - Land Owner
- Public - County Road
- Public - Interstate Highway
- Public - Other
- Public - State Highway
- Public - City Street
- Unknown

- Did Excavator Notify You  Yes  No
- Excavation Required  Yes  No
- Media at Site  Yes  No
- Was There Ignition of Gas?  Yes  No
- INVOICE:  Yes  No  N/S

**DAMAGING PARTY:**  
 Name: Custom Concrete  
 Address: 17241 Foundation Pkwy  
 City/ State/ Zip: Westfield IN 46074  
 Phone: ( 317 ) 896-2885  
Blake Co 5/17/13  
 Prepared / Investigated By: \_\_\_\_\_ Date: \_\_\_\_\_

**PARTY TO INVOICE:**  
 Name: SPMG  
 Address: \_\_\_\_\_  
 City/ State/ Zip: \_\_\_\_\_  
 Phone: \_\_\_\_\_  
 Reviewed by Field Supervisor: \_\_\_\_\_ Date: 5/20/13

*USIC located 5-9-17 AM  
 Service was ran also on 5-9-17*

# Ticket Portal Production

**Ticket Text**   **Photos**

**Ticket Text**

ID7131 00988 IUPPSa 05/07/2013 13:52:57 1305072390-00A NORM NEW STRT  
 NORMAL NOTICE  
 Ticket : 1305072390 Date: 05/07/2013 Time: 13:49 Oper: SALLY.SCHROCK.IN Chan:000  
 State: IN Cnty: JOHNSON Twp: PLEASANT  
 Cityname: GREENWOOD Inside: N Near: Y  
 Subdivision: HOMECOMING AT UNIVERSITY PARK Lot: 560  
 Address : 708  
 Street : CLASSIC LN  
 Cross 1 : N 200 E Within 1/4 mile: Y  
 Location: LOCATE ENTIRE PROPERTY  
 :  
 Grids : 3936C8603D 3936D8603D  
 Boundary: n 39.605363 s 39.603479 w -86.052031 e -86.050083  
 Work type : INSTALLING SIDEWALKS AND DRIVEWAYS  
 Done for : RYAN SLAB HOMES  
 Start date: 05/09/2013 Time: 14:00 Hours notice: 48/048 Priority: NORM  
 Ug/Oh/Both: U Blasting: N Boring: N Railroad: N Emergency: N  
 Duration : ONE DAY Depth: THREE FEET  
 Company : CUSTOM CONCRETE Type: CONT  
 Co addr : 17241 FOUNDATION PARKWAY  
 City : WESTFIELD State: IN Zip: 46074  
 Caller : SALLY SCHROCK Phone: (317)399-2288  
 Contact : SALLY SCHROCK OFFICE Phone:  
 BestTime:  
 Mobile : (317)399-2288  
 Fax : (317)399-2388  
 Email : SALLYS@CUSTOMCONCRETE.COM  
 Remarks : All tickets are taken and processed on Eastern Daylight Time  
 Will you be white-lining the dig site area? NO  
 :  
 Submitted date: 05/07/2013 Time: 13:49  
 Members: ID0270 ID1254 ID4378 ID6921 ID7131 ID7288 SBCIN SM  
 -----  
 Email\_From: irth@iupps.org  
 Email\_Subject: IUPPS ID7131 2013/05/07 #00988 1305072390-00A NORM NEW  
 Email\_Sent\_Date: 2013-05-07 12:52:57 CDT  
 Email\_MessageID: <20130507175257.847EE89A5F@mx-caprica.easydns.com>  
 Email\_host: tickets5.811tickets.com  
 Email\_user: 811.in.oc-vvc  
 Email\_To: 811.in.oc-vvc@tickets.811tickets.com  
 Email\_ContentType: text/plain; charset=us-ascii



Property of United States Infrastructure Corporation  
Photo taken on 5/9/2013 11:02:52 AM

## Ticket Portal Production

**Ticket Text**   Photos

**Ticket Text**

ATTIN Seq: 1162 Transmitted: Fri May 17 12:54:48 CDT 2013  
 SBCIN 01156 IUPPSa 05/17/2013 13:53:17 1305172010-00A EMER DAMG STRT  
 DAMAGE DAMAGE  
 Ticket : 1305172010 Date: 05/17/2013 Time: 13:49 Oper: MMOELLER Chan:039  
 State: IN Cnty: JOHNSON Twp: PLEASANT  
 Cityname: GREENWOOD Inside: N Near: Y  
 Subdivision: HOMECOMING AT UNIVERSITY PARK Lot: 560  
 Address : 708  
 Street : CLASSIC LN  
 Cross 1 : N 200 E Within 1/4 mile: Y  
 Location: LOCATE ENTIRE PROPERTY  
 :  
 Grids : 3936C8603D 3936D8603D  
 Boundary: n 39.605363 s 39.603479 w -86.052031 e -86.050083  
 Work type : INSTALLING SIDEWALKS AND DRIVEWAYS  
 Done for : RYAN SLAB HOMES  
 Start date: 05/17/2013 Time: 13:50 Hours notice: 0/000 Priority: EMER  
 Ug/Oh/Both: U Blasting: Y Boring: N Railroad: N Emergency: Y  
 Duration : ONE DAY Depth: THREE FEET  
 Company : CUSTOM CONCRETE Type: CONT  
 Co addr : 17241 FOUNDATION PARKWAY  
 City : WESTFIELD State: IN Zip: 46074  
 Caller : AMANDA BURCHAM Phone: (317)399-2288  
 Contact : SALLY SCHROCK OFFICE Phone:  
 BestTime:  
 Mobile : (317)399-2288  
 Fax : (317)399-2388  
 Email : SALLYS@CUSTOMCONCRETE.COM  
 Remarks : All tickets are taken and processed on Eastern Daylight Time  
 PER AMANDA BURCHAM - CUT VECTREN GAS LINE IN THE FRONT OF THE PROPERTY - CANNOT  
 DESCRIBE THE LINE - GAS IS BLOWING - ADVISED TO CALL 911 AND VECTREN - CREW IS  
 ON SITE - PREVIOUS TICKET 1305072390 - THANK YOU  
 Will you be white-lining the dig site area? NO  
 :  
 Submitted date: 05/17/2013 Time: 13:49  
 Members: ID0270 ID1254 ID4378 ID6921 ID7131 ID7288 SBCIN SM  
 -----  
 Email\_From: att-tickets@tickets.translore.com  
 Email\_Subject: ATT Translore - 1305172010  
 Email\_Sent\_Date: 2013-05-17 12:54:48 CDT  
 Email\_MessageID: <1368813288379.1403997851.TransLore.att-tickets@tickets.translore.com>  
 Email\_host: tickets5.811tickets.com  
 Email\_user: 811.in.att  
 Email\_To: 811.in.att@tickets.811tickets.com  
 Email\_ContentType: text/plain; charset=ISO-8859-1



Property of United States Infrastructure Corporation  
Photo taken on 5/17/2013 2:37:16 PM



Property of United States Infrastructure Corporation  
Photo taken on 5/17/2013 2:37:40 PM

# Service Order Status

**Enter Service Order Number:**

5648336



Home Page

Support Case

**Banner Instance:**  CS03PROD  CS01PROD  CS02PROD

**Order Number:** N5648336

**Order Type:** INVE

**Order Status:** Completed

**Customer:** 620225639 - RYAN HOMES

**Prem:** 5738611 - 708 CLASSIC LN

**Technician:** 3663 - McIntosh, Jim

**Order Dates and Times**

**Need Date:** 5/17/2013 2:13:00 PM  
**Time Created:** 5/17/2013 2:01:47 PM  
**Time Dispatched:** 5/17/2013 2:01:47 PM  
**Time In Route:** 5/17/2013 2:04:37 PM  
**Time On-Site:** 5/17/2013 2:16:50 PM  
**Tech Complete:** 5/17/2013 3:43:31 PM  
**Time Closed:** 5/17/2013 3:43:31 PM

**Events Performed/Completion Code**

IVEG - CMP

**Meter Information**

**Current ReadStatus**

**Old Meter:**

**New Meter:**

**Completion Notes**

cut service, concrete crew cut with bobcat, capped line, miller to repair 3663

**Request Notes**

PER AMBER WITH 811/REPORTING HIT LINE/NO INFO ON SIZE GIVEN/BY CUSTOM CONCRETECONTACT PERSON SALLY/317 399 2288/DAM TICKET#1305172010

**MDSI Event Dates and Times**

Event	Date/Time	User
AsnAssignmentManualAck_evt	5/17/2013 2:03:37 PM	McIntosh, Jim
AsnAssignmentEnRoute_evt	5/17/2013 2:04:37 PM	McIntosh, Jim
AsnAssignmentOnSite_evt	5/17/2013 2:16:50 PM	McIntosh, Jim
OrdOrderComplete_evt	5/17/2013 3:43:31 PM	McIntosh, Jim

NOTE:The Reporting database replicates in near real-time; it has been approximately 0 minute(s) since the last transaction replicated.



**INFORMATION REQUEST**

State Form 54909 (R / 3-13)

INDIANA UTILITY REGULATORY COMMISSION – PIPELINE SAFETY DIVISION

**Case Number:** 4832 \_\_\_\_\_

**Date of Damage** (*month, day, year*): 5/17/2013 \_\_\_\_\_

**Location of Damage:**

Address (*number and street*): 708 Classic Ln \_\_\_\_\_

City, State and ZIP Code: Greenwood, IN, 46142 \_\_\_\_\_

Nearest Intersection: Allen Rd & Classic Ln \_\_\_\_\_

**Excavator Information:**

Business Name: Custom Concrete Co. Inc (Damage by subcontractor-Carrcrete LLC, info listed below) \_\_\_\_\_

Responsible Party Personal Name: Manuel Carrera \_\_\_\_\_

Title (*if any*): Owner of Carrcrete LLC. \_\_\_\_\_

Address (*number and street*): 7307 Backbay Court, Apt 1A \_\_\_\_\_

City, State and ZIP Code: Indianapolis, IN 46214 \_\_\_\_\_

Preferred Telephone Number (area code): 317-797-6849 \_\_\_\_\_

Email Address: carrcrete@yahoo.com, Custom Concrete info is: Tyler Kingdon, EI 

**Utility Information:**

Utility Name: Vectron Gas \_\_\_\_\_

Contact Person: \_\_\_\_\_

Title (*if any*): \_\_\_\_\_

**Cause of Damage Information**

Type of Equipment (*select one*):

Type of Work Performed (*select one*):

Repair Cost: \$ UnKnown

Did a leak result from damage:  Yes  No

Was there ignition:  Yes  No

Excavator Notify 911 due to leak:  Yes  No

Excavator Notify 811 upon damage:  Yes  No

Excavator Notify Utility upon Damage:  Yes  No

---

**Locate Information**

Excavator Request Locate:  Yes  No

Indiana 811 Locate Ticket Number: 1305072390

Locate Marks Visible:  Yes  No

Locate Marks Correct:  Yes  No

Excavator "White Lined":  Yes  No

Was Locate Provided within Two (2) Working Days:  Yes  No

Utility Employees On-site during Excavation:  Yes  No

---

**Incident Information:**

Fire Department Response:  Yes  No

Police Department Response:  Yes  No

Ambulance Response:  Yes  No

**Additional Information / Comments**

Subcontractor hit gas service line to house while installing public sidewalk. Locates were called in and Subcontractor failed to pothole. We would like to discuss how to better manage the subcontractors who are working on our sites. Should they be calling in locates in lue of us calling them in. We don't like that this will go against our record for the year when we didn't physically do the work. Can we login in for the subcontractor to request a locate on their behalf for a job they will be doing?  
Thank You  
Tyler Kingdon

Printed Name:  Tyler Kingdon

Signature: \_\_\_\_\_ Date (month, day, year):  07/23/2013

*\*If submitting this form electronically, typing your name in the signature box will act as an electronic signature.*

**Please return completed form to:**

**[PipelineDamageCase@urc.in.gov](mailto:PipelineDamageCase@urc.in.gov)**

**Or mail to:**

**Indiana Utility Regulatory Commission  
Pipeline Safety Division - Case Number \_\_\_\_\_  
101 West Washington Street, 1500E  
Indianapolis, IN 46204**

**Or fax to:  
317-233-2410**