



INDIANA UTILITY REGULATORY COMMISSION  
101 W. WASHINGTON STREET, SUITE 1500E  
INDIANAPOLIS, INDIANA 46204-3407

<http://www.in.gov/iurc>  
Office: (317) 232-2701  
Facsimile: (317) 232-6758

## Pipeline Safety Division Investigation Report

### Investigation regarding: Laporte County Highway Department

UPPAC Database Record ID: 5104

Report Date: 10/7/2013

Investigator: Mike Orr

Damage Date: 7/18/2013 9:53:40 AM

Damage Address: N Goldring Rd, Coolspring, Laporte

### The Parties

Excavator: **Laporte County Highway Department**

Address: 1805 West 5th Street, La Porte, In 46350

Facility Owner: **NIPSCO**

### Pipeline Facility

Facility Type: Natural Gas

Facility Function: Distribution

Type of Equipment: Unknown/Other

Type of Work Performed: Storm Drain

### Damage Impact

Product Release: No

Ignition: No

Service Interruption: False

Number of Customers Affected: 0

Injuries: 0

Fatalities: 0

Repair Cost (if known): \$

### Excavator Activities/Cause of Damage Information:

Excavator Request Locates: No  
5/15/2013

Indiana 811 Ticket Number: 1305132520

Original Start Date:

Locate Instructions: STARTING AT 2736 GOING NORTH AND SOUTH 100FT--LOCATE BOTH SIDES OF GOLDRING RD

Follow-Up Locate Instructions (if applicable):

**Synopsis:** Excavator struck and damaged an underground natural gas main while performing storm drain work.

**Findings:** Reported by Indiana 811; excavator did not respond to initial notice mailed 8/6/2013. Excavator failed to maintain a valid locate ticket when the gas main was scraped and damaged.

**Conclusion:** There was a failure to provide notice of excavation.

**Violation:** IC 8-1-26-16(g)(expire) Failure to provide notice of excavation - expired ticket.



150 West Market Street, Suite 600  
Indianapolis, IN 46204

August 26, 2013

[Via Electronic Transmission – PipelineDamageCase@urc.in.gov](mailto:PipelineDamageCase@urc.in.gov)

Pipeline Safety Division – Case No. 5104  
Indiana Utility Regulatory Commission  
101 West Washington Street, Suite 1500 East  
Indianapolis, Indiana 46204

RE: Investigation Request for Information; Pipeline Division Case No. 5104

To Whom It May Concern:

Attached please find Northern Indiana Public Service Company's ("NIPSCO") written information, and supporting documentation, relating to the following event:

Date of Event: 7/18/2013

Event Location: N GOLDRING RD

City: COOLSPRING

Facility Owner: NIPSCO

Excavator: LAPORTE COUNTY HIGHWAY DEPARTMENT

Other Party: N/A

Pipeline Division Case No. 5104

NIPSCO has reviewed its recovery and damage prevention files for this matter and has provided answers, when known, to the list of questions set forth in the Information Request. To the extent available, NIPSCO is also providing a copy of the Damage Information Report – Pipeline Safety Division previously submitted by NIPSCO to IURC Pipeline Safety as well as additional documentation relating to this Event Location.

Upon completion of the investigation, NIPSCO requests that it be provided with a copy of the Pipeline Division's Investigation Report with findings that will be forwarded to the Underground Plant Protection Advisory Committee. If there are any additional questions, please contact the undersigned.

Very truly yours,

Christopher C. (Kit) Earle  
NiSource Corporate Services - Legal  
Phone: 317-684-4904  
Fax: 317-684-4918  
Email: [cearle@nisource.com](mailto:cearle@nisource.com)

<b>IURC INFORMATION REQUEST</b>	
<b>Pipeline Safety Division Case No. 5104</b>	
Date of Event	7/18/2013
Event Location	N GOLDRING RD
Event City	COOLSPRING
Facility Owner	NIPSCO
Excavator	LAPORTE COUNTY HIGHWAY DEPARTMENT
Date of IURC Information Request	July 26, 2013
<b>THE PARTIES</b>	
<b>EXCAVATOR:</b>	
BUSINESS NAME	Laporte County Highway Department
RESPONSIBLE PARTY PERSONAL NAME	
TITLE (IF ANY)	
ADDRESS	1805 West 5 <sup>th</sup> St
CITY/ STATE/ZIP	Laporte, IN 46350
PREFERRED TELEPHONE	219 362 2051
CELL PHONE TELEPHONE	
EMAIL ADDRESS	
<b>FACILITY INFORMATION - OWNER/OPERATOR OF UTILITY LINE:</b>	
BUSINESS NAME	NORTHERN INDIANA PUBLIC SERVICE COMPANY
RESPONSIBLE PARTY PERSONAL NAME	LUKE SELKING
TITLE	
ADDRESS	1501 HALE AVENUE
CITY/STATE/ZIP	FORT WAYNE, IN 46802
PREFERRED TELEPHONE	260/439-1290
SECONDARY TELEPHONE	
EMAIL ADDRESS	LSELKING@NISOURCE.COM
<b>LOCATOR SERVICE INFORMATION</b>	
BUSINESS NAME	USIC
RESPONSIBLE PARTY PERSONAL NAME	Morgan Thompson
TITLE (IF ANY)	Claims Coordinator
ADDRESS	9045 N. River Rd. Suite 300
CITY/ STATE/ZIP	Indianapolis, IN 46240
PREFERRED TELEPHONE	1-317-538-7301
CELL PHONE TELEPHONE	Same
EMAIL ADDRESS	morganthompson@usicinc.com
<b>OTHER (WITNESS, POLICE, FIRE, OTHER) INFORMATION</b>	
PERSONAL CONTACT	Morgan Thompson
BUSINESS/ORGANIZATION NAME	Claims Coordinator
TITLE (IF ANY)	9045 N. River Rd. Suite 300

ADDRESS	
CITY/ STATE/ZIP	
PREFERRED TELEPHONE	
CELL PHONE TELEPHONE	
EMAIL ADDRESS	
<b>UTILITY LINE IMPACT</b>	
<b>LOCATION OF DAMAGE</b>	
ADDRESS	2736 N Goldring Road
CITY/STATE/ZIP	Laporte, IN 46350
NEAREST INTERSECTION	W 275 N
<b>PRODUCT TYPE (Select One)</b>	
NATURAL GAS	X SCRAPED MAIN NO RELEASE OF GAS
LIQUID PIPELINE	
UNKNOWN/OTHER	
<b>FACILITY TYPE (Select One)</b>	
DISTRIBUTION	X SCRAPED MAIN NO RELEASE OF GAS
GATHERING	
SERVICE/DROP	
TRANSMISSION	
UNKNOWN/OTHER	
SIZE (DIAMETER/ETC.)	2"
PRESSURE (PSIG/INCHES)	
INTERRUPTION IN SERVICE (YES/NO)	No
NUMBER OF CUSTOMERS AFFECTED	0
EVACUATION (YES/NO)	No
IF YES, HOW MANY EVACUATED	0
REPAIR COST (IF KNOWN) (\$)	
<b>CAUSE OF DAMAGE INFORMATION:</b>	
<b>TYPE OF EQUIPMENT (Select One)</b>	
Auger	
Backhoe/Trackhoe	
Boring/Drilling	
Directional Drilling	
Explosives	
Farm Equipment	
Grader/Scraper	
Hand Tools	
Milling Equipment	
Probing Device	

Trancher	
Vacuum Equipment	
Unknown/Other	X
<b>TYPE OF WORK PERFORMED (Select One)</b>	
Agriculture	
Cable TV	
Curb/Sidewalk	
Bldg. Construction	
Bldg. Demolition	
Drainage	
Driveway	
Electric	
Engineering/Surveying	
Fencing	
Grading	
Irrigation	
Landscaping	
Liquid Pipeline	
Milling	
Natural Gas	
Pole	
Public Transit Authority	
Railroad Maintenance	
Road Work	
Sewer (Sanitary/Storm)	
Site Development	
Steam	
Storm Drain/Culvert	X
Street Light	
Telecommunications	
Traffic Signal	
Traffic Sign	
Water	
Waterway Improvement	
Unknown/Other	
RELEASE OF PRODUCT (YES/NO)	No
IGNITION AND/OR FIRE (YES/NO)	No
EXCAVATOR NOTIFY 811 (YES/NO)	Yes 1307180954
<b>LOCATE INFORMATION:</b>	
EXCAVATOR REQUEST LOCATE (YES/NO)	No

INDIANA 811 LOCATE TICKET NUMBER	
LOCATE MARKS VISIBLE (YES/NO)	N/A
LOCATE MARKS CORRECT (YES/NO)	N/A
EXCAVATOR "WHITE LINED" (YES/NO)	N/A
MAPS USED TO MARK FACILITIES (YES/NO)	N/A
OPERATOR EMPLOYEES ON-SITE DURING EXCAVATION (YES/NO)	No
<b>INCIDENT IMPACT INFORMATION</b>	
NUMBER OF OUTPATIENT TREATED	0
NUMBER OF INPATIENT TREATED	0
NUMBER OF FATALITIES	0
FIRE DEPARTMENT RESPONSE (YES/NO)	N/A
POLICE DEPARTMENT RESPONSE (YES/NO)	N/A
AMBULANCE RESPONSE (YES/NO)	N/A
<b>ADDITIONAL INFORMATION/COMMENTS</b>	
<p>No release of gas. Excavator working on expired ticket # 1305132520  Nipsco Emergency Repair Ticket # 1307180926</p>	

Order/Ticket Charges = \$ 0.00, Ticket # 942976203, Order # 386558209


Order Activity

Type	Date/Time	Operato
<b>FEDBACK-COMPLETE</b>	07/18/2013-09:21AM	WMNIPRD
COMPLETE IN FIELD	07/18/2013-09:21AM	WMNIPRD
ON-SITE	07/18/2013-09:01AM	WMNIPRD
ENROUTE	07/18/2013-08:43AM	WMNIPRD
ASSIGNED	07/18/2013-08:43AM	WMNIPRD
ACCEPTED	07/18/2013-08:26AM	TOMONDI, M
SCHEDULED	07/18/2013-08:26AM	VELAZQUEZ
UNSCHEDULED	07/18/2013-08:26AM	VELAZQUEZ

Order Status Comments

NO LEAK FOUND

Page 1 of 1



**Order/Ticket Charges = \$ 0.00, Ticket # 942976203, Order # 386558209**

Order Type GAS LEAK  
Customer Name KRAMER, SUSAN P  
Customer Address 2736 N GOLDRING RD  
LA PORTE, IN  
Customer Phone (219) 879-5572 Ext Contact Ph (219) 362-2051 Ext  
Original Caller CHARITY, LAPORTE CO HWY DEPT  Mar  
Modified Caller  Field  
Schdl Date/Time 07/18/2013 8:00AM - 9:59AM Sent to WMS 07/18/2013  
Employee ID   
Charge Type

- General
- Order Activity
- Feedback
- Gas Leak
- Related Orders



# NORTHERN INDIANA PUBLIC SERVICE COMPANY FACILITY DAMAGE REPORT

\*\* COMPLETE FORM FOR ALL DAMAGES TO NIPSCO FACILITIES \*\*

REPORTING OPERATING AREA LaPorte MAXIMO WO # N/A  
 OPERATING AREA CONTACT Slocum JOB ORDER # NONE  
 TRACKING NUMBER 018 7013 0718 004 LOCATE REF # N/A  
 Locate Performed By: \_\_\_\_\_

DATE AND TIME OF ACCIDENT 7/18 2013, 9:00AM DATE OF REPORT 7/18/13  
 PLACE OF DAMAGE (INCLUDE CITY) 2736 N Golden Rd LaPorte

**DAMAGE WAS TO:**  
**ELECTRIC** - POLE / TRANSFORMER: # \_\_\_\_\_ SIZE \_\_\_\_\_ YEAR INSTALLED \_\_\_\_\_ BROKEN YES ( ) NO ( )  
 OTHER (DESCRIBE) NONE

**GAS:** SERVICE ( ) MAIN (  ) SIZE \_\_\_\_\_ MATERIAL: PLASTIC ( ) STEEL (  ) METER ( ) REG STATION ( ) STUB ( )  
 OTHER (DESCRIBE) \_\_\_\_\_

DEPTH OF FACILITY (inches) 30" PRESSURE (PSI) N/A Lbs.

RELEASE OF GAS: YES ( ) NO (  ) IGNITION OF GAS: YES ( ) NO (  ) EVACUATION REQUIRED: YES ( ) # \_\_\_\_\_ NO (  )

INTERRUPTION OF SERVICE: YES ( ) NO (  ) NUMBER OF CUSTOMERS LOST: 0

DURATION OF INTERRUPTION: TIME REPORTED N/A TIME RESTORED N/A

DIAMETER/MEASUREMENT OF HOLE IN GAS FACILITY: NONE

LOCATE MARKS ON SITE: YES (  ) DISTANCE BETWEEN FACILITY AND LOCATE MARKS \_\_\_\_\_ NO ( )  
 HOW LOCATED: PAINT ( ) FLAGS ( ) BOTH ( ) WHITE LINED ( )

PARTY THAT CAUSED DAMAGES (NAME) LaPorte County Street Dept

ADDRESS OF PARTY (INCLUDE CITY) \_\_\_\_\_

WHO WAS IN CHARGE OF THE WORK SITE AT TIME OF DAMAGE \_\_\_\_\_

WITNESS NAME AND ADDRESS \_\_\_\_\_

WITNESS REMARKS \_\_\_\_\_

AGENCIES NOTIFIED / ONSITE: POLICE ( ) AGENCY \_\_\_\_\_ REPORT # \_\_\_\_\_  
 FIRE ( ) AGENCY \_\_\_\_\_ REPORT # \_\_\_\_\_  
 OTHER ( ) \_\_\_\_\_ Any Injuries? ( ) YES # \_\_\_\_\_ (  ) NO

PHOTOS TAKEN: YES ( ) NO (  ) TAKEN BY: \_\_\_\_\_ (ATTACH PHOTOS TO REPORT)  
 MEDIA ON SITE YES ( ) NO (  )

- WORK IN PROGRESS WHEN FACILITY DAMAGED** — CHECK APPROPRIATE CHOICE BELOW
- |                         |                |  |                        |
|-------------------------|----------------|--|------------------------|
| ( ) AGRICULTURE/FARMING | ( ) CABLE TV   | ( ) CURB/SIDEWALK                                | ( ) TELECOMMUNICATIONS |
| ( ) BLDG CONSTRUCTION   | ( ) DEMOLITION | ( <input checked="" type="checkbox"/> ) DRAINAGE | ( ) WATER              |
| ( ) DRIVEWAY            | ( ) ELECTRIC   | ( ) SURVEYING                                    | ( ) DRAINS/CULVERTS    |
| ( ) FENCING             | ( ) GRADING    | ( ) IRRIGATION                                   | ( ) MOWING             |
| ( ) LANDSCAPING         | ( ) PIPELINE   | ( ) MILLING                                      | ( ) OTHER _____        |
| ( ) POLE/SIGN POST      | ( ) ROAD WORK  | ( ) SEWER  |                        |

- TYPE OF EQUIPMENT USED** — CHECK APPROPRIATE CHOICE BELOW
- |                       |                    |   |
|-----------------------|--------------------|---|
| ( ) AUGER             | ( ) HAND TOOLS     | ( ) BACKHOE/TRACKHOE                                |
| ( ) MILLING EQUIPMENT | ( ) PROBING DEVICE | ( ) BORING / DRILLING                               |
| ( ) EXPLOSIVES        | ( ) TRENCHER       | ( ) FARM EQUIPMENT                                  |
| ( ) VACCUUM EQUIPMENT | ( ) GRADER         | ( <input checked="" type="checkbox"/> ) OTHER _____ |

- REASON DAMAGE OCCURRED** — CHECK APPROPRIATE CHOICE BELOW
- |                         |                                   |  |
|-------------------------|-----------------------------------|--|
| ( ) AUTOMOTIVE ACCIDENT | ( ) EXCAVATING BEFORE LOCATES DUE | ( ) CARELESS MACHINE OPERATOR                                |
| ( ) NO NOTIFICATION     | ( ) MARKS DISTURBED               | ( ) STUB   |
|                         |                                   | ( <input checked="" type="checkbox"/> ) OTHER <u>unknown</u> |

COMMENTS:

Country well main no repairs needed.  
pulled cabinet scrap'd main.

PERSON PREPARING REPORT

Steve Garsen

FIELD SUPERVISOR

Steve Garsen

FIELD MANAGER

Rich Elm

- ORIGINAL REPORT AND SUPPORTING INFORMATION IS TO BE SENT TO FACILITY DAMAGE RECOVERY
- COPY OF REPORT IS TO BE SENT TO DAMAGE PREVENTION

SKETCH: - Show position of all pertinent information

**FOR OFFICE USE ONLY:**

- |   |     |    |
|---|-----|----|
| • DID EXCAVATION OCCUR BEFORE LOCATES WERE DUE  | YES | NO |
| • NO IN 811 LOCATE CALLED IN                    | YES | NO |
| • DAMAGE CAUSED FROM EXCAVATION WITHIN 24" ZONE | YES | NO |
| • EXPIRED LOCATE                                | YES | NO |
| • WAS WHITE LINING INDICATED ON LOCATE REQUEST  | YES | NO |

COMPLETED BY: \_\_\_\_\_ DATE: \_\_\_\_\_



NIPSCO 00847 IUPPSa 05/13/2013 13:24:28 1305132520-00A NORM NEW GRID

NORMAL NOTICE **EXPIRED TICKET**

Ticket : 1305132520 Date: 05/13/2013 Time: 13:21 Oper: SPOPE Chan:044

State: IN Cnty: LAPORTE Twp: COOLSPRING  
Cityname: MICHIGAN CITY Inside: N Near: Y  
Subdivision:

Address :  
Street : N GOLDRING RD  
Cross 1 : W 275 N Within 1/4 mile: Y  
Location: STARTING AT 2736 GOING NORTH AND SOUTH 100FT--LOCATE BOTH SIDES OF  
GOLDRING RD

:  
Grids : 4138A8649A 4138A8650D 4138B8649A  
Boundary: n 41.648485 s 41.644323 w -86.834903 e -86.830069

Work type : REPLACE CULVERT  
Done for : LAPORTE COUNTY HIGHWAY  
Start date: 05/15/2013 Time: 13:30 Hours notice: 48/048 Priority: NORM  
Ug/Oh/Both: U Blasting: N Boring: N Railroad: N Emergency: N  
Duration : 2 DAYS Depth: 8 FEET

Company : LAPORTE COUNTY HIGHWAY DEPARTMENT Type: OTHR  
Co addr : 1805 WEST 5TH STREET  
City : LA PORTE State: IN Zip: 46350  
Caller : JOE SKALKA Phone: (219)362-2051  
Contact : JOE SKALKA---CELL Phone:  
BestTime:  
Mobile : (219)608-9742  
Fax : (219)362-4221

Remarks : All tickets are taken and processed on Eastern Daylight Time  
Will you be white-lining the dig site area? YES  
:

Submitted date: 05/13/2013 Time: 13:21  
Members: BE COMCN ID5845 ID9330 NIPSCO SBCIN SM

NIPSCO 00318 IUPPSa 07/18/2013 09:53:49 1307180954-00A EMER DAMG GRID

DAMAGE DAMAGE -SEE REMARKS

Ticket : 1307180954 Date: 07/18/2013 Time: 09:49 Oper: CALEVI Chan:031

State: IN Cnty: LAPORTE Twp: COOLSPRING  
Cityname: MICHIGAN CITY Inside: N Near: Y  
Subdivision:

Address :

Street : N GOLDRING RD

Cross 1 : W 275 N Within 1/4 mile: Y

Location: STARTING AT 2736 GOING NORTH AND SOUTH 100FT--LOCATE BOTH SIDES OF  
GOLDRING RD

:

Grids : 4138A8649A 4138A8650D 4138B8649A

Boundary: n 41.648485 s 41.644323 w -86.834903 e -86.830069

Work type : REPLACE CULVERT

Done for : LAPORTE COUNTY HIGHWAY

Start date: 07/18/2013 Time: 09:50 Hours notice: 0/000 Priority: EMER

Ug/Oh/Both: U Blasting: N Boring: N Railroad: N Emergency: Y

Duration : 2 DAYS Depth: 8 FEET

Company : LAPORTE COUNTY HIGHWAY DEPARTMENT Type: OTHR

Co addr : 1805 WEST 5TH STREET

City : LA PORTE State: IN Zip: 46350

Caller : JOE SKALKA Phone: (219)362-2051

Contact : JOE SKALKA---CELL Phone:

BestTime:

Mobile : (219)608-9742

Fax : (219)362-4221

Remarks : All tickets are taken and processed on Eastern Daylight Time  
PER CHARITY-HAVE NICKED A NIPSCO GAS LINE -IT IS NOT SPEWING,HAVE CALLED  
NIPSCO-IT WAS A PLASTIC LINE-NOT SURE OF LOCATION EXCEPT-THATS ITS IN THE  
RIGHT

OF WAY-CREW IS ON SITE-PREVIOUS TICKET NUMBER 1305132520

Will you be white-lining the dig site area? YES

:

Submitted date: 07/18/2013 Time: 09:49

Members: BE COMCN ID5845 ID9330 NIPSCO SBCIN SM

NIPSCO 00307 IUPPSa 07/18/2013 09:50:30 1307180926-00A EMER NEW GRID

EMERGENCY SEE REMARKS

Ticket : 1307180926 Date: 07/18/2013 Time: 09:47 Oper: SPOPE Chan:044

State: IN Cnty: LAPORTE Twp: COOLSPRING  
Cityname: LA PORTE Inside: N Near: Y  
Subdivision:

Address : 2736  
Street : N GOLDRING RD  
Cross 1 : PINEBROOK DR Within 1/4 mile: Y  
Location: LOCATE ENTIRE PROPERTY

:  
Grids : 4138A8649A 4138A8650D 4138B8649A 4138B8650D  
Boundary: n 41.648989 s 41.645310 w -86.835493 e -86.829866

Work type : REPAIR GAS LINE  
Done for : NIPSCO  
Start date: 07/18/2013 Time: 09:48 Hours notice: 0/000 Priority: EMER  
Ug/Oh/Both: U Blasting: N Boring: N Railroad: N Emergency: Y  
Duration : 1 DAY Depth: 6 FEET

Company : NIPSCO Type: MEMB  
Co addr : 801 EAST 86TH AVENUE  
City : MERRILLVILLE State: IN Zip: 46410  
Caller : JAMILA MARTIN Phone: (800)322-2806  
Contact : STEVE GEORGIAN - CELL Phone:  
BestTime:  
Mobile : (219)363-1033  
Fax : (219)647-4764

Remarks : All tickets are taken and processed on Eastern Daylight Time  
CREW EN ROUTE  
Will you be white-lining the dig site area? NO  
:

Submitted date: 07/18/2013 Time: 09:47  
Members: BE COMCN ID5845 ID9330 NIPSCO SBCIN SM

Fact Based Investigation Report

**Notification ID** 01820130718004  
**Damage Date** 07/18/2013 08:25  
**Notified By** JAMILA MARTIN (Facility Owner)  
**Damage Address** 2736 N GOLDRING RD X PINEBROOK DR LAPORTE  
LA PORTE, IN  
**District** Northern Indiana  
**Notification Date** 07/18/2013 09:57

---

**Damaged Customer** NIPSCO

---

**Investigation Date From** 07/18/2013 09:10:00 **To** 07/18/2013 09:30:00

---

**Excavator Involved** LAPorte County Highway  
**Type of Excavation** REPLACE CULVERT

---

**Orig. Locate Request** 1305132520 **Start Date**  
**Type of Ticket** **Locate Req. Info** N/A

---

**Damage Request #** M97374403 **Start Date**

---

**Pictures Taken By** ERIC VEACH **Date** 07/18/2013 09:15  
**Photography Type** Digital **Frame #**

---

**Investigator Emp. #** 113212 **Investigator Name** ERIC VEACH  
**Based on your investigation, is further investigation needed?** No

---

 Fact Based Investigation Customer Information

**Facility Description** Low Profile **Facility ID** Gas Main

**Locator Name & EMP #** Kmiecik Justin - 136441 **Locator Not Known**

---

**Investigation Findings**

Facility Marked Accurately

**Other Notes**

---

**Investigation Methods**

Visual, Facility Exposed At Time Of Investigation

---

**Investigator Statement/Causal Factors**

LA PORTE COUNTY HIGHWAY DEPT. WAS REPLACING A CULVERT WHEN THEY NICKED A 2"PL NIPSCO GAS MAIN. NO GAS WAS LEAKING FROM THE NICK. TICKET IS OLD BACK FROM MAY OF 2013. THERE ARE OLD MARKS IN THE ROAD THAT I CIRCLED WITH WHITE PAINT THAT LINE UP WITH THE MAIN THAT IS EXPOSED. CONTRACTOR HAD THE MAIN EXPOSED WHEN THEY WERE PULLING THE OLD CULVERT OUT WHEN THEY NICKED THE 2"PL GAS MAIN.

**Names of Utility Representatives Contacted or on Site and Statement**

APPEARS NIPSCO HAD MARKED MAIN ON AN UNTONEABLE.

**Names of Excavator's Representatives Contacted or on Site and Statement**

N/A

**Other individuals on site**

N/A

---

**Were any markings visible on the damage site upon arrival?** Yes

<b>Were any other indicators of facility present in the area?</b>	Yes
<b>Was the excavation within the tolerance zone of marks?</b>	No
<b>Extent of facility damage</b>	NICKED
<b>Replacement Footage</b>	N/A
<b>Was contractor assistance required? If yes, who?</b>	No
<b>What contractor equipment was used?</b>	TRACKHOE
<b>Is the facility shown on the utility records?</b>	Yes
<b>If yes, list record numbers</b>	LAP



Property of United States Infrastructure Corporation

Photo taken on 7/18/2013 9:19:42 AM