
TITLE 410 INDIANA STATE DEPARTMENT OF HEALTH

Notice of Intent to Adopt a Rule

LSA Document #07-657

Under [IC 4-22-2-23](#), the Indiana State Department of Health intends to adopt a rule concerning the following:

OVERVIEW: Amends [410 IAC 16.2](#) to require automatic fire sprinkler systems in comprehensive care facilities and have a battery operated or hard-wired smoke detector in each resident's room as required by [IC 16-28-11-5](#). Amends [410 IAC 16.2](#) to clarify license requirements for comprehensive and residential care administrators in accordance with [IC 25-19-1-5](#) regarding comprehensive care facility administrator licenses and residential care facility administrator licenses. Amends the definition of children. Written comments may be submitted to the Indiana State Department of Health, Health Care Regulatory Services Commission, 2 North Meridian Street, Indianapolis, Indiana 46204. Statutory authority: [IC 16-28-1-7](#); [IC 16-28-1-12](#); [IC 16-28-11-5](#).

For purposes of [IC 4-22-2-28.1](#), the Small Business Regulatory Coordinator for this rule is:

Terry Whitson
Indiana State Department of Health
2 North Meridian Street, 5A
Indianapolis, Indiana 46204
(317) 233-7022
twhitson@isdh.in.gov

Posted: 10/10/2007 by Legislative Services Agency
An [html](#) version of this document.