
FIRE PREVENTION AND BUILDING SAFETY COMMISSION

Interpretation by the Fire Prevention and Building Safety Commission

Title: Interpretation of [675 IAC 28-1-4](#) (NFPA 12-2005 edition), Sections 4.4.3 and 4.4.4

Date: July 2, 2013

Purpose: The purpose of this nonrule policy document is to clarify the effect of the Indiana amendments to Sections 4.4.3 and 4.4.4, concerning testing requirements for carbon dioxide extinguishing systems.

Interpretation: The Indiana amendments require that visual and operational testing be performed, but not full discharge testing.

Posted: 07/10/2013 by Legislative Services Agency

An [html](#) version of this document.