
FIRE PREVENTION AND BUILDING SAFETY COMMISSION

**Interpretation by
the Fire Prevention and Building Safety Commission**

Title: Interpretation of [675 IAC 14-4.3](#), 2005 Indiana Residential Code, Section R403.1.6

Date: February 2, 2016

Purpose and Background: The purpose of this nonrule policy is to clarify the requirements for anchor bolts at interior load bearing walls.

Interpretation: The Commission hereby interprets Section R403.1.6 to allow adhesive anchoring at load bearing interior walls resisting gravity loads only, bearing on monolithic slabs.

Posted: 05/25/2016 by Legislative Services Agency
An [html](#) version of this document.