
FIRE PREVENTION AND BUILDING SAFETY COMMISSION

**Interpretation by
the Fire Prevention and Building Safety Commission**

Title: Interpretation of [675 IAC 18-1.6](#), 2014 Indiana Mechanical Code, Table 507.2 and Sections 507.2.2 and 507.2.3

Date: February 2, 2016

Purpose and Background: The purpose of this nonrule policy is to clarify the hood requirements for residential appliances used in Class 1 Buildings that are not Retail Food Service Establishments regulated by [410 IAC 7-24](#).

Interpretation: The Commission hereby interprets Table 507.2, 507.2.2, and 507.2.3 to not require either Type I or Type II hoods for residential cooking appliances used in warming kitchens and employee break rooms in other than Retail Food Service Establishments regulated by [410 IAC 7-24](#).

Posted: 05/25/2016 by Legislative Services Agency
An [html](#) version of this document.