

## **ARTICLE 7. SULFUR DIOXIDE RULES**

*NOTE: IC 13-1 and IC 13-7 were repealed by P.L.1-1996, SECTION 99, effective July 1, 1996.*

### **Rule 1. Sulfur Dioxide Emission Limitations**

#### **326 IAC 7-1-1 Applicability (Repealed)**

Sec. 1. *(Repealed by Air Pollution Control Division; filed Aug 28, 1990, 4:50 p.m.: 14 IR 81)*

#### **326 IAC 7-1-2 Sulfur dioxide emission limitations; conflict with local rules (Repealed)**

Sec. 2. *(Repealed by Air Pollution Control Division; filed Aug 28, 1990, 4:50 p.m.: 14 IR 81)*

#### **326 IAC 7-1-3 Reporting requirements and methods to determine compliance (Repealed)**

Sec. 3. *(Repealed by Air Pollution Control Division; filed Aug 28, 1990, 4:50 p.m.: 14 IR 81)*

#### **326 IAC 7-1-4 Ambient monitoring; reports (Repealed)**

Sec. 4. *(Repealed by Air Pollution Control Division; filed Aug 28, 1990, 4:50 p.m.: 14 IR 81)*

#### **326 IAC 7-1-5 Control strategies (Repealed)**

Sec. 5. *(Repealed by Air Pollution Control Division; filed Aug 28, 1990, 4:50 p.m.: 14 IR 81)*

#### **326 IAC 7-1-6 Compliance schedules (Repealed)**

Sec. 6. *(Repealed by Air Pollution Control Division; filed Aug 28, 1990, 4:50 p.m.: 14 IR 81)*

#### **326 IAC 7-1-7 State implementation plan revisions (Repealed)**

Sec. 7. *(Repealed by Air Pollution Control Division; filed Aug 28, 1990, 4:50 p.m.: 14 IR 81)*

#### **326 IAC 7-1-8 Lake County sulfur dioxide limitations (Repealed)**

Sec. 8. *(Repealed by Air Pollution Control Division; filed Sep 23, 1988, 11:12 a.m.: 12 IR 268)*

#### **326 IAC 7-1-8.1 Lake County sulfur dioxide emission limitations (Repealed)**

Sec. 8.1. *(Repealed by Air Pollution Control Division; filed Aug 28, 1990, 4:50 p.m.: 14 IR 81)*

#### **326 IAC 7-1-9 Marion County sulfur dioxide emission limitations (Repealed)**

Sec. 9. *(Repealed by Air Pollution Control Division; filed Aug 28, 1990, 4:50 p.m.: 14 IR 81)*

#### **326 IAC 7-1-10 Vigo County sulfur dioxide emission limitations (Repealed)**

Sec. 10. *(Repealed by Air Pollution Control Division; filed Jun 30, 1988, 3:00 pm: 11 IR 3787)*

#### **326 IAC 7-1-10.1 Vigo County sulfur dioxide emission limitations (Repealed)**

Sec. 10.1. *(Repealed by Air Pollution Control Division; filed Aug 28, 1990, 4:50 p.m.: 14 IR 81)*

**326 IAC 7-1-11 Wayne County sulfur dioxide emission limitations (Repealed)**

Sec. 11. *(Repealed by Air Pollution Control Division; filed Aug 28, 1990, 4:50 p.m.: 14 IR 81)*

**326 IAC 7-1-12 Laporte County sulfur dioxide emission limitations (Repealed)**

Sec. 12. *(Repealed by Air Pollution Control Division; filed Aug 28, 1990, 4:50 p.m.: 14 IR 81)*

**326 IAC 7-1-13 Jefferson County sulfur dioxide emission limitations (Repealed)**

Sec. 13. *(Repealed by Air Pollution Control Division; filed Aug 28, 1990, 4:50 p.m.: 14 IR 81)*

**326 IAC 7-1-14 Sullivan County sulfur dioxide emission limitations (Repealed)**

Sec. 14. *(Repealed by Air Pollution Control Division; filed Aug 28, 1990, 4:50 p.m.: 14 IR 81)*

**326 IAC 7-1-15 Vermillion County sulfur dioxide emission limitations (Repealed)**

Sec. 15. *(Repealed by Air Pollution Control Division; filed Aug 28, 1990, 4:50 p.m.: 14 IR 81)*

**326 IAC 7-1-16 Floyd County sulfur dioxide emission limitations (Repealed)**

Sec. 16. *(Repealed by Air Pollution Control Division; filed Aug 28, 1990, 4:50 p.m.: 14 IR 81)*

**326 IAC 7-1-17 Warrick County sulfur dioxide emission limitations (Repealed)**

Sec. 17. *(Repealed by Air Pollution Control Division; filed Aug 28, 1990, 4:50 p.m.: 14 IR 81)*

**326 IAC 7-1-18 Morgan County sulfur dioxide emission limitations (Repealed)**

Sec. 18. *(Repealed by Air Pollution Control Division; filed Aug 28, 1990, 4:50 p.m.: 14 IR 81)*

**326 IAC 7-1-19 Gibson County sulfur dioxide emission limitations (Repealed)**

Sec. 19. *(Repealed by Air Pollution Control Division; filed Aug 28, 1990, 4:50 p.m.: 14 IR 81)*

**326 IAC 7-1-20 Dearborn County sulfur dioxide emission limitations (Repealed)**

Sec. 20. *(Repealed by Air Pollution Control Division; filed Aug 28, 1990, 4:50 p.m.: 14 IR 81)*

**326 IAC 7-1-21 Porter County sulfur dioxide emission limitations (Repealed)**

Sec. 21. *(Repealed by Air Pollution Control Division; filed Aug 28, 1990, 4:50 p.m.: 14 IR 81)*

**Rule 1.1. Sulfur Dioxide Emission Limitations**

**326 IAC 7-1.1-1 Applicability**

Authority: IC 13-14-8; IC 13-17-3-4; IC 13-17-3-11; IC 13-17-3-12

Affected: IC 13-15; IC 13-17

Sec. 1. All emissions units with a potential to emit twenty-five (25) tons per year or ten (10) pounds per hour of sulfur dioxide shall comply with the following:

(1) The limitations in section 2 of this rule.

(2) The compliance test methods in 326 IAC 7-2.

(3) The sulfur dioxide emission limitations and other requirements under 326 IAC 2, 326 IAC 7-4, 326 IAC 7-4.1, and 326 IAC 12.

*(Air Pollution Control Division; 326 IAC 7-1.1-1; filed Aug 28, 1990, 4:50 p.m.: 14 IR 52; filed Apr 22, 1997, 2:00 p.m.: 20 IR 2368; filed Dec 20, 2001, 4:30 p.m.: 25 IR 1600; filed May 25, 2005, 10:50 a.m.: 28 IR 2953)*

**326 IAC 7-1.1-2 Sulfur dioxide emission limitations**

Authority: IC 13-14-8; IC 13-17-3-4; IC 13-17-3-11; IC 13-17-3-12

Affected: IC 13-15; IC 13-17

Sec. 2. (a) Sulfur dioxide emissions from fuel combustion emissions units shall be limited as follows, unless specified otherwise in 326 IAC 7-4, 326 IAC 7-4.1, or in a construction permit issued under 326 IAC 2:

(1) Six and zero-tenths (6.0) pounds per million British thermal units (MMBtu) for coal combustion.

(2) One and six-tenths (1.6) pounds per MMBtu for residual oil combustion.

(3) Five-tenths (0.5) pound per MMBtu for distillate oil combustion.

(b) For emissions units combusting coal and oil simultaneously, the sulfur dioxide emission limitation shall be six and zero-tenths (6.0) pounds per MMBtu. For emissions units combusting oil and any fuel other than coal simultaneously, the sulfur dioxide emission limitation shall be the limitation specified in subsection (a)(2) or (a)(3), depending on the type of oil combusted. For the purposes of this subsection, simultaneous combustion of coal and oil shall include those periods of startup, shutdown, and flame stabilization required under normal operations. *(Air Pollution Control Division; 326 IAC 7-1.1-2; filed Aug 28, 1990, 4:50 p.m.: 14 IR 52; filed Apr 22, 1997, 2:00 p.m.: 20 IR 2369; filed Dec 20, 2001, 4:30 p.m.: 25 IR 1600; filed May 25, 2005, 10:50 a.m.: 28 IR 2953)*

**326 IAC 7-1.1-3 Compliance date**

Authority: IC 13-14-8; IC 13-17

Affected: IC 13-15; IC 13-17

Sec. 3. The emission limitations in 326 IAC 7-4-2.1, 326 IAC 7-4-3.1, 326 IAC 7-4-11.1, and 326 IAC 7-4-15 are effective January 1, 2017. *(Air Pollution Control Division; 326 IAC 7-1.1-3; filed Sep 2, 2015, 1:50 p.m.: 20150930-IR-326110356FRA)*

**Rule 2. Compliance**

**326 IAC 7-2-1 Reporting requirements; methods to determine compliance**

Authority: IC 13-14-8; IC 13-17-3-4; IC 13-17-3-11

Affected: IC 13-14-8; IC 13-15; IC 13-17

Sec. 1. (a) As used in this article, "weighting factor" means the daily quantity of coal bunkered or megawatt generation or other appropriate measure of the output of a combustion source.

(b) As used in this article, "rolling weighted average sulfur dioxide emission rate" means the summation of the average sulfur dioxide emission rate times the daily weighting factor divided by the summation of the weighting factors.

(c) Owners or operators of sources or emissions units subject to 326 IAC 7-1.1, 326 IAC 7-4, or 326 IAC 7-4.1 shall submit to the commissioner the following reports based on fuel sampling and analysis data obtained in accordance with procedures

specified under 326 IAC 3-7:

- (1) Fuel combustion sources with total coal-fired heat input capacity greater than or equal to one thousand five hundred (1,500) million British thermal units (MMBtu) per hour shall submit quarterly reports of the thirty (30) day rolling weighted average sulfur dioxide emission rate in pounds per MMBtu. Records of the daily average coal sulfur content, coal heat content, weighting factor, and daily average sulfur dioxide emission rate in pounds per MMBtu shall be submitted to the department in the quarterly report and maintained by the source owner or operator for a period of at least two (2) years.
- (2) Fuel combustion sources with total coal-fired heat input capacity greater than one hundred (100) and less than one thousand five hundred (1,500) MMBtu per hour shall submit quarterly reports of the calendar month average coal sulfur content, coal heat content, and sulfur dioxide emission rate in pounds per MMBtu and the total monthly coal consumption.
- (3) All other fuel combustion sources shall submit reports of calendar month average sulfur content, heat content, fuel consumption, and sulfur dioxide emission rate in pounds per MMBtu upon request.
- (d) Fuel sampling and analysis data shall be collected pursuant to the procedures specified in 326 IAC 3-7-2 or 326 IAC 3-7-3 for coal combustion or 326 IAC 3-7-4 for oil combustion. Computation of calculated sulfur dioxide emission rates from fuel sampling and analysis data shall be based on the emission factors contained in U.S. EPA publication AP-42\* unless other emission factors based on site-specific sulfur dioxide measurements are approved by the commissioner and U.S. EPA. Fuel sampling and analysis data shall be collected as follows:
  - (1) For coal-fired fuel combustion sources with heat input capacity greater than or equal to one thousand five hundred (1,500) MMBtu per hour, compliance shall be determined using a thirty (30) day rolling weighted average sulfur dioxide emission rate in pounds per MMBtu unless a shorter averaging time or alternate averaging methodology is specified for a source under this article.
  - (2) For all other combustion sources, compliance shall be determined using a calendar month average sulfur dioxide emission rate in pounds per MMBtu unless a shorter averaging time or alternate averaging methodology is specified for a source under this article.
  - (e) Subsection (c) does not apply when continuous emission monitoring data collected and reported under 326 IAC 3-5 is used as the means for determining compliance with the emission limitations in this article.
  - (f) Owners or operators of sources or emission units subject to a restriction on the number of operating hours in 326 IAC 7-4 shall maintain, and make available to the department upon request, a log of operating hours for each emission unit.
  - (g) When determining compliance using continuous emission monitoring data, the diluent cap methodology under 40 CFR 75 may be used to calculate emissions in lbs/MMBtu.
  - (h) Compliance or noncompliance with the emission limitations contained in 326 IAC 7-1.1 or 326 IAC 7-4 may be determined by an appropriate method as follows:
    - (1) A stack test conducted in accordance with 326 IAC 3-6 using procedures in 40 CFR 60, Appendix A, Method 6\*, 6A\*, 6C\*, or 8\*.
    - (2) A continuous emission monitoring system in accordance with 326 IAC 3-5.
    - (3) Source sampling in accordance with 326 IAC 3-6.
    - (4) Fuel sampling and analysis data collected in accordance with subsection (d) or 326 IAC 3-7.
    - (5) Other methods approved by the commissioner and U.S. EPA.

\*These documents are incorporated by reference. Copies may be obtained from the Government Printing Office, 732 North Capitol Street NW, Washington, D.C. 20401 or are available for review and copying at the Indiana Department of Environmental Management, Office of Legal Counsel, Indiana Government Center North, Thirteenth Floor, 100 North Senate Avenue, Indianapolis, Indiana 46204. (*Air Pollution Control Division; 326 IAC 7-2-1; filed Aug 28, 1990, 4:50 p.m.: 14 IR 52; filed Jan 30, 1998, 4:00 p.m.: 21 IR 2078; errata filed Feb 9, 1999, 4:06 p.m.: 22 IR 2006; readopted filed Jan 10, 2001, 3:20 p.m.: 24 IR 1477; errata filed Nov 7, 2001, 3:00 p.m.: 25 IR 813; errata filed Dec 12, 2002, 3:30 p.m.: 26 IR 1565; filed Aug 26, 2004, 11:30 a.m.: 28 IR 42; filed May 25, 2005, 10:50 a.m.: 28 IR 2953; filed Aug 11, 2011, 1:54 p.m.: 20110907-IR-326050330FRA; filed Sep 2, 2015, 1:50 p.m.: 20150930-IR-326110356FRA*)

### **Rule 3. Ambient Monitoring**

**326 IAC 7-3-1 Applicability**

Authority: IC 13-14-8; IC 13-17-3-4; IC 13-17-3-11; IC 13-17-3-12

Affected: IC 13-15; IC 13-17

Sec. 1. Sources with total actual emissions of sulfur dioxide greater than ten thousand (10,000) tons per year are subject to the requirements of this rule. (*Air Pollution Control Division; 326 IAC 7-3-1; filed Aug 28, 1990, 4:50 p.m.: 14 IR 53; filed Apr 22, 1997, 2:00 p.m.: 20 IR 2369; filed Dec 20, 2001, 4:30 p.m.: 25 IR 1600*)

**326 IAC 7-3-2 Ambient monitoring**

Authority: IC 13-1-1-4; IC 13-7-7

Affected: IC 13-1-1-1; IC 13-1-1-4; IC 13-7

Sec. 2. (a) The source owner or operator shall install and operate continuous ambient sulfur dioxide air quality monitors and a meteorological data acquisition system according to a monitoring plan submitted to the commissioner for approval. At a minimum, the monitoring plan shall contain the following requirements:

(1) Installation and operation of one (1) or two (2) air quality monitors and one (1) meteorological instrumentation system capable of measuring wind speed and wind direction at a height of at least ten (10) meters above grade. The monitor shall be located in areas of expected maximum ambient concentration as determined by methods acceptable to the commissioner.

(2) Reporting of the air quality and meteorological data in a format specified by the commissioner within ninety (90) days after the end of each calendar quarter.

(3) Operation of the air quality monitor and meteorological instrumentation in accordance with a quality assurance program specified by the commissioner.

(b) A monitoring plan shall be submitted to the department prior to October 1, 1991. The commissioner may require that the monitoring plan be modified, at any time, consistent with the requirements of this section.

(c) Source owners or operators subject to the requirements of this rule, located in the same county, may submit a joint monitoring plan to satisfy the requirements of this rule. The joint monitoring plan shall specify the responsible owner or operator for each requirement in subsection (a). Upon approval by the commissioner, the joint monitoring plan may contain fewer than two (2) air quality monitors and one (1) meteorological station per owner or operator.

(d) A source owner or operator may petition the commissioner for an administrative waiver of all or some of the requirements of this section if such owner or operator can demonstrate that ambient monitoring is unnecessary to determine continued maintenance of the sulfur dioxide ambient air quality standards in the vicinity of the source. The demonstration shall address uncertainties in any air quality dispersion models used in the demonstration and shall address the adequacy of any existing monitoring data to characterize the worst-case ambient concentrations in the vicinity of the source. A waiver shall be effective upon written approval by the commissioner. The commissioner may establish conditions in the approval of a waiver to assure compliance with the provisions of this article. Failure to continuously meet the requirements for obtaining a waiver or failure to comply with any condition contained in the approval of a waiver shall render void any waiver issued. (*Air Pollution Control Division; 326 IAC 7-3-2; filed Aug 28, 1990, 4:50 p.m.: 14 IR 53*)

**Rule 4. Emission Limitations and Requirements by County**

**326 IAC 7-4-1 Lake County sulfur dioxide emission limitations (Repealed)**

Sec. 1. (*Repealed by Air Pollution Control Division; filed Aug 8, 1991, 10:00 a.m.: 14 IR 2218*)

**326 IAC 7-4-1.1 Lake County sulfur dioxide emission limitations (Repealed)**

Sec. 1.1. (*Repealed by Air Pollution Control Division; filed May 25, 2005, 10:50 a.m.: 28 IR 2966*)

## SULFUR DIOXIDE RULES

### 326 IAC 7-4-2 Marion County sulfur dioxide emission limitations before January 1, 2017 Version a

Authority: IC 13-14-8; IC 13-17-3-4

Affected: IC 13-12; IC 13-14-4-3; IC 13-16-1

*NOTE: This version of section effective until January 1, 2017. See also following version of section, effective January 1, 2017.*

Sec. 2. Before January 1, 2017, sources and emission units located in Marion County shall comply with the sulfur dioxide emission limitations in pounds per million Btu (lbs/MMBtu) and pounds per hour (lbs/hr), unless otherwise specified, and other requirements, as follows:

| Source                                                                  | Emission Unit Description | Emission Limitations lbs/MMBtu | Emission Limitations lbs/hr |
|-------------------------------------------------------------------------|---------------------------|--------------------------------|-----------------------------|
| (1) Belmont Advanced Wastewater Treatment Plant Source ID No. 00032     | (A) Incinerator 1         | 2.0 pounds per ton             | 14.19                       |
|                                                                         | (B) Incinerator 2         | 2.0 pounds per ton             | 14.19                       |
|                                                                         | (C) Incinerator 3         | 2.0 pounds per ton             | 14.19                       |
|                                                                         | (D) Incinerator 4         | 2.0 pounds per ton             | 14.19                       |
| (2) Quemetco Source ID No. 00079                                        | Reverberatory Furnace     | 24.6 pounds per ton            | 617.0                       |
| (3) Vertellus Agriculture and Nutrition Specialties Source ID No. 00315 | (A) 2722 W                | 1.25                           | 114.75                      |
|                                                                         | (B) 2726 S                | 1.25                           | 49.1                        |
|                                                                         | (C) 186 N                 | 1.25                           | 46.0                        |
|                                                                         | (D) 2707 V                | 1.25                           | 20.0                        |
|                                                                         | (E) 112 E                 | 0.0**                          | 0.0**                       |
|                                                                         | (F) 2724 W                | 1.25                           | 26.3                        |
|                                                                         | (G) 2714 V                | 1.25                           | 18.8                        |
|                                                                         | (H) 2729 Q                | 1.25                           | 3.8                         |
|                                                                         | (I) 2740 Q                | 1.25                           | 7.5                         |
|                                                                         | (J) 732714                | 1.25                           | 45.0                        |
|                                                                         | (K) 2728 S                | 1.25                           | 7.5                         |
|                                                                         | (L) Still                 | less than 0.05                 | 0.0**                       |
|                                                                         | (M) Kettle                | less than 0.05                 | 0.0**                       |
|                                                                         | (N) 2607 T                | less than 0.05                 | 0.0**                       |
|                                                                         | (O) 722804                | less than 0.05                 | 0.0**                       |
|                                                                         | (P) 2706 Q                | less than 0.05                 | 0.0**                       |

(4) Rolls-Royce Corporation Plant 8, Source ID No. 00311, shall comply with the sulfur dioxide emission limitations and other requirements as follows:

(A) Babcock and Wilcox Boilers 3 (0070-58), 4 (0070-59), and Combustion Engineering Boilers 7 through 10 (0070-62 through 0070-65) may burn either:

(i) natural gas at any time; or

(ii) fuel oil with a sulfur dioxide emission limitation of two and one-tenth (2.1) lbs/MMBtu each during periods when either fuel oil is burned in no more than:

(AA) two (2) Babcock and Wilcox boilers and no more than two (2) combustion engineering boilers; or

(BB) one (1) Babcock and Wilcox boiler and no more than three (3) combustion engineering boilers.

(B) A log of hourly operational status and fuel type for each boiler shall be maintained at the plant and made available to the department upon request.

(C) A daily summary of operating status and fuel type for each boiler for each day of a calendar quarter shall be submitted to the department on a quarterly basis.

(D) Rolls-Royce Corporation Plant 8 shall maintain a twenty (20) foot stack extension with a diameter at the extension outlet of four (4) feet for each stack serving Boilers 3 (0070-58) and 4 (0070-59).

---

SULFUR DIOXIDE RULES

---

(5) Citizens Thermal, C.C. Perry K Steam Plant, Source ID No. 00034, shall comply with the sulfur dioxide emission limitations in lbs/MMBtu and other requirements as follows:

(A) Boiler numbers 17 and 18 shall not exceed three-tenths (0.3) lbs/MMBtu.

(B) Boiler numbers 11, 12, 13, 14, 15, and 16 shall not exceed two and one-tenth (2.1) lbs/MMBtu.

(C) As an alternative to the emission limitations in clause (B), sulfur dioxide emissions from Boilers 11, 12, 13, 14, 15, and 16 may comply with any one (1) of the sets of emission limitations in lbs/MMBtu as follows:

| Boiler Number            | Emission Limitations |
|--------------------------|----------------------|
| (i) 13, 14, 15, and 16   | 0.0                  |
| 11 and 12                | 4.4                  |
| (ii) 11, 12, 15, and 16  | 0.0                  |
| 13 and 14                | 4.4                  |
| (iii) 11, 12, 13, and 14 | 0.0                  |
| 15 and 16                | 4.4                  |
| (iv) 11, 12, 15, and 16  | 3.0                  |
| 13 and 14                | 0.3                  |
| (v) 11 and 12            | 0.3                  |
| 13, 14, 15, and 16       | 3.0                  |

(D) Citizens Thermal shall notify the department prior to the use by Citizens Thermal of any one (1) of the sets of alternative emission limitations specified in clause (C).

(E) A log of hourly operating status for each boiler shall be maintained and made available to the department upon request.

(F) A daily summary indicating which boilers were in service during the day shall be submitted to the department quarterly. In addition, records of the daily average sulfur content, heat content, and sulfur dioxide emission rate for each day in which an alternative set of emission limitations specified in clause (C) is used shall be submitted to the department quarterly.

(G) For the purposes of 326 IAC 7-2-1(d)(1), during thirty (30) day periods in which Citizens Thermal relies on more than one (1) set of emission limitations specified in clauses (B) and (C), a separate thirty (30) day rolling weighted average for each set of limitations shall be determined. Each thirty (30) day rolling weighted average shall be based on data from the previous thirty (30) operational days within the last ninety (90) days for that set of limitations. If Citizens Thermal does not operate thirty (30) days under any one (1) set of limitations within the last ninety (90) days, the rolling weighted average shall be based on all operational days within the last ninety (90) days for that set of limitations.

(6) Indianapolis Power & Light Company Harding Street Generating Station, Source ID No. 00033, shall comply with the sulfur dioxide emission limitations in lbs/MMBtu and other requirements as follows:

| Boiler/Turbine Number                         | Emission Limitations |
|-----------------------------------------------|----------------------|
| (A) Boiler 70                                 | 5.3                  |
| (B) Boilers 50 and 60                         | 4.7                  |
| Boilers 1 through 8                           | 0.0                  |
| Boilers 9 and 10 and Gas Turbines 1, 2, and 3 | 0.35                 |

(C) As an alternative to the emission limitations in clause (B), sulfur dioxide emissions from Boilers 50, 60, and 1 through 10 and Gas Turbines 1, 2, and 3 may comply with any one (1) of the sets of emission limitations in lbs/MMBtu as follows:

| Boiler/Turbine Number                             | Emission Limitations |
|---------------------------------------------------|----------------------|
| (i) Boilers 50 and 60                             | 5.2                  |
| Boilers 1 through 10 and Gas Turbines 1, 2, and 3 | 0.0                  |
| (ii) Boilers 50 and 60                            | 5.0                  |
| Boilers 1 through 10                              | 0.0                  |

## SULFUR DIOXIDE RULES

|       |                                               |      |
|-------|-----------------------------------------------|------|
|       | Gas Turbines 1, 2, and 3                      | 0.4  |
| (iii) | Boilers 50 and 60                             | 4.1  |
|       | Boilers 1 through 8                           | 0.26 |
|       | Boilers 9 and 10                              | 0.35 |
|       | Gas Turbines 1, 2, and 3                      | 0.3  |
| (iv)  | Boilers 50 and 60                             | 3.9  |
|       | Boilers 1 through 8                           | 0.34 |
|       | Boilers 9 and 10 and Gas Turbines 1, 2, and 3 | 0.35 |

(D) Indianapolis Power & Light Company shall notify the department prior to the use by Indianapolis Power & Light Company of any one (1) of the sets of alternative emission limitations specified in clause (C).

(E) A log of hourly operating status for each boiler shall be maintained and made available to the department upon request.

(F) A daily summary indicating which boilers were in service during the day shall be submitted to the department quarterly. In addition, records of the daily average sulfur content, heat content, and sulfur dioxide emission rate for each day in which an alternative set of emission limitations specified in clause (C) is used shall be submitted to the department quarterly.

(G) For the purposes of 326 IAC 7-2-1(d)(1), during thirty (30) day periods in which Indianapolis Power & Light Company relies on more than one (1) set of emission limitations specified in clauses (B) and (C), a separate thirty (30) day rolling weighted average for each set of limitations shall be determined. Each thirty (30) day rolling weighted average shall be based on data from the previous thirty (30) operational days within the last ninety (90) days for that set of limitations. If Indianapolis Power & Light Company does not operate thirty (30) days under any one (1) set of limitations within the last ninety (90) days, the rolling weighted average shall be based on all operational days within the last ninety (90) days for that set of limitations.

(H) Indianapolis Power & Light Company shall install and maintain a stack diameter restriction for the stack serving Boilers 50 and 60. The stack diameter restriction shall reduce the diameter to six and one-half (6 1/2) feet at the tip of the stack.

*(Air Pollution Control Division; 326 IAC 7-4-2; filed Aug 28, 1990, 4:50 p.m.: 14 IR 65; filed Feb 9, 1999, 4:22 p.m.: 22 IR 1959; readopted filed Jan 10, 2001, 3:20 p.m.: 24 IR 1477; filed Feb 20, 2007, 3:15 p.m.: 20070321-IR-326050118FRA; filed Sep 2, 2015, 1:50 p.m.: 20150930-IR-326110356FRA)*

### 326 IAC 7-4-2 Marion County sulfur dioxide emission limitations (Repealed) Version b

*NOTE: This version of section effective January 1, 2017. See also preceding version of section, effective until January 1, 2017.*

*Sec. 2. (Repealed by Air Pollution Control Division; filed Sep 2, 2015, 1:50 p.m.: 20150930-IR-326110356FRA, eff Jan 1, 2017)*

### 326 IAC 7-4-2.1 Marion County sulfur dioxide emission limitations

Authority: IC 13-14-8; IC 13-17-3

Affected: IC 13-15; IC 13-17

Sec. 2.1. (a) On and after January 1, 2017, sources and emission units located in Marion County shall comply with the sulfur dioxide emission limit and other requirements, as follows:

| Source                                                | Emission Unit Description | Emission Limit (lbs/hour) or<br>Other Requirements | Emission Limit<br>(lbs/MMBtu) |
|-------------------------------------------------------|---------------------------|----------------------------------------------------|-------------------------------|
| (1) Citizens Thermal - Perry K<br>Source ID No. 00034 | (A) Boiler 11             | 73.6                                               | 0.2                           |
|                                                       | (B) Boiler 13             | 80.6                                               | 0.2                           |
|                                                       | (C) Boiler 14             | 80.6                                               | 0.2                           |

---

SULFUR DIOXIDE RULES

---

|                                                                         |                                                                |                                                                                           |        |
|-------------------------------------------------------------------------|----------------------------------------------------------------|-------------------------------------------------------------------------------------------|--------|
|                                                                         | (D) Boilers 12, 15, and 16                                     | Burn natural gas                                                                          |        |
|                                                                         | (E) Boiler 17                                                  | 72.6                                                                                      | 0.3    |
|                                                                         | (F) Boiler 18                                                  | 72.6                                                                                      | 0.3    |
| (2) Belmont Advanced Wastewater Treatment Plant Source ID No. 00032     | Incinerator 1, Incinerator 2, Incinerator 3, and Incinerator 4 | Comply with SO <sub>2</sub> limit in 40 CFR 60, Subpart Mmmm* or 40 CFR 60, Subpart LLLL* |        |
| (3) Rolls-Royce Source ID No. 00311                                     | (A) Boiler 0070-58                                             | 0.07                                                                                      | 0.0015 |
|                                                                         | (B) Boiler 0070-59                                             | 0.07                                                                                      | 0.0015 |
|                                                                         | (C) Boiler 0070-62                                             | 0.37                                                                                      | 0.0015 |
|                                                                         | (D) Boiler 0070-63                                             | 0.37                                                                                      | 0.0015 |
|                                                                         | (E) Boilers 0070-64                                            | Burn natural gas or landfill gas                                                          | 0.01   |
|                                                                         | (F) Boiler 0070-65                                             | Burn natural gas or landfill gas                                                          | 0.01   |
|                                                                         | (G) Generating Turbine 0070-80                                 | Burn natural gas or landfill gas                                                          | 0.01   |
|                                                                         | (H) 2 Gas Turbine Engines 0070-66                              |                                                                                           | 0.1    |
|                                                                         | (I) 12 Gas Turbine Engines 0070-67                             |                                                                                           | 0.05   |
|                                                                         | (J) 3 Gas Turbine Engines 0070-68c, 0070-68d, and 0070-68e     |                                                                                           | 0.05   |
|                                                                         | (K) 2 Gas Turbine Engines 0070-68a and 0070-68b                | Burn natural gas                                                                          |        |
|                                                                         | (L) 3 Gas Turbine Engines 0070-69                              |                                                                                           | 0.05   |
|                                                                         | (M) Three Shack Heaters 0070-70                                | Burn natural gas                                                                          |        |
|                                                                         | (N) Rental Generators                                          |                                                                                           | 0.0015 |
|                                                                         | (O) Engine Test Cells Plant 5                                  |                                                                                           | 0.05   |
|                                                                         | (P) Engine Test Cell Plant 8                                   |                                                                                           | 0.1    |
|                                                                         | (Q) Engine Test Cell N20                                       | 18 foot vertical stack, if operating                                                      |        |
|                                                                         | (R) Engine Test Cell N21                                       | 20 foot vertical stack, if operating                                                      |        |
|                                                                         | (S) Engine Test Cell N23                                       | 30 foot vertical stack, if operating                                                      |        |
|                                                                         | (T) Engine Test Cell N24                                       | 20 foot vertical stack, if operating                                                      |        |
| (4) Vertellus Agriculture and Nutrition Specialties Source ID No. 00315 | (A) 70K Boiler 70-2722W                                        | 18.4                                                                                      | 0.20   |
|                                                                         | (B) 30K Boiler 30-2726S                                        | 9.8                                                                                       | 0.25   |
|                                                                         | (C) 28K Boiler 28-186N                                         | 9.9                                                                                       | 0.27   |
|                                                                         | (D) Boiler CB-70K                                              | Burn natural gas                                                                          |        |
|                                                                         | (E) BM Furnace BM2724W                                         | 1.1                                                                                       | 0.05   |
|                                                                         | (F) Box Furnace BX2707V                                        | 0.8                                                                                       | 0.05   |
|                                                                         | (G) DAB Furnace 732714                                         | 2.8                                                                                       | 0.05   |
|                                                                         | (H) Born Heater 722804                                         | 0.34                                                                                      | 0.05   |
|                                                                         | (I) Born Heater Furnace BXS2706Q                               | 0.3                                                                                       | 0.05   |

## SULFUR DIOXIDE RULES

|                                                                                            |                                                      |                                        |      |
|--------------------------------------------------------------------------------------------|------------------------------------------------------|----------------------------------------|------|
|                                                                                            | (J) EP Furnace EP2729Q                               | 0.15                                   | 0.05 |
|                                                                                            | (K) CB20 CB600-300 Boiler                            | 2.3                                    | 0.09 |
|                                                                                            | (L) 50K CN5-400 Boiler                               | 5.5                                    | 0.09 |
|                                                                                            | (M) BD Furnace BD2714V                               | 0.75                                   | 0.05 |
|                                                                                            | (N) Heater BS2740Q                                   | 0.3                                    | 0.05 |
|                                                                                            | (O) Heater BT2728S                                   | 0.3                                    | 0.05 |
|                                                                                            | (P) Furnace HW-925.001                               | 12.25                                  | 1.25 |
|                                                                                            | (Q) CS Kettle Born Heater                            | Burn natural gas                       |      |
|                                                                                            | (R) CS Still Born Heater                             | Burn natural gas                       |      |
|                                                                                            | (S) Born Hot Oil Furnace (Process Heater) Unit 2607T | Burn natural gas                       |      |
| (5) Quemetco Source ID No. 00079                                                           | WESP Stack                                           | 52.0                                   |      |
| (6) Indianapolis Power & Light Co. - Harding Street Generating Station Source ID No. 00033 | (A) Boiler 9                                         | Do not operate                         |      |
|                                                                                            | (B) Boiler 10                                        | Do not operate                         |      |
|                                                                                            | (C) Boiler 50                                        | Burn natural gas                       |      |
|                                                                                            | (D) Boiler 60                                        | Burn natural gas                       |      |
|                                                                                            | (E) Boiler 70                                        | Burn natural gas                       |      |
|                                                                                            | (F) Gas Turbine 1                                    | 29.9                                   | 0.1  |
|                                                                                            | (G) Gas Turbine 2                                    | 29.9                                   | 0.1  |
|                                                                                            | (H) Gas Turbine 4                                    | 87.5                                   | 0.1  |
|                                                                                            | (I) Gas Turbine 5                                    | 86.7                                   | 0.1  |
|                                                                                            | (J) Gas Turbine 6                                    | Burn natural gas                       |      |
|                                                                                            | (K) Emergency Generator                              | 500 hour calendar year operating limit |      |

(b) Compliance with the emission limit in subsection (a)(5) shall be determined by using quality assured hourly average continuous emission monitoring system data.

\*These documents are incorporated by reference. Copies may be obtained from the Government Printing Office, 732 North Capitol Street NW, Washington, D.C. 20401 or are available for review and copying at the Indiana Department of Environmental Management, Office of Legal Counsel, Indiana Government Center North, Thirteenth Floor, 100 North Senate Avenue, Indianapolis, Indiana 46204. (*Air Pollution Control Division; 326 IAC 7-4-2.1; filed Sep 2, 2015, 1:50 p.m.: 20150930-IR-326110356FRA*)

### 326 IAC 7-4-3 Vigo County sulfur dioxide emission limitations before January 1, 2017 Version a

Authority: IC 13-14-8; IC 13-17-3-4

Affected: IC 13-12; IC 13-14-4-3; IC 13-16-1

*NOTE: This version of section effective until January 1, 2017. See also following version of section, effective January 1, 2017.*

Sec. 3. Before January 1, 2017, sources and emission units located in Vigo County shall comply with the sulfur dioxide emission limitations in pounds per million Btu, unless otherwise specified, and other requirements, as follows:

| Source                                          | Emission Unit Description      | Emission Limitations |
|-------------------------------------------------|--------------------------------|----------------------|
| (1) SONY Digital Audio Disc Source ID No. 00032 | (A) #1 Kewanee Boiler          | 0.36                 |
|                                                 | (B) #2 Kewanee Boiler          | 0.36                 |
| (2) Taghleef Industries Source ID No. 00045     | (A) Murray Iron Works Boiler A | 0.51                 |
|                                                 | (B) Murray Iron Works Boiler B | 0.51                 |

---

SULFUR DIOXIDE RULES

---

|                                                                                                                                                                                                                                                        |                              |      |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------|------|
|                                                                                                                                                                                                                                                        | (C) Clayton Boiler (Standby) | 0.51 |
|                                                                                                                                                                                                                                                        | (D) Nebraska Boiler          | 0.51 |
| (3) Duke Energy Wabash River Source ID No. 00021                                                                                                                                                                                                       | Boilers 2, 3, 4, 5, and 6    | 4.04 |
| (4) Terre Haute Regional Hospital Source ID No. 00046                                                                                                                                                                                                  | (A) #1 Boiler                | 0.45 |
|                                                                                                                                                                                                                                                        | (B) (New) #2 Boiler          | 0.45 |
| (5) Union Hospital Source ID No. 00047                                                                                                                                                                                                                 | 2 Keeler Boilers             | 0.36 |
| <i>(Air Pollution Control Division; 326 IAC 7-4-3; filed Aug 28, 1990, 4:50 p.m.: 14 IR 70; readopted filed Jan 10, 2001, 3:20 p.m.: 24 IR 1477; filed Aug 31, 2004, 2:30 p.m.: 28 IR 117; filed Sep 2, 2015, 1:50 p.m.: 20150930-IR-326110356FRA)</i> |                              |      |

**326 IAC 7-4-3 Vigo County sulfur dioxide emission limitations (Repealed) Version b**

*NOTE: This version of section effective January 1, 2017. See also preceding version of section, effective until January 1, 2017.*

*Sec. 3. (Repealed by Air Pollution Control Division; filed Sep 2, 2015, 1:50 p.m.: 20150930-IR-326110356FRA, eff Jan 1, 2017)*

**326 IAC 7-4-3.1 Vigo County sulfur dioxide emission limitations**

Authority: IC 13-14-8; IC 13-17-3

Affected: IC 13-15; IC 13-17

Sec. 3.1. (a) On and after January 1, 2017, sources and emission units located in Vigo County shall comply with the sulfur dioxide emission limits and other requirements, as follows:

| Source                                                | Emission Unit Description                                                                                                                                                                  | Emission Limit (lbs/hour)<br>or Other Requirements                   | Emission Limit<br>(lbs/MMBtu)                        |
|-------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------|------------------------------------------------------|
| (1) Wabash River Combined Cycle Source ID No. 00147   | Combustion Turbine Unit 1A                                                                                                                                                                 | 333.76                                                               | 0.195                                                |
| (2) sgSolutions Source ID No. 00091                   | (A) Tail Gas Incinerator Stack EP1<br>(B) Process Flare Unit 2                                                                                                                             | 230.6<br>500 hour calendar year<br>operating limit on<br>coal/syngas |                                                      |
| (3) SONY Digital Audio Disc Source ID No. 00032       | (A) #1 Kewanee Boiler<br>(B) #2 Kewanee Boiler<br>(C) Unit 3 Burnham Boiler<br>(D) Unit 4 Burnham Boiler<br>(E) Unit 5 Superior Boiler<br>(F) Unit 6 Superior Boiler<br>(G) Unit 18 Boiler |                                                                      | 0.05<br>0.05<br>0.05<br>0.05<br>0.05<br>0.05<br>0.05 |
| (4) Taghleef Industries Source ID No. 00045           | (A) Clayton Boiler (Standby)<br>(B) Nebraska Boiler<br>(C) Nebraska-D Boiler                                                                                                               | 0.03<br>0.05<br>Burn natural gas                                     | 0.0015<br>0.0015                                     |
| (5) Terre Haute Regional Hospital Source ID No. 00046 | (A) #1 Boiler<br>(B) New #2 Boiler                                                                                                                                                         |                                                                      | 0.45<br>0.45                                         |
| (6) Union Hospital Source ID No. 00047                | 2 Keeler Boilers                                                                                                                                                                           |                                                                      | 0.36                                                 |

## SULFUR DIOXIDE RULES

|                                                                          |                                                      |                                                             |             |
|--------------------------------------------------------------------------|------------------------------------------------------|-------------------------------------------------------------|-------------|
| (7) Duke Energy - Wabash River Generating Station<br>Source ID No. 00021 | (A) Boiler 6<br>(B) Diesel Generators 7A, 7B, and 7C | 1,499.5<br>500 hour calendar year<br>operating limit (each) | 0.5<br>0.05 |
|--------------------------------------------------------------------------|------------------------------------------------------|-------------------------------------------------------------|-------------|

(b) Compliance with the emission limit in subsection (a)(1) shall be determined by using quality assured hourly average continuous emission monitoring system data.

(c) Compliance with the emission limit in subsection (a)(2)(A) shall be determined by calculating the thirty (30) unit operating day rolling arithmetic average emission rate at the end of each unit operating day using all of the quality assured hourly average continuous emission monitoring system data for the previous thirty (30) unit operating days. Unit operating day means a twenty-four (24) hour period that begins at midnight and ends the following midnight during which the unit is operated. It is not necessary for the unit to be operating the entire twenty-four (24) hour period. (*Air Pollution Control Division; 326 IAC 7-4-3.1; filed Sep 2, 2015, 1:50 p.m.: 20150930-IR-326110356FRA*)

### 326 IAC 7-4-4 Wayne County sulfur dioxide emission limitations

Authority: IC 13-1-1-4; IC 13-7-7

Affected: IC 13-1-1; IC 13-7

Sec. 4. The following sources and facilities located in Wayne County shall comply with the sulfur dioxide emission limitations in pounds per million Btu, unless otherwise specified, and other requirements:

| Source                                                                                                                                                                                                                                                                                         | Facility Description                    | Emission Limitations |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------|----------------------|
| (1) Belden Corp.                                                                                                                                                                                                                                                                               | Boilers 3,4,5,6 (oil) (common stack)    | 1.6                  |
| (2) Earlham College                                                                                                                                                                                                                                                                            | Boilers 1 & 2 (oil/gas) (common stack)  | 1.6                  |
| (3) Johns-Manville Co.                                                                                                                                                                                                                                                                         | Boiler B-2 (oil/gas)                    | 1.6                  |
|                                                                                                                                                                                                                                                                                                | Glass Furnaces SX-2,SX-3 (common stack) | 9 pounds per ton     |
| (4) Joseph Hill (Plant A)                                                                                                                                                                                                                                                                      | Boilers 1,2,4 (oil) (common stack)      | 1.6                  |
|                                                                                                                                                                                                                                                                                                | Boiler 3 (oil)                          | 1.6                  |
| (5) Joseph Hill (Plant B)                                                                                                                                                                                                                                                                      | Boilers 1,2,3 (oil/gas) (common stack)  | 0.3                  |
| (6) Kemper                                                                                                                                                                                                                                                                                     | Boiler 1 (coal)                         | 2.3                  |
|                                                                                                                                                                                                                                                                                                | Boiler 2 (wood/coal)                    | 2.1                  |
|                                                                                                                                                                                                                                                                                                | Boiler 3 (wood/sawdust)                 | 1.2                  |
| Kemper Boilers 1 and 2 also shall be limited to one and three-tenths (1.3) pounds per million Btu, and Boiler 3 also shall be limited to one and two-tenths (1.2) pounds per million Btu based on the annual average sulfur content of the fuel over any twelve (12) consecutive month period. |                                         |                      |
| (7) NATCO                                                                                                                                                                                                                                                                                      | Boiler 1 (coal)                         | 4.9                  |
| NATCO Boiler 1 also shall be limited to three and seven-tenths (3.7) pounds per million Btu based on the annual average sulfur content of the fuel over any twelve (12) consecutive month period.                                                                                              |                                         |                      |
| (8) Ralston Purina Co.                                                                                                                                                                                                                                                                         | Boilers 1 & 2 (oil/gas) common stack    | 1.6                  |
| (9) Richmond Power and Light (RP&L)                                                                                                                                                                                                                                                            | Boilers 1 and 2 (coal) (common stack)   | 6.0                  |
| RP&L shall construct a new good engineering practice stack with height of at least three hundred twenty-five (325) feet above grade by July 31, 1988.                                                                                                                                          |                                         |                      |
| (10) Richmond State Hospital                                                                                                                                                                                                                                                                   | Boilers 1,2,3,4 (coal) (common stack)   | 6.0                  |
| (11) Sanyo E&E                                                                                                                                                                                                                                                                                 | Boiler 1 (coal)                         | 4.9                  |
|                                                                                                                                                                                                                                                                                                | Boiler 2 (coal)                         | 4.9                  |
| Sanyo E&E Boilers 1 and 2 also shall be limited to three and nine-tenths (3.9) pounds per million Btu based on the annual average sulfur content of the fuel over any twelve (12) consecutive month period.                                                                                    |                                         |                      |
| (12) Wallace Metals                                                                                                                                                                                                                                                                            | Boiler 1 (oil/gas)                      | 1.6                  |

(*Air Pollution Control Division; 326 IAC 7-4-4; filed Aug 28, 1990, 4:50 p.m.: 14 IR 73; readopted filed Jan 10, 2001, 3:20 p.m.: 24 IR 1477*)

---

SULFUR DIOXIDE RULES

---

**326 IAC 7-4-5 LaPorte County sulfur dioxide emission limitations**

Authority: IC 13-1-1-4; IC 13-7-7

Affected: IC 13-1-1; IC 13-7

Sec. 5. The following sources and facilities located in LaPorte County shall comply with the sulfur dioxide emission limitations in pounds per million Btu and other requirements:

| Source                                                                   | Facility Description                                    | Emission Limitations |
|--------------------------------------------------------------------------|---------------------------------------------------------|----------------------|
| (1) Indiana State Prison                                                 | 3 Coal Boilers                                          | 5.12                 |
|                                                                          | 1 Oil Boiler                                            | 1.60                 |
| (2) Westville Correctional Center                                        | 3 Coal Boilers                                          | 6.00                 |
| (3) Allis Chalmers                                                       | 3 Oil Boilers                                           | 1.60                 |
| (4) Northern Indiana Public Service Company (NIPSCO) Michigan City Plant | Unit 12                                                 | 6.0                  |
|                                                                          | Units 4, 5, and 6: If only one (1) unit is in operation | 2.2                  |
|                                                                          | If two (2) units are in operation                       | 1.11 each            |
|                                                                          | If three (3) units are in operation                     | 0.74 each            |

(A) A log of hourly operating status for Units 4, 5, and 6 shall be maintained and made available to the department upon request. A summary indicating which boilers were in service each day of a calendar quarter shall be submitted to the department on a quarterly basis. In addition, records of the daily average sulfur content and sulfur dioxide emission rate for each day in which more than one (1) of Units 4, 5, and 6 were in operation shall be submitted to the department quarterly.

(B) For the purposes of 326 IAC 7-2-1(c)(1), during thirty (30) day periods in which NIPSCO relies on more than one (1) set of limits contained in this subdivision, a separate thirty (30) day rolling weighted average for each set of limits shall be determined. Each thirty (30) day rolling weighted average shall be based on data from the previous thirty (30) operational days within the last ninety (90) days for that set of limits. If NIPSCO does not operate thirty (30) days under any one (1) set of limits within the last ninety (90) days, the rolling weighted average shall be based on all operational days within the last ninety (90) days for that set of limits.

(C) For periods when natural gas is the only fuel being burned in Units 4, 5, or 6, the reporting required in clauses (A) and (B) shall be satisfied by indicating that natural gas was the only fuel burned. No reporting of sulfur dioxide emission rates is necessary for these periods.

*(Air Pollution Control Division; 326 IAC 7-4-5; filed Aug 28, 1990, 4:50 p.m.: 14 IR 73; readopted filed Jan 10, 2001, 3:20 p.m.: 24 IR 1477)*

**326 IAC 7-4-6 Jefferson County sulfur dioxide emission limitations**

Authority: IC 13-1-1-4; IC 13-7-7

Affected: IC 13-1-1; IC 13-7

Sec. 6. The following sources and facilities located in Jefferson County shall comply with the sulfur dioxide emission limitations in pounds per million Btu:

| Source                     | Facility Description | Emission Limitations |
|----------------------------|----------------------|----------------------|
| (1) IKEC—Clifty Creek      | Boilers 1, 2, and 3  | 7.52                 |
|                            | Boilers 4, 5, and 6  | 7.52                 |
| (2) Madison State Hospital | Boilers 1, 2, and 3  | 6.0                  |

*(Air Pollution Control Division; 326 IAC 7-4-6; filed Aug 28, 1990, 4:50 p.m.: 14 IR 74; readopted filed Jan 10, 2001, 3:20 p.m.: 24 IR 1477)*

---

SULFUR DIOXIDE RULES

---

**326 IAC 7-4-7 Sullivan County sulfur dioxide emission limitations**

Authority: IC 13-1-1-4; IC 13-7-7

Affected: IC 13-1-1; IC 13-7

Sec. 7. The following sources and facilities located in Sullivan County shall comply with the sulfur dioxide emission limitations in pounds per million Btu:

| Source                   | Facility Description | Emission Limitations |
|--------------------------|----------------------|----------------------|
| (1) IMEC-Breed           | Boiler               | 9.57                 |
| (2) Hoosier Energy-Merom | Boiler 1             | 1.2                  |
|                          | Boiler 2             | 1.2                  |

Boiler 1 and Boiler 2 are subject to new source performance standards in the applicable construction permit.

(Air Pollution Control Division; 326 IAC 7-4-7; filed Aug 28, 1990, 4:50 p.m.: 14 IR 74; readopted filed Jan 10, 2001, 3:20 p.m.: 24 IR 1477)

**326 IAC 7-4-8 Vermillion County sulfur dioxide emission limitations**

Authority: IC 13-1-1-4; IC 13-7-7

Affected: IC 13-1-1; IC 13-7

Sec. 8. The following sources and facilities located in Vermillion County shall comply with the sulfur dioxide emission limitations in pounds per million Btu and other requirements:

| Source                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                          | Facility Description                  | Emission Limitations |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------|----------------------|
| (1) Public Service Indiana Cayuga (PSI)                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                         | Boiler 1 and Boiler 2:                | 4.84 each            |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                 | On or before December 31, 1988        |                      |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                 | On or before March 1, 1989            | 4.40 each            |
| (A) Upon certification by PSI to the commissioner that the Universal Mine cannot assure a long term supply of compliance coal, final compliance with the four and forty-hundredths (4.40) pounds per million Btu sulfur dioxide emission limitation may be extended until December 31, 1989. The commissioner shall notify the U.S. EPA upon receipt of such a certification by PSI.                                                                                                                                                                            |                                       |                      |
| (B) PSI may at any time petition the commissioner for a four and forty-eight hundredths (4.48) pounds per million Btu final sulfur dioxide emission limitation. The petition shall include evidence that such a limitation will protect the sulfur dioxide ambient air quality standards on all land not fenced or otherwise effectively restricted from public access. If the commissioner approves such a petition, the department shall amend the operation permit according to procedures specified in 326 IAC 2 and submit the revised permit to U.S. EPA. |                                       |                      |
| (2) Newport Army Ammunition                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                     | Boilers 103A, 103B, 103C, and 7700D   | 1.6 each             |
| (3) Eli Lilly Clinton Laboratories                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                              | Boiler C31-1                          | 4.72                 |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                 | Boiler C21-4, C21-1, C21-2, and C21-3 | 0.36 each            |

(Air Pollution Control Division; 326 IAC 7-4-8; filed Aug 28, 1990, 4:50 p.m.: 14 IR 74; readopted filed Jan 10, 2001, 3:20 p.m.: 24 IR 1477)

**326 IAC 7-4-9 Floyd County sulfur dioxide emission limitations**

Authority: IC 13-1-1-4; IC 13-7-7

Affected: IC 13-1-1; IC 13-7

Sec. 9. Sulfur dioxide emissions from the Public Service Indiana (PSI) Gallagher Plant Units 1, 2, 3, and 4 shall be limited to four and seven-tenths (4.7) pounds per million Btu each. (Air Pollution Control Division; 326 IAC 7-4-9; filed Aug 28, 1990, 4:50 p.m.: 14 IR 74; readopted filed Jan 10, 2001, 3:20 p.m.: 24 IR 1477)

---

SULFUR DIOXIDE RULES

---

**326 IAC 7-4-10 Warrick County sulfur dioxide emission limitations**

Authority: IC 13-14-8; IC 13-17-3

Affected: IC 13-15; IC 13-17; IC 13-22

Sec. 10. (a) The following sources and facilities located in Warrick County shall comply with the sulfur dioxide emission limitations in pounds per million Btu, unless otherwise specified, and other requirements:

(1) Southern Indiana Gas and Electric Company (SIGECO)

| Facility Description                                                                                                                                                                 | Emission Limitations |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------|
| (A) Culley Units 1, 2, and 3                                                                                                                                                         |                      |
| Beginning December 31, 1989                                                                                                                                                          | 5.41 each            |
| Beginning August 1, 1991 (Units 1 and 2 only)                                                                                                                                        | 2.79 each            |
| (B) As an alternative to the emission limitations specified in clause (A), beginning August 1, 1991, sulfur dioxide emissions from Culley Units 1 and 2 shall be limited as follows: |                      |

| Facility Description | Emission Limitations |
|----------------------|----------------------|
| Unit 1               | 0.0006               |
| Unit 2               | 4.40                 |

(C) SIGECO shall notify the department and the U.S. EPA via certified mail at least fourteen (14) days prior to its intention to rely on the set of limits in clause (B) or to switch between sets of limits listed in clauses (A) and (B).

(D) For the purposes of 326 IAC 7-2-1(e)(1), during thirty (30) day periods in which SIGECO relies on more than one (1) set of limits contained in clauses (A) and (B), a separate thirty (30) day rolling weighted average for each set of limits shall be determined. Each thirty (30) day rolling weighted average shall be based on data from the previous thirty (30) operational days within the last ninety (90) days for that set of limits. If SIGECO does not operate thirty (30) days under any one (1) set of limits within the last ninety (90) days, the rolling weighted average shall be based on all operational days within the last ninety (90) days for that set of limits.

(E) Units 2 and 3 shall maintain a thirty (30) day rolling average sulfur dioxide (SO<sub>2</sub>) removal efficiency of at least ninety-five percent (95%) using continuous emissions monitoring system (CEMS) data from both the inlet and outlet of the control device determined in accordance with 40 CFR 75\*. A thirty (30) day rolling average sulfur dioxide (SO<sub>2</sub>) removal efficiency means the percent reduction in the mass of a pollutant achieved by a unit's pollution control device over a thirty (30) day period using the thirty (30) day rolling average emission rate. A thirty (30) day rolling average emission rate shall be determined by calculating an arithmetic average of all hourly emission rates in lb/MMBtu for the current day and the previous twenty-nine (29) operating days. A new thirty (30) day rolling average emission rate shall be calculated for each new operating day. Each thirty (30) day rolling average emission rate shall include all startup, shutdown, and malfunction periods within an operating day.

(F) SIGECO shall continuously operate the flue gas desulfurization system (FGD) serving Units 2 and 3 at all times the units are in operation. Following startup of the units, SIGECO need not operate the FGD until either unit is fired with any coal. In the event of a planned FGD outage, SIGECO may continue to operate Unit 2, but shall burn down the coal existing in the Unit 2 bunker to the extent practicable, and, prior to shutting down the FGD, load compliance coal into the bunker for use until such time as the FGD resumes operation. In the event of an unplanned FGD outage, SIGECO shall feed compliance coal to the Unit 2 bunker until such time as the FGD resumes operation. Compliance coal is defined as two (2.0) lb/MMBtu SO<sub>2</sub>, as demonstrated by a four (4) hour composite sample of the feed stock.

(2) Aluminum Company of America (ALCOA) Warrick Power Plant

| Facility Description | Emission Limitations |
|----------------------|----------------------|
| Units 1, 2, 3, and 4 | 5.11 each            |

Unit 4 is jointly owned by ALCOA and SIGECO.

(3) ALCOA-Warrick Smelter Operations shall comply with the sulfur dioxide emission limitations in pounds per hour, unless otherwise specified, and other requirements as follows:

| Facility Description | Emission Limitations |
|----------------------|----------------------|
| (A) Potline 1:       |                      |

---

## SULFUR DIOXIDE RULES

---

|                                              |                           |
|----------------------------------------------|---------------------------|
| All stacks associated with scrubber          | 176.3                     |
| Roof monitors associated with Potline 1      | 19.6                      |
| (B) Potline 2:                               |                           |
| All stacks associated with scrubber          | 195.2                     |
| Roof monitors associated with Potline 2      | 21.7                      |
| (C) Potline 3:                               |                           |
| All vents or stacks associated with scrubber | 195.2                     |
| Roof monitors associated with Potline 3      | 21.7                      |
| (D) Potline 4:                               |                           |
| All vents associated with scrubber           | 195.2                     |
| Roof monitors associated with Potline 4      | 21.7                      |
| (E) Potline 5:                               |                           |
| All stacks associated with scrubber          | 195.2                     |
| Roof monitors associated with Potline 5      | 21.7                      |
| (F) Potline 6:                               |                           |
| All stacks associated with scrubber          | 195.2                     |
| Roof monitors associated with Potline 6      | 21.7                      |
| (G) Potlines 1, 2, 3, 4, 5, and 6            | 5,608 tons per year total |
| (H) Anode Bake Ring Furnace                  | 94.1                      |
|                                              | (412 tons per year)       |

Any sulfur dioxide emission limitation established in a permit issued in conformance with the prevention of significant deterioration rules under 326 IAC 2-2 or 40 CFR 52\*, if more stringent, shall supersede the requirements in this subdivision.

(b) Compliance with the pounds per hour limitations specified in subsection (a)(4) shall be based on a stack test under 326 IAC 7-2-1(d).

(c) Compliance with the tons per year limitations specified in subsection (a)(4) shall be based on a rolling twelve (12) consecutive month emission total. Monthly sulfur dioxide emissions shall be determined from calendar month material balances using actual average sulfur content and material throughput. Quarterly reports shall be submitted to the department containing the calendar month and rolling twelve (12) month sulfur dioxide emissions from the smelter operations (potline scrubber stacks, roof monitors, and anode bake ring furnace). The report shall:

- (1) include documentation of the data and methodology used to calculate the monthly sulfur dioxide emissions; and
- (2) be submitted by the end of the month following the end of the quarter.

\*These documents are incorporated by reference. Copies may be obtained from the Government Printing Office, 732 North Capitol Street NW, Washington, D.C. 20401 or are available for review and copying at the Indiana Department of Environmental Management, Office of Air Quality, Indiana Government Center-North, Tenth Floor, 100 North Senate Avenue, Indianapolis, Indiana 46204. (*Air Pollution Control Division; 326 IAC 7-4-10; filed Aug 28, 1990, 4:50 p.m.: 14 IR 75; readopted filed Jan 10, 2001, 3:20 p.m.: 24 IR 1477; errata filed Dec 12, 2002, 3:35 p.m.: 26 IR 1568; filed Aug 26, 2004, 11:30 a.m.: 28 IR 43; filed Jul 31, 2008, 4:00 p.m.: 20080827-IR-326070309FRA*)

### **326 IAC 7-4-11 Morgan County sulfur dioxide emission limitations before January 1, 2017 Version a**

Authority: IC 13-14-8; IC 13-17-3

Affected: IC 13-15; IC 13-17

*NOTE: This version of section effective until January 1, 2017. See also following version of section, effective January 1, 2017.*

Sec. 11. Before January 1, 2017, Indianapolis Power & Light Company (IPL) Eagle Valley Generating Station, Source ID No. 00004, shall comply with the sulfur dioxide emission limitations in pounds per million Btu and other requirements as follows:

## SULFUR DIOXIDE RULES

| Emission Unit Description | Emission Limitations |
|---------------------------|----------------------|
| (1) Units 1 and 2         | 0.37 each            |
| (2) Unit 3                | 0.37                 |
| (3) Units 4, 5, and 6     | 3.04 each            |

(4) As an exception to the emission limitations specified in subdivisions (2) and (3), after September 30, 1990, at any time in which IPL burns coal on Unit 3, sulfur dioxide emissions from Units 3, 4, 5, and 6 shall be limited to two and fifty-seven hundredths (2.57) pounds per million Btu each.

(5) The two (2) stacks serving Units 3, 4, 5, and 6 shall be at least two hundred and eighty-one (281) feet above grade.

(6) After September 30, 1990, on a day for which Unit 3 does not burn any coal, the limitations in subdivisions (2) and (3) are in effect, and compliance shall be determined as specified in 326 IAC 7-2-1(d).

(7) After September 30, 1990, on a day for which Unit 3 burns any coal, the limitations in subdivision (4) are in effect. As an exception to the requirements of 326 IAC 7-2-1(d)(1) on a day for which Unit 3 burns any coal, if the thirty (30) day rolling weighted average for any unit is above two and fifty-seven hundredths (2.57) pounds per million Btu, then 326 IAC 7-2-1(d)(1) does not apply, and the daily average emission rate for that unit for that day shall not exceed two and fifty-seven hundredths (2.57) pounds per million Btu.

(8) After September 30, 1990, for the purposes of determining compliance under 326 IAC 7-2-1(h)(1), stack tests performed on Units 3, 4, 5, and 6 shall demonstrate compliance with the most stringent set of limits in effect at any time during the day prior to or during the test based on the Unit 3 operating status and fuel type as indicated by the log maintained pursuant to subdivision (9).

(9) After September 30, 1990, IPL shall maintain and make available to the department upon request a log of the operating status and fuel type used for Unit 3. In addition, in the quarterly report required by 326 IAC 7-2-1(c), IPL shall submit to the department a daily summary indicating fuel type for Unit 3, and, for days on which Unit 3 burned any coal and any thirty (30) day rolling weighted average was greater than two and fifty-seven hundredths (2.57) pounds per million Btu, IPL shall submit to the department the daily average sulfur content, heat content, and sulfur dioxide emission rate for Units 3, 4, 5, and 6.

*(Air Pollution Control Division; 326 IAC 7-4-11; filed Aug 28, 1990, 4:50 p.m.: 14 IR 76; readopted filed Jan 10, 2001, 3:20 p.m.: 24 IR 1477; filed Sep 2, 2015, 1:50 p.m.: 20150930-IR-326110356FRA)*

### **326 IAC 7-4-11 Morgan County sulfur dioxide emission limitations (Repealed) Version b**

*NOTE: This version of section effective January 1, 2017. See also preceding version of section, effective until January 1, 2017.*

*Sec. 11. (Repealed by Air Pollution Control Division; filed Sep 2, 2015, 1:50 p.m.: 20150930-IR-326110356FRA, eff Jan 1, 2017)*

### **326 IAC 7-4-11.1 Morgan County sulfur dioxide emission limitations**

Authority: IC 13-14-8; IC 13-17-3

Affected: IC 13-15; IC 13-17

Sec. 11.1. (a) On and after January 1, 2017, sources and emission units located in Morgan County shall comply with the sulfur dioxide emission limits and other requirements, as follows:

| Source                                                                                                | Emission Unit Description                                      | Emission Limit or Other Requirements | Emission Limit (lbs/MMBtu) |
|-------------------------------------------------------------------------------------------------------|----------------------------------------------------------------|--------------------------------------|----------------------------|
| (1) Indianapolis Power & Light Company (IPL) - Eagle Valley Generating Station<br>Source ID No. 00004 | (A) Combined Cycle Combustion Turbine 1 including duct burners | Burn natural gas                     |                            |
|                                                                                                       | (B) Combined Cycle Combustion Turbine 2 including duct burners | Burn natural gas                     |                            |
|                                                                                                       | (C) Auxiliary Boiler                                           | Burn natural gas                     |                            |

## SULFUR DIOXIDE RULES

|                                                             |                      |                                                                                 |     |
|-------------------------------------------------------------|----------------------|---------------------------------------------------------------------------------|-----|
| (2) Hydraulic Press Brick Company (HPB) Source ID No. 00007 | (D) Dew Point Heater | Burn natural gas                                                                |     |
|                                                             | (A) Kiln 3           | Do not operate                                                                  |     |
|                                                             | (B) Kiln 4           | Minimum control efficiency of 50% or 2.5 lbs/MMBtu, whichever is less stringent | 6.0 |
|                                                             | (C) Kiln 5           | Minimum control efficiency of 50% or 2.5 lbs/MMBtu, whichever is less stringent | 6.0 |

(b) HPB shall comply with the sulfur dioxide emission limits in subsection (a)(2) as follows:

- (1) The emission limit applies to sulfur dioxide emissions from both the combustion of coal and the processing of shale.
- (2) Monthly fuel sampling and analysis data shall be collected according to 326 IAC 7-2-1 for both coal and shale.
- (3) HPB shall install and operate a limestone injection system to control sulfur dioxide emissions from Kiln 4 and Kiln 5.
- (4) Compliance with the control efficiency limit in subsection (a)(2) shall be based on measured sulfur content in the shale and fuel compared to the outlet SO<sub>2</sub> concentration determined by a stack test pursuant to 326 IAC 3-6. The shale and fuel sulfur content measurements for this purpose shall reflect a representative sample of the material fed into the kiln during each run of the stack test.

*(Air Pollution Control Division; 326 IAC 7-4-11.1; filed Sep 2, 2015, 1:50 p.m.: 20150930-IR-326110356FRA)*

### 326 IAC 7-4-12 Gibson County sulfur dioxide emission limitations (Repealed)

Sec. 12. *(Repealed by Air Pollution Control Division; filed Nov 5, 1990, 11:53 a.m.: 14 IR 439)*

### 326 IAC 7-4-12.1 Gibson County sulfur dioxide emission limitations

Authority: IC 13-1-1-4; IC 13-7-7

Affected: IC 13-1-1; IC 13-7

Sec. 12.1. (a) Prior to January 1, 1992, Public Service Indiana (PSI) Gibson Units 1, 2, 3, 4, and 5 shall comply with the sulfur dioxide emission limitations in pounds per million Btu (lbs./MMBtu) and other requirements as follows:

| <u>Facility Description</u>                            | <u>Emission Limitations</u> |
|--------------------------------------------------------|-----------------------------|
| Units 1, 2, 3, and 4                                   | 5.1                         |
| Unit 5                                                 |                             |
| New source performance standard pursuant to 326 IAC 12 | 1.2                         |
| Twenty-four (24) hour average                          | 1.10                        |

(b) Beginning January 1, 1992, Public Service Indiana (PSI) Gibson Units 1, 2, 3, 4, and 5 shall comply with the sulfur dioxide emission limitations in pounds per million Btu (lbs./MMBtu) and other requirements as provided under either subdivision (1) or (2) as follows:

| (1) | <u>Facility Description</u>     | <u>Emission Limitations</u> |
|-----|---------------------------------|-----------------------------|
|     | Units 1, 2, 3, and 4            |                             |
|     | Beginning January 1, 1992       | 3.57                        |
|     | No later than December 31, 1993 | 3.13                        |
|     | No later than December 31, 1995 | 2.7                         |
|     | Unit 5                          |                             |

---

SULFUR DIOXIDE RULES

---

|     |                                                        |                             |
|-----|--------------------------------------------------------|-----------------------------|
|     | Beginning January 1, 1992                              |                             |
|     | New source performance standard pursuant to 326 IAC 12 | 1.2                         |
|     | Twenty-four (24) hour average                          | 1.10                        |
|     | No later than December 31, 1995                        | 1.10                        |
| (2) | <u>Facility Description</u>                            | <u>Emission Limitations</u> |
|     | Units 1, 2, and 3                                      |                             |
|     | Beginning January 1, 1992                              | 3.57                        |
|     | No later than December 31, 1993                        | 3.13                        |
|     | No later than December 31, 1995                        | 3.19                        |
|     | Unit 4                                                 |                             |
|     | Beginning January 1, 1992                              | 3.57                        |
|     | No later than December 31, 1993                        | 3.13                        |
|     | No later than December 31, 1995                        | 0.60                        |

In order to achieve compliance with the sixty-hundredths (0.60) pounds per million Btu emission limitation for Unit 4, PSI shall install and operate a flue gas desulfurization (FGD) system on Unit 4 as follows:

- (A) Select architectural engineer for design of FGD system by July 1, 1992.
- (B) Award contract for construction of FGD system and begin construction by July 1, 1993.
- (C) Complete construction of FGD system by July 1, 1995.
- (D) Begin operation of FGD system by December 31, 1995.

Unit 5

|                                                        |      |
|--------------------------------------------------------|------|
| Beginning January 1, 1992                              |      |
| New source performance standard pursuant to 326 IAC 12 | 1.2  |
| Twenty-four (24) hour average                          | 1.10 |
| No later than December 31, 1995                        | 1.10 |

PSI shall indicate in a certified letter to the commissioner whether it intends to comply with the emission limitations and other requirements under either subdivision (1) or (2) by December 31, 1991.

- (c) Notwithstanding PSI's decision to comply as provided under either subsection (b)(1) or (b)(2), PSI shall:
  - (1) secure contracts by July 1, 1991, for the purchase of low-sulfur coal sufficient to attain and maintain compliance with the applicable emission limitations contained in subsection (b)(1) or (b)(2);
  - (2) complete test coal burns and engineering studies by July 1, 1994, to determine the need for particulate control upgrades in order to meet the applicable emission limitations;
  - (3) complete particulate control upgrades, as necessary, by December 31, 1995;
  - (4) establish procedures and complete equipment installation, as appropriate, for coal blending on Units 1, 2, 3, and 4:
    - (A) by September 30, 1991, in order to meet the interim emission limitation of three and fifty-seven hundredths (3.57) pounds per million Btu by December 31, 1991; and
    - (B) by September 30, 1993, in order to meet the interim emission limitation of three and thirteen-hundredths (3.13) pounds per million Btu by December 31, 1993;

---

SULFUR DIOXIDE RULES

---

(5) turn over existing coal stockpile to eliminate higher sulfur coal by December 31, 1991; and

(6) construct or utilize effective physical barriers, prior to December 31, 1991, to restrict public access to areas of the PSI Gibson property for which modeled violations were predicted based on the emission limitation of three and fifty-seven hundredths (3.57) pounds per million Btu.

*(Air Pollution Control Division; 326 IAC 7-4-12.1; filed Nov 5, 1990, 11:53 a.m.: 14 IR 438; readopted filed Jan 10, 2001, 3:20 p.m.: 24 IR 1477)*

**326 IAC 7-4-13 Dearborn County sulfur dioxide emission limitations**

Authority: IC 13-14-8; IC 13-17-3-4; IC 13-17-3-11; IC 13-17-3-12

Affected: IC 13-15; IC 13-17

Sec. 13. The following sources and facilities located in Dearborn County shall comply with the sulfur dioxide emission limitations in pounds per million Btu and other requirements:

|     | <u>Source</u>                                                                       | <u>Facility Description</u>         | <u>Emission Limitations</u> |
|-----|-------------------------------------------------------------------------------------|-------------------------------------|-----------------------------|
| (1) | Indiana Michigan Power Tanners Creek Station, Source Identification No. 00002       | (A) Units 1, 2, and 3<br>(B) Unit 4 | 1.2 each<br>5.24            |
| (2) | Pernod Ricard USA, Seagram Lawrenceburg Distillery, Source Identification No. 00005 | Steam Boiler EU-96                  | 1.92                        |
| (3) | Anchor Glass Container Corporation, Source Identification No. 00007                 | Furnaces 1 and 2                    | 1.4 each                    |

*(Air Pollution Control Division; 326 IAC 7-4-13; filed Aug 28, 1990, 4:50 p.m.: 14 IR 77; filed Apr 18, 1995, 3:00 p.m.: 18 IR 2220; readopted filed Jan 10, 2001, 3:20 p.m.: 24 IR 1477; filed Feb 14, 2005, 11:05 a.m.: 28 IR 2021)*

**326 IAC 7-4-14 Porter County sulfur dioxide emission limitations**

Authority: IC 13-14-8; IC 13-17

Affected: IC 13-15

Sec. 14. The following sources and facilities located in Porter County shall comply with the sulfur dioxide emission limitations in pounds per million Btu (lbs/MMBtu) and pounds per hour (lbs/hr), unless otherwise specified, and other requirements:

(1) ArcelorMittal Burns Harbor LLC shall comply with the following:

(A) The following facilities shall burn natural gas only:

(i) BOF Shop FM Boiler.

(ii) 160 inch Plate Mill Continuous Hardening and Annealing Heat Treatment Furnace.

(iii) 160 inch Plate Mill Boilers No. 2 and 4.

(iv) Batch Annealing Furnaces (24).

(v) Continuous Heat Treat Line – Preheat, Heating and Soaking, and Reheat.

(B) The following facilities shall comply with the sulfur dioxide emission limitations and other requirements:

| Facility Description              | Emission Limitations               |        |
|-----------------------------------|------------------------------------|--------|
|                                   | lbs/MMBtu                          | lbs/hr |
| (i) Blast Furnace C Stoves        | 0.83                               | 545    |
| (ii) Blast Furnace D Stoves       | 0.83                               | 545    |
| (iii) Sinter Plant Windbox        | 1.0 pound per ton process material | 400    |
| (iv) No. 1 Coke Battery Underfire | 1.73                               | 803    |
| (v) No. 2 Coke Battery Underfire  | 1.96                               | 911    |

## SULFUR DIOXIDE RULES

(vi) Slab Mill Soaking Pits:

(AA) Not more than nine (9) of thirty-two (32) horizontally discharged soaking pits may be fired on coke oven gas at the same time with total sulfur dioxide emissions not to exceed four hundred eighty-two (482) pounds per hour.

(BB) The remaining twenty-three (23) of thirty-two (32) horizontally discharged soaking pits may burn blast furnace or natural gas, or both, with total sulfur dioxide emissions not to exceed twenty-four (24) pounds per hour.

(CC) The four (4) vertically discharged soaking pits may burn blast furnace or natural gas, or both, with total sulfur dioxide emissions not to exceed four (4) pounds per hour.

|                                                                             |      |         |
|-----------------------------------------------------------------------------|------|---------|
| (vii) 160 inch Plate Mill Continuous Reheat Furnace No. 1 and Boiler No. 1  | 1.96 | 299     |
| (viii) 160 inch Plate Mill Continuous Reheat Furnace No. 2 and Boiler No. 3 | 1.96 | 299     |
| (ix) 80 inch Hot Strip Mill Furnace No. 1, 2, and 3                         | 1.96 | 79 each |
| (x) 110 inch Plate Mill Furnaces No. 1 and 2                                | 1.96 | 441     |
| (xi) 110 inch Plate Mill Normalizing Furnace                                | 1.07 | 88      |
| (xii) 160 inch Plate Mill I & O Furnaces No. 4 and 5                        | 1.96 | 274     |
| (xiii) 160 inch Plate Mill I & O Furnaces No. 6 and 7                       | 1.96 | 274     |
| (xiv) 160 inch Plate Mill I & O Furnace No. 8                               | 1.96 | 176     |
| (xv) Power Station Boiler No. 7                                             | 0.8  | 520     |
| (xvi) Power Station Boilers No. 8, 9, 10, 11, and 12                        | 1.45 | 2,798   |

(C) As an alternative to the sulfur dioxide emission limitations specified in clause (B), ArcelorMittal Burns Harbor LLC shall comply with the sulfur dioxide emission limitations and other requirements as follows:

| Facility Description                                                                                                                                                                                                              | Emission Limitations               |          |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------|----------|
|                                                                                                                                                                                                                                   | lbs/MMBtu                          | lbs/hr   |
| (i) Blast Furnace C Stoves                                                                                                                                                                                                        | 0.75                               | 498      |
| (ii) Blast Furnace D Stoves                                                                                                                                                                                                       | 0.75                               | 498      |
| (iii) Sinter Plant Windbox                                                                                                                                                                                                        | 1.0 pound per ton process material | 400      |
| (iv) No. 1 Coke Battery Underfire                                                                                                                                                                                                 | 1.57                               | 730      |
| (v) No. 2 Coke Battery Underfire                                                                                                                                                                                                  | 1.78                               | 828      |
| (vi) Slab Mill Soaking Pits:                                                                                                                                                                                                      |                                    |          |
| (AA) Not more than six (6) of thirty-two (32) horizontally discharged soaking pits may be fired on coke oven gas at the same time with total sulfur dioxide emissions not to exceed two hundred ninety-two (292) pounds per hour. |                                    |          |
| (BB) The remaining twenty-six (26) of thirty-two (32) horizontally discharged soaking pits may burn blast furnace or natural gas, or both, with total sulfur dioxide emissions not to exceed twenty-seven (27) pounds per hour.   |                                    |          |
| (CC) The four (4) vertically discharged soaking pits may burn blast furnace or natural gas, or both, with total sulfur dioxide emissions not to exceed four (4) pounds per hour.                                                  |                                    |          |
| (vii) 160 inch Plate Mill Continuous Reheat Furnace No. 1 and Boiler No. 1                                                                                                                                                        | 1.78                               | 293      |
| (viii) 160 inch Plate Mill Continuous Reheat Furnace No. 2 and Boiler No. 3                                                                                                                                                       | 1.78                               | 293      |
| (ix) 80 inch Hot Strip Mill Furnace No. 1, 2, and 3                                                                                                                                                                               | 1.78                               | 483 each |
| (x) 110 inch Plate Mill Furnaces No. 1 and 2                                                                                                                                                                                      | 1.78                               | 401      |
| (xi) 110 inch Plate Mill Normalizing Furnace                                                                                                                                                                                      | 1.07                               | 88       |
| (xii) 160 inch Plate Mill I & O Furnaces No. 4 and 5                                                                                                                                                                              | 1.78                               | 249      |

---

SULFUR DIOXIDE RULES

---

If 160 inch Plate Mill I & O Furnaces No. 6 or 7, or both, are in operation on a fuel other than natural gas, Furnaces No. 4 and 5 shall not operate or shall burn natural gas only.

|                                                       |      |     |
|-------------------------------------------------------|------|-----|
| (xiii) 160 inch Plate Mill I & O Furnaces No. 6 and 7 | 1.78 | 249 |
|-------------------------------------------------------|------|-----|

If 160 inch Plate Mill I & O Furnaces No. 4 or 5, or both, are in operation on a fuel other than natural gas, Furnaces No. 6 and 7 shall not operate or shall burn natural gas only.

|                                               |      |     |
|-----------------------------------------------|------|-----|
| (xiv) 160 inch Plate Mill I & O Furnace No. 8 | 1.78 | 160 |
|-----------------------------------------------|------|-----|

|                                  |     |     |
|----------------------------------|-----|-----|
| (xv) Power Station Boilers No. 7 | 0.8 | 520 |
|----------------------------------|-----|-----|

|                                                      |            |             |
|------------------------------------------------------|------------|-------------|
| (xvi) Power Station Boilers No. 8, 9, 10, 11, and 12 | 1.45 total | 2,500 total |
|------------------------------------------------------|------------|-------------|

(xvii) ArcelorMittal Burns Harbor LLC shall notify the department at least twenty-four (24) hours prior to reliance on the alternative set of limits specified in items (i) through (xvi). ArcelorMittal Burns Harbor LLC shall maintain records of fuel type and operational status of facilities listed in items (xii) and (xiii) and shall make the records available to the department upon request.

(xviii) For the purposes of 326 IAC 7-2-1(c)(2), compliance shall be determined based on separate calendar month averages for the set of requirements specified in this clause and for the set of requirements specified in clause (B).

(D) Coke oven gas usage at facilities other than the No. 1 and 2 Coke Battery Underfire Stacks shall be restricted to not more than seventy-five (75) million cubic feet per day. Total sulfur dioxide emissions from the facilities listed in clause (B)(i) through (B)(iii), (B)(vi)(AA) through (B)(vi)(BB), (B)(vii) through (B)(x), and (B)(xii) through (B)(xvi) shall not exceed four thousand four hundred twenty-nine (4,429) pounds per hour. During periods in which the limits contained in clause (C) are in effect, coke oven gas usage at facilities other than the No. 1 and 2 Coke Battery Underfire Stacks shall be restricted to not more than seventy (70) million cubic feet per day, and total sulfur dioxide emissions from the facilities listed in clause (C)(i) through (C)(iii), (C)(vi)(AA) through (C)(vi)(BB), (C)(vii) through (C)(x), and (C)(xii) through (C)(xvi) shall not exceed four thousand six hundred thirty (4,630) pounds per hour.

(E) ArcelorMittal Burns Harbor LLC shall achieve compliance with the requirements specified in clause (B) or (C) prior to December 31, 1988. Thereafter, ArcelorMittal Burns Harbor LLC shall submit a report to the department within thirty (30) days following the end of each calendar quarter containing the following information:

(i) Records of the total coke oven gas, blast furnace gas, fuel oil, and natural gas usage for each day at each facility listed in clauses (B) and (C).

(ii) Records of the:

(AA) average sulfur content and heating value as determined per the procedures specified in clause (F) for each fuel type used during the calendar quarter; and

(BB) maximum number of slab mill soaking pits burning coke oven gas at any given time during each day.

(iii) The calculated sulfur dioxide emission rate in the applicable emission units (pounds per hour, pounds per million Btu, or pounds per ton) for each facility for each day and the average sulfur dioxide emissions from the facilities listed in clause (C)(i) through (C)(iii), (C)(vi)(AA) through (C)(vi)(BB), (C)(vii) through (C)(x), and (C)(xii) through (C)(xvi) for each day in pounds per hour during the calendar quarter.

(F) ArcelorMittal Burns Harbor LLC shall submit a sampling and analysis protocol to the department by December 31, 1988. The protocol shall:

(i) contain a description of planned procedures for:

(AA) sampling of sulfur-bearing fuels and materials;

(BB) analysis of the sulfur content; and

(CC) any planned direct measurement of sulfur dioxide emissions vented to the atmosphere; and

(ii) specify the frequency of sampling, analysis, and measurement for each:

(AA) fuel and material; and

(BB) facility.

The department shall incorporate the protocol into the source's operation permit per procedures specified in 326 IAC 2. The department may revise the protocol as necessary to establish acceptable sampling, analysis, and measurements procedures and frequency. The department may also require that a source conduct a stack test at any facility listed in

## SULFUR DIOXIDE RULES

this subdivision within thirty (30) days of written notification by the department.

(2) Northern Indiana Public Service Company Bailly Station shall comply with the following:

| Facility Description                                                | Emission Limitations<br>lbs/MMBtu |
|---------------------------------------------------------------------|-----------------------------------|
| (A) Boilers 7 and 8                                                 | 6.0 each                          |
| Boilers 7 and 8 shall be fired with coal, fuel oil, or natural gas. |                                   |
| (B) Gas Turbine 10                                                  | natural gas only                  |

(3) Midwest Steel shall comply with the following:

| Facility Description                                              | Emission Limitations<br>lbs/MMBtu |
|-------------------------------------------------------------------|-----------------------------------|
| Babcock and Wilcox Boiler 1 and Erie City Boilers No. 1, 2, and 3 | 1.33 each                         |

Only two (2) of four (4) boilers may burn fuel oil with a sulfur dioxide emission rate greater than three-tenths (0.3) pounds per million Btu at the same time. Midwest Steel shall maintain records of fuel type for each boiler for each hour. The records of fuel type shall be made available to the department upon request.

(4) Air Products and Chemical shall comply with the following:

| Facility Description                        | Emission Limitations |
|---------------------------------------------|----------------------|
| All boilers and the No. 3 Hydrogen Reformer | natural gas only     |

*(Air Pollution Control Division; 326 IAC 7-4-14; filed Aug 28, 1990, 4:50 p.m.: 14 IR 78; readopted filed Jan 10, 2001, 3:20 p.m.: 24 IR 1477; errata filed Dec 12, 2002, 3:35 p.m.: 26 IR 1568; filed Sep 29, 2009, 3:00 p.m.: 20091028-IR-326070088FRA)*

### 326 IAC 7-4-15 Pike County sulfur dioxide emission limitations

Authority: IC 13-14-8; IC 13-17-3

Affected: IC 13-15; IC 13-17

Sec. 15. (a) On and after January 1, 2017, sources and emission units located in Pike County shall comply with the sulfur dioxide emission limits and other requirements, as follows:

| Source                                                                                | Emission Unit Description                  | Emission Limit (lbs/hour)<br>or Other Requirements | Emission Limit<br>(lbs/MMBtu) |
|---------------------------------------------------------------------------------------|--------------------------------------------|----------------------------------------------------|-------------------------------|
| (1) Indianapolis Power & Light - Petersburg Generating Station<br>Source ID No. 00002 | (A) Unit 1                                 | 330.0                                              | 0.15                          |
|                                                                                       | (B) Unit 2                                 | 621.6                                              | 0.15                          |
|                                                                                       | (C) Unit 3                                 | 2,049.8                                            | 0.37                          |
|                                                                                       | (D) Unit 4                                 | 1,942.5                                            | 0.35                          |
|                                                                                       | (E) Diesel Generators PB-2, PB-3, and PB-4 | 500 hour calendar year operating limit (each)      |                               |
| (2) Hoosier Energy - Ratts<br>Source ID No. 00001                                     | (A) Boiler 1                               | 58                                                 | 0.05                          |
|                                                                                       | (B) Boiler 2                               | 58                                                 | 0.05                          |
|                                                                                       | (C) No. 2 Auxiliary Boiler                 | 1                                                  | 0.05                          |

(b) Compliance with the emission limits in subsection (a) shall be determined by using quality assured hourly average continuous emission monitoring system data, except as allowed under subsection (c).

(c) As an alternative to the emission limits in subsection (a)(1)(A) through (a)(1)(D), Indianapolis Power & Light - Petersburg Generating Station may comply with the following:

| Emission Unit Description | Emission Limit (lbs/hour - 30 day<br>rolling average) | Emission Limit (lbs/MMBtu - 30 day<br>rolling average) |
|---------------------------|-------------------------------------------------------|--------------------------------------------------------|
| (1) Unit 1                | 263.0                                                 | 0.12                                                   |
| (2) Unit 2                | 495.4                                                 | 0.12                                                   |
| (3) Unit 3                | 1,633.7                                               | 0.29                                                   |

(4) Unit 4 1,548.2 0.28

(d) Compliance with the emission limits in subsection (c) shall be determined by calculating the thirty (30) boiler operating day rolling arithmetic average emission rate at the end of each boiler operating day using all of the quality assured hourly average continuous emission monitoring system data for the previous thirty (30) boiler operating days. Boiler operating day means a twenty-four (24) hour period that begins at midnight and ends the following midnight during which any fuel is combusted at any time in the boiler. It is not necessary for the fuel to be combusted the entire twenty-four (24) hour period.

(e) Indianapolis Power & Light shall notify the department prior to the compliance date to indicate if compliance for Units 1 through 4 will be determined using the emission limits in subsection (a) or subsection (c) and prior to switching from compliance with the set of emission limits in subsection (a) to subsection (c) or from subsection (c) to subsection (a). Indianapolis Power & Light may not switch between complying with the one (1) hour average limits in subsection (a) and the thirty (30) day rolling average limits in subsection (c) unless Indianapolis Power & Light continues to show compliance with the one (1) hour average limit for each boiler until the first thirty (30) boiler operating day rolling arithmetic average emission rate is calculated. (*Air Pollution Control Division; 326 IAC 7-4-15; filed Sep 2, 2015, 1:50 p.m.: 20150930-IR-326110356FRA*)

## **Rule 4.1. Lake County Sulfur Dioxide Emission Limitations**

### **326 IAC 7-4.1-1 Lake County sulfur dioxide emission limitations**

Authority: IC 13-14-8; IC 13-17-3-4; IC 13-17-3-11

Affected: IC 13-15; IC 13-17

Sec. 1. All new and existing fossil fuel-fired combustion sources and emissions units subject to 326 IAC 7-1.1 located in Lake County shall burn natural gas only unless an alternate sulfur dioxide emission limit is provided in this rule. An emissions unit subject to 326 IAC 7-1.1, but not located at a source specifically listed in this rule, may burn distillate oil with sulfur dioxide emissions limited to three-tenths (0.3) pound per million British thermal units (MMBtu) if the fuel combustion unit has a maximum capacity of less than twenty (20) MMBtu per hour actual heat input. (*Air Pollution Control Division; 326 IAC 7-4.1-1; filed May 25, 2005, 10:50 a.m.: 28 IR 2954*)

### **326 IAC 7-4.1-2 Sampling and analysis protocol**

Authority: IC 13-14-8; IC 13-17-3-4; IC 13-17-3-11

Affected: IC 13-15; IC 13-17

Sec. 2. (a) BP Products North America Inc., Cargill, Inc., Carmeuse Lime, Cokenergy, Inc., Indiana Harbor Coke Company, ISG Indiana Harbor Inc., Ispat Inland Inc., Safety-Kleen Oil Recovery Company, U.S. Steel-Gary Works, and Walsh and Kelly shall submit a sampling and analysis protocol to the department by July 1, 2006.

(b) The protocol shall:

(1) contain a description of planned procedures for:

(A) sampling of sulfur-bearing fuels and materials;

(B) analysis of the sulfur content; and

(C) any planned direct measurement of sulfur dioxide emissions vented to the atmosphere; and

(2) specify the frequency of sampling, analysis, and measurement for each fuel and material and for each emissions unit.

(c) The department shall incorporate the protocol into the source's Title V or other appropriate permit per procedures specified in 326 IAC 2. The protocol may be revised as necessary with approval by the department.

(d) The department may also require that a source listed in this section conduct a stack test at any emissions unit within sixty (60) days of written notification by the department. (*Air Pollution Control Division; 326 IAC 7-4.1-2; filed May 25, 2005, 10:50 a.m.: 28 IR 2954*)

### **326 IAC 7-4.1-3 BP Products North America Inc. sulfur dioxide emission limitations**

Authority: IC 13-14-8; IC 13-17-3-4; IC 13-17-3-11

Affected: IC 13-15; IC 13-17

## SULFUR DIOXIDE RULES

Sec. 3. (a) BP Products North America Inc., Source Identification Number 00003, shall comply with the sulfur dioxide emission limits in pounds per million British thermal units (MMBtu), pounds per hour, and other requirements as follows:

| Emissions Unit Description                           | Emission Limit lbs/MMBtu | Emission Limit lbs/hour    |
|------------------------------------------------------|--------------------------|----------------------------|
| (1) No. 1 Power Station Boilers 3, 4, 5, 6, and 7:   |                          |                            |
| (A) Boilers 3 and 4                                  | 0.033 each               | 17.49 total                |
| (B) Boilers 5, 6, and 7                              | 0.033 each               | 26.24 total                |
| (2) No. 3 Power Station Boilers 1, 2, 3, 4, and 6    | 0.033 each               | 18.98 each                 |
| (3) No. 11 Pipe Still:                               |                          |                            |
| (A) H-1X Heater                                      | 0.033                    | 8.25                       |
| (B) H-2 Vacuum Heater                                | 0.033                    | 1.49                       |
| (C) H-3 Vacuum Heater                                | 0.033                    | 1.82                       |
| (D) H-101, 102, 103, and 104 Coker Preheaters        | 0.033 each               | 6.60 total                 |
| (E) H-200 Crude Charge                               | 0.033                    | 8.23                       |
| (F) H-300 Furnace                                    | 0.033                    | 5.94                       |
| (4) No. 12 Pipe Still:                               |                          |                            |
| (A) H-1A, H-1B Preheaters, and H-2 Vacuum Heater     | 0.033 each               | 21.78 total                |
| (B) H-1CN and H-1CS Crude Preheaters                 | 0.033 each               | 7.92 total                 |
| (C) H-1CX                                            | 0.033                    | 13.53                      |
| (5) No. 2 Isomerization H-1 Feed Heater Furnace      | 0.034                    | 6.46                       |
| (6) No. 3 Ultraformer:                               |                          |                            |
| (A) H-1 Feed Heater Furnace                          | 0.033                    | 7.92                       |
| (B) H-2 Feed Heater Furnace                          | 0.034                    | 6.29                       |
| (C) F-7 Furnace                                      | 0.035                    | 0.81                       |
| (7) No. 4 Ultraformer:                               |                          |                            |
| (A) F-1 Ultraformer Furnace, F-8A and F-8B Reboilers | 0.033 each               | 13.00 total                |
| (B) F-2 Preheat Furnace                              | 0.033                    | 9.44                       |
| (C) F-3 No. 1 Reheat Furnace                         | 0.033                    | 7.99                       |
| (D) F-4, F-5, and F-6 Reheat Furnaces                | 0.033 each               | 9.41 total                 |
| (E) F-7 Furnace                                      | 0.033                    | 1.72                       |
| (8) Aromatic Recovery Unit F-200A and F-200B Furnace | 0.035 each               | 17.47 total                |
| (9) Blending Oil Desulfurization Furnace F-401       | 0.034                    | 1.19                       |
| (10) Catalytic Refining Unit:                        |                          |                            |
| (A) F-101 Feed Preheater                             | 0.04                     | 2.88                       |
| (B) F-102a Stripper Reboiler                         | 0.04                     | 2.40                       |
| (11) FCU 500                                         |                          | 750.00                     |
| (12) FCU 600                                         |                          | 437.50                     |
| (13) Wastewater Sludge Fluid Bed Incinerator         |                          | 1.78                       |
| (14) Catalytic Feed Hydrotreating Unit:              |                          |                            |
| (A) F-801 A/B Preheater Furnace                      | 0.035                    | 2.33                       |
| (B) F-801 C Preheater Furnace                        | 0.035                    | 2.1                        |
| (15) Beavon-Stretford Tail Gas Unit                  |                          | 53.10 total reduced sulfur |
| (16) Sodium Bisulfite Tail Gas Unit                  |                          | 9.0                        |
| (17) Sulfur Recovery Unit Incinerator                | 0.033                    | 1.25                       |
| (18) F-1 Asphalt Heater                              | 0.033                    | 0.43                       |

---

SULFUR DIOXIDE RULES

---

|                                                                |            |            |
|----------------------------------------------------------------|------------|------------|
| (19) F-2 Steiglitz Park Residual Heater                        | 0.033      | 0.90       |
| (20) Distillate Desulfurization Unit Heaters WB-301 and WB-302 | 0.033 each | 4.24 total |
| (21) Hydrogen Unit B-1                                         | 0.033      | 12.09      |

(b) BP Products North America Inc. shall:

(1) maintain daily records of:

(A) fuel type, average sulfur content, and average fuel gravity for each emissions unit specified in this section with sulfur dioxide emission limitations less than or equal to four-hundredths (0.04) pound per MMBtu;

(B) calculated coke burn and sulfur content of the coke for the FCU 500 and FCU 600;

(C) total reduced sulfur concentration, hydrogen sulfide concentration, and calculated stack gas flow rate for the Beavon-Stretford Tail Gas Unit; and

(D) sulfur dioxide concentration and stack gas flow rate for the Sodium Bisulfite Tail Gas Unit; and

(2) submit a report to the department within thirty (30) days after the end of each calendar quarter containing the average daily sulfur dioxide emission rate in pounds per hour sulfur dioxide for the emissions units specified in this section, except for the Beavon-Stretford Tail Gas Unit, that is to be reported as pounds per hour total reduced sulfur calculated as sulfur dioxide.

*(Air Pollution Control Division; 326 IAC 7-4.1-3; filed May 25, 2005, 10:50 a.m.: 28 IR 2955)*

**326 IAC 7-4.1-4 Bucko Construction sulfur dioxide emission limitations**

Authority: IC 13-14-8; IC 13-17-3-4; IC 13-17-3-11

Affected: IC 13-15; IC 13-17

Sec. 4. Bucko Construction, Source Identification Number 00179, shall comply with the sulfur dioxide emission limits for the Rotary Dryer of four-hundredths (0.04) pound per ton asphalt and ten (10) pounds per hour. *(Air Pollution Control Division; 326 IAC 7-4.1-4; filed May 25, 2005, 10:50 a.m.: 28 IR 2956)*

**326 IAC 7-4.1-5 Cargill, Inc. sulfur dioxide emission limitations**

Authority: IC 13-14-8; IC 13-17-3-4; IC 13-17-3-11

Affected: IC 13-15; IC 13-17

Sec. 5. (a) Cargill, Inc., Source Identification Number 00203, shall comply with the sulfur dioxide emission limits as follows:

| <u>Emissions Unit Description</u>    | <u>Emissions Unit Identification</u> | <u>Emission Limit lbs/hour</u> |
|--------------------------------------|--------------------------------------|--------------------------------|
| (1) Gluten Dryer System              | 121-01-G                             | 0.68                           |
| (2) Fiber Dryer and Drying Equipment | 89-01-G                              | 3.95                           |
| (3) Germ Dryer                       | 124-A-01                             | 0.77                           |
| (4) Carbon Regen Furnace             | 104-01-R                             | 0.11                           |
| (5) Biogas Flare                     | 800-04-E                             | 9.13                           |

(b) Cargill, Inc. shall submit a quarterly report of the twelve (12) month rolling total of all sulfur dioxide emissions in tons per year. *(Air Pollution Control Division; 326 IAC 7-4.1-5; filed May 25, 2005, 10:50 a.m.: 28 IR 2956; filed Oct 20, 2010, 9:02 a.m.: 20101117-IR-326090476FRA)*

**326 IAC 7-4.1-6 Carmeuse Lime sulfur dioxide emission limitations**

Authority: IC 13-14-8; IC 13-17-3-4; IC 13-17-3-11

Affected: IC 13-15; IC 13-17

Sec. 6. (a) Carmeuse Lime, Source Identification Number 00112, shall comply with the sulfur dioxide emission limits for Rotary Kilns 1 through 5 as follows:

(1) When three (3) or fewer kilns are in operation at the same time, the sulfur dioxide emissions are not to exceed:

(A) two and ninety-four thousandths (2.094) pounds per ton of lime based on a one (1) hour average; and

---

## SULFUR DIOXIDE RULES

---

- (B) forty-eight (48) pounds per hour per operating kiln.
- (2) When four (4) kilns are in operation at the same time, the sulfur dioxide emissions are not to exceed:
  - (A) one and seven hundred forty-five thousandths (1.745) pounds per ton of lime based on a one (1) hour average; and
  - (B) forty (40) pounds per hour per operating kiln.
- (3) When five (5) kilns are in operation at the same time, the sulfur dioxide emissions are not to exceed:
  - (A) one and four hundred eighty-three thousandths (1.483) pounds per ton of lime based on a one (1) hour average; and
  - (B) thirty-four (34) pounds per hour per operating kiln.
- (4) The production of lime is not to exceed five hundred fifty (550) tons per day for each rotary kiln.
- (b) Sulfur dioxide emissions shall be vented from the kilns/kiln gas filter systems at the following heights above grade:
  - (1) For Kiln No. 1, a stack height of seventy-nine and one-tenth (79.1) feet.
  - (2) For Kiln No. 2, a stack height of eighty-five and nine-tenths (85.9) feet.
  - (3) For Kiln No. 3, a stack height of eighty-six and zero-tenths (86.0) feet.
  - (4) For Kiln No. 4, a stack height of ninety-four and four-tenths (94.4) feet.
  - (5) For Kiln No. 5, a stack height of eighty-seven and four-tenths (87.4) feet.

(Air Pollution Control Division; 326 IAC 7-4.1-6; filed May 25, 2005, 10:50 a.m.: 28 IR 2956)

### **326 IAC 7-4.1-7 Cokenergy Inc. sulfur dioxide emission limitations**

Authority: IC 13-14-8; IC 13-17-3-4; IC 13-17-3-11

Affected: IC 13-15; IC 13-17

Sec. 7. Cokenergy Inc., Source Identification Number 00383, shall comply with the sulfur dioxide emission limit in pounds per hour for the heat recovery coke carbonization waste gas stack, identified as Stack ID 201, combined with the sixteen (16) vents from the Indiana Harbor Coke Company of a twenty-four (24) hour average emission rate of one thousand six hundred fifty-six (1,656) pounds per hour. (Air Pollution Control Division; 326 IAC 7-4.1-7; filed May 25, 2005, 10:50 a.m.: 28 IR 2957)

### **326 IAC 7-4.1-8 Indiana Harbor Coke Company sulfur dioxide emission limitations**

Authority: IC 13-14-8; IC 13-17-3-4; IC 13-17-3-11

Affected: IC 13-15; IC 13-17

Sec. 8. (a) Indiana Harbor Coke Company (IHCC), Source Identification Number 00382, shall comply with the sulfur dioxide emission limits in pounds per ton, pounds per hour, and other requirements as follows:

| Emissions Unit Description                                                                                                                  | Emission Limit lbs/ton                     | Emission Limit lbs/hour              |
|---------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------|--------------------------------------|
| (1) IHCC Coal Carbonization Charging                                                                                                        | 0.0068 each                                | 1.57 total                           |
| (2) IHCC Coal Carbonization Pushing                                                                                                         | 0.0084                                     | 1.96                                 |
| (3) IHCC Coal Carbonization Quenching                                                                                                       | 0.0053                                     | 1.232 total                          |
| (4) IHCC Coal Carbonization Thaw Shed                                                                                                       | 0.0006 lbs/1,000<br>cubic feet natural gas | 0.015                                |
| (5) IHCC Vent Stacks (16 total) in combination with Cokenergy's heat recovery coke carbonization waste gas stack identified as Stack ID 201 |                                            | 1,656 total for a 24 hour<br>average |

(b) The coke ovens shall recycle the gases emitted during the coking process and utilize it as the only fuel source for the ovens during normal operations. The gases shall not be routed directly to the atmosphere unless they first pass through the common tunnel afterburner. A maximum of nineteen percent (19%) of the coke oven waste gases leaving the common tunnel shall be allowed to be vented to the atmosphere on a twenty-four (24) hour basis and fourteen percent (14%) on an annual basis. (Air Pollution Control Division; 326 IAC 7-4.1-8; filed May 25, 2005, 10:50 a.m.: 28 IR 2957)

### **326 IAC 7-4.1-9 Ironside Energy, LLC sulfur dioxide emission limitations**

Authority: IC 13-14-8; IC 13-17-3-4; IC 13-17-3-11

Affected: IC 13-15; IC 13-17

---

## SULFUR DIOXIDE RULES

---

Sec. 9. (a) Ironside Energy, LLC, Source Identification Number 00448, shall comply with the sulfur dioxide emission limits for Utility Boiler No. 9 of two hundred ninety-thousandths (0.290) pound per million British thermal units (MMBtu) and one hundred ninety and fifty-three hundredths (190.53) pounds per hour. Utility Boiler No. 9 shall be fired on blast furnace gas and natural gas only.

(b) Utility Boiler No. 9 in combination with ISG Indiana Harbor Inc. Utility Boilers 5, 6, 7, and 8 are limited to an annual operating limit of five thousand eight hundred seventy-one and sixty-one hundredths (5,871.61) tons per year.

(c) For Utility Boiler No. 9, Ironside Energy, LLC shall:

(1) maintain records of the:

(A) total blast furnace gas and natural gas combusted for each day; and

(B) average sulfur content and heating value for each day for each fuel type combusted during the calendar quarter; and

(2) submit to the department within thirty (30) days of the end of each calendar quarter the calculated sulfur dioxide emission rate in pounds per MMBtu for each fuel type, the total fuel combusted for each day during the calendar quarter.

*(Air Pollution Control Division; 326 IAC 7-4.1-9; filed May 25, 2005, 10:50 a.m.: 28 IR 2957)*

### **326 IAC 7-4.1-10 ISG Indiana Harbor Inc. sulfur dioxide emission limitations**

Authority: IC 13-14-8; IC 13-17-3-4; IC 13-17-3-11

Affected: IC 13-15; IC 13-17

Sec. 10. (a) ISG Indiana Harbor Inc., Source Identification Number 00318, shall comply with the sulfur dioxide emission limits in pounds per million British thermal units (MMBtu), pounds per hour, and other requirements as follows:

| Emissions Unit Description                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                    | Emission Limit<br>lbs/MMBtu           | Emission Limit<br>lbs/hour |
|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------|----------------------------|
| (1) Utility Boilers 5, 6, 7, and 8:<br>(A) Total actual heat input from fuel oil usage at all boilers combined shall not exceed two thousand four hundred fifty-two (2,452) MMBtu per hour.<br>(B) Boilers shall be fired on fuel oil, blast furnace gas, and natural gas only.<br>(C) Fuel oil burned shall not exceed one and three-tenths percent (1.3%) sulfur and one and thirty-five hundredths (1.35) pounds per MMBtu.<br>(D) Utility Boilers 5, 6, 7, and 8 in combination with the Ironside Energy, LLC Utility Boiler No. 9 are limited to an annual operating limit of five thousand eight hundred seventy-one and sixty-one hundredths (5,871.61) tons per year. | 0.594 each                            | 1456.5 total               |
| (2) Hot Strip Mill Slab Heat Reheat Furnaces 1, 2, and 3                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                      | 1.254 each                            | 535.1 each                 |
| (3) Sinter Plant Windbox                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                      |                                       | 240                        |
| (4) Blast Furnace Stoves:<br>(A) No. 3 Blast Furnace Stove<br>(B) No. 4 Blast Furnace Stove                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                   | 0.290<br>0.290                        | 127.89<br>140.94           |
| (5) Reladling and Desulfurization Baghouse                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                    | 0.057 pounds per<br>ton feed material | 30.40                      |
| (6) Number 4 Blast Furnace EC Baghouse                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        | 0.18 pounds per<br>ton feed material  | 69.9                       |

(b) ISG Indiana Harbor Inc. shall:

(1) maintain records of the:

(A) total coke oven gas, blast furnace gas, fuel oil, and natural gas usage for each day at each emissions unit listed in subsection (a)(1) through (a)(4); and

(B) average sulfur content and heating value for each day for each fuel type used during the calendar quarter; and

(2) submit to the department within thirty (30) days of the end of each calendar quarter the calculated sulfur dioxide emission rate in pounds per MMBtu for each emissions unit for each day during the calendar quarter and the total fuel usage for each

---

SULFUR DIOXIDE RULES

---

type at each emissions unit for each day.

(Air Pollution Control Division; 326 IAC 7-4.1-10; filed May 25, 2005, 10:50 a.m.: 28 IR 2958)

**326 IAC 7-4.1-11 Ispat Inland Inc. sulfur dioxide emission limitations**

Authority: IC 13-14-8; IC 13-17-3-4; IC 13-17-3-11

Affected: IC 13-15; IC 13-17

Sec. 11. (a) Ispat Inland Inc., Source Identification Number 00316, shall comply with the sulfur dioxide emission limits in pounds per million British thermal units (MMBtu), pounds per ton, pounds per hour, and other requirements as follows:

| Emissions Unit Description                                                                                                                                                                                                                                                                                                                                                                                                                                                                                            | Emission Limit<br>lbs/MMBtu | Emission Limit<br>lbs/hour |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------|----------------------------|
| (1) No. 1 Blast Furnace Stoves                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        | 0.080 total                 | 11.92 total                |
| (2) No. 2 Blast Furnace Stoves                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        | 0.080 total                 | 12.4 total                 |
| (3) No. 5 and 6 Blast Furnace Stoves                                                                                                                                                                                                                                                                                                                                                                                                                                                                                  | 0.140 each                  | 41.02 each                 |
| (4) No. 7 Blast Furnace Stoves                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        | 0.195 total                 | 162 total                  |
| (5) No. 5 Boilerhouse                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                 | 0.198                       | 265.2                      |
| (6) No. 2AC Boilers 207, 208, 209, and 210                                                                                                                                                                                                                                                                                                                                                                                                                                                                            |                             | 15.873 total               |
| (7) No. 2AC Boilers 211, 212, and 213                                                                                                                                                                                                                                                                                                                                                                                                                                                                                 | 0.140 each                  | 168.0 total                |
| (8) No. 4AC Boilers 401, 402, 403, 404, and 405:                                                                                                                                                                                                                                                                                                                                                                                                                                                                      |                             | 890.23 total               |
| (A) Stack 1 (Boilers 401 and 402) and Stack 2 (Boilers 403 and 404)                                                                                                                                                                                                                                                                                                                                                                                                                                                   | 1.5 per stack               |                            |
| (B) Stack 3 (Boiler 405)                                                                                                                                                                                                                                                                                                                                                                                                                                                                                              | 1.0                         |                            |
| (C) Sulfur dioxide emissions from Stacks 1, 2, and 3 shall be limited in accordance with the following equation in units of pounds per MMBtu:                                                                                                                                                                                                                                                                                                                                                                         |                             |                            |
| $(\text{Stack 1} + \text{Stack 2})/2 + 0.425 \times \text{Stack 3} \leq 1.6$                                                                                                                                                                                                                                                                                                                                                                                                                                          |                             |                            |
| If any one (1) of Boilers 401 through 405 is not operating for a given calendar day, the pounds per MMBtu for Stack 3 for the purposes of the equation in this clause is twenty-four hundredths (0.24) pounds per MMBtu.                                                                                                                                                                                                                                                                                              |                             |                            |
| (D) Ispat Inland Inc. shall maintain and operate sulfur dioxide continuous emission monitoring systems (CEMS) in Stacks 1, 2, and 3. CEMS data shall be used to determine compliance and to determine the sulfur dioxide emission rate in pounds per MMBtu for the report required under subsection (b)(3) [sic.]. The CEMS shall be operated in accordance with the procedures specified in 326 IAC 3-5, and records of hourly emissions data shall be maintained and made available to the department upon request. |                             |                            |
| (9) Lime Plant Kiln Baghouse Stacks                                                                                                                                                                                                                                                                                                                                                                                                                                                                                   | 0.460                       | 32.08 total                |
| (10) Anneal 3, 4                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                      | 0.000                       | 0.000                      |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       | Emission Limit<br>lbs/ton   | Emission Limit<br>lbs/hour |
| (11) EAF Shop Ladle Metal Baghouse                                                                                                                                                                                                                                                                                                                                                                                                                                                                                    | 0.125                       | 13.90                      |
| (12) Pigging Ladle Facility                                                                                                                                                                                                                                                                                                                                                                                                                                                                                           | 0.020                       | 4.000                      |
| (13) Sinter Plant Windbox                                                                                                                                                                                                                                                                                                                                                                                                                                                                                             |                             | 180.000                    |
| (14) No. 7 Blast Furnace Canopy                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       | 0.220                       | 50.400                     |
| (15) No. 7 BF Casthouse Baghouse                                                                                                                                                                                                                                                                                                                                                                                                                                                                                      | 0.220                       | 50.400                     |
| (16) No. 2 BOF Secondary Vent Stack                                                                                                                                                                                                                                                                                                                                                                                                                                                                                   | 0.014                       | 6.440                      |
| (17) No. 2 BOF Charge Aisle and HMS Baghouse                                                                                                                                                                                                                                                                                                                                                                                                                                                                          | 0.151                       | 69.460                     |
| (18) No. 2 BOF Ladle Metal Baghouse                                                                                                                                                                                                                                                                                                                                                                                                                                                                                   | 0.025                       | 11.500                     |

---

SULFUR DIOXIDE RULES

---

- |                                     |            |             |
|-------------------------------------|------------|-------------|
| (19) No. 4 BOF HMS Baghouse S and N | 0.151 each | 36.391 each |
| (20) No. 4 BOF Secondary Vent Stack | 0.001      | 0.535       |
- (b) Ispat Inland Inc. shall:
- (1) maintain records of the:
- (A) total blast furnace gas, fuel oil, and natural gas usage for each day at each emissions unit listed in this section; and
- (B) average sulfur content and heating value for each day for each fuel type used during the calendar quarter and of the operational status of 2AC Station Boilers 207, 208, 209, 210, 211, 212, and 213, 4AC Station Boilers 401, 402, 403, 404, and 405; and
- (2) submit to the department within thirty (30) days of the end of each calendar quarter the calculated sulfur dioxide emission rate in pounds per million Btu and pounds per hour for each emissions unit for each day during the calendar quarter, the total fuel usage for each type of fuel used at each emissions unit for each day.

*(Air Pollution Control Division; 326 IAC 7-4.1-11; filed May 25, 2005, 10:50 a.m.: 28 IR 2958)*

**326 IAC 7-4.1-12 Methodist Hospital sulfur dioxide emission limitations**

Authority: IC 13-14-8; IC 13-17-3-4; IC 13-17-3-11

Affected: IC 13-15; IC 13-17

Sec. 12. Methodist Hospital, Source Identification Number 00114, shall comply with the sulfur dioxide emission limits for Boiler 1 of one hundred fifty-two thousandths (0.152) pound per million British thermal units and four and eight hundred sixty-four thousandths (4.864) pounds per hour. *(Air Pollution Control Division; 326 IAC 7-4.1-12; filed May 25, 2005, 10:50 a.m.: 28 IR 2959)*

**326 IAC 7-4.1-13 National Recovery Systems sulfur dioxide emission limitations**

Authority: IC 13-14-8; IC 13-17-3-4; IC 13-17-3-11

Affected: IC 13-15; IC 13-17

Sec. 13. National Recovery Systems, Source Identification Number 00323, shall comply with the sulfur dioxide emission limits for the dryer of three-tenths (0.3) pound per million British thermal units and two and seven hundred-thousandths (2.700) pounds per hour. *(Air Pollution Control Division; 326 IAC 7-4.1-13; filed May 25, 2005, 10:50 a.m.: 28 IR 2959)*

**326 IAC 7-4.1-14 NIPSCO Dean H. Mitchell Generating Station sulfur dioxide emission limitations**

Authority: IC 13-14-8; IC 13-17-3-4; IC 13-17-3-11

Affected: IC 13-15; IC 13-17

Sec. 14. (a) NIPSCO Dean H. Mitchell Generating Station, Source Identification Number 00117, shall comply with the sulfur dioxide emission limits for Boilers 4, 5, 6, and 11 in pounds per million British thermal units (MMBtu), pounds per hour, and other requirements as follows:

- (1) Operation under either subdivision (2)(B) or (2)(C) shall only be allowed provided that a nozzle is in the stack serving Boilers 4 and 5 such that the stack diameter is restricted to eight and three-tenths (8.3) feet.
- (2) Sulfur dioxide emissions for boilers operating under the scenarios listed in this subdivision shall be measured as a daily weighted average by the continuous emissions monitoring systems (CEMS) required in subsection (b)(2). NIPSCO Dean H. Mitchell Generating Station may operate under any one (1) of the following scenarios:
- (A) Boilers 4, 5, 6, and 11 may operate simultaneously under the following conditions:
- (i) One (1) of Boiler 4 or 5 may operate on coal if the other boiler is operated on natural gas or is not operating. Sulfur dioxide emissions from the stack serving Boilers 4 and 5 shall be limited to one and five-hundredths (1.05) pounds per MMBtu and one thousand three hundred thirteen (1,313.0) pounds per hour.
- (ii) Boilers 6 and 11 may operate simultaneously on coal. Sulfur dioxide emissions from the stack serving Boilers 6 and 11 shall be limited to one and five-hundredths (1.05) pound per MMBtu and two thousand four hundred seventy-five (2,475.0) pounds per hour.

- (B) Boilers 4, 5, 6, and 11 may operate simultaneously on coal subject to the following conditions:
  - (i) Sulfur dioxide emissions from the stack serving Boilers 4 and 5 shall be limited to seventy-seven hundredths (0.77) pound per MMBtu and one thousand nine hundred twenty-five (1,925.0) pounds per hour.
  - (ii) Sulfur dioxide emissions from the stack serving Boilers 6 and 11 shall be limited to seventy-seven hundredths (0.77) pound per MMBtu and one thousand eight hundred fifteen (1,815.0) pounds per hour.
- (C) One (1) set of either Boilers 4 and 5 or 6 and 11 may operate on coal if the other set is not operating, subject to the following conditions:
  - (i) Sulfur dioxide emissions from the stack serving Boilers 4 and 5 shall be limited to one and five-hundredths (1.05) pounds per MMBtu and two thousand six hundred twenty-five (2,625.0) pounds per hour.
  - (ii) Sulfur dioxide emissions from the stack serving Boilers 6 and 11 shall be limited to one and five-hundredths (1.05) pounds per MMBtu and two thousand four hundred seventy-five (2,475.0) pounds per hour.
- (3) NIPSCO Dean H. Mitchell Generating Station shall maintain a daily log of the following for Boilers 4, 5, 6, and 11:
  - (A) Fuel type.
  - (B) Transition time of changes between or within operating scenarios.

The log shall be maintained for a minimum of five (5) years and shall be made available to the department and U.S. EPA upon request.
- (4) Emission limits shall be maintained during transition periods within or between operating scenarios.
- (b) NIPSCO Dean H. Mitchell Generating Station shall comply with the following:
  - (1) The diameter of the stack serving Boilers 6 and 11 shall be restricted to eight and three-tenths (8.3) feet.
  - (2) Beginning May 31, 1992, NIPSCO Dean H. Mitchell Generating Station shall maintain and operate CEMS in the stacks serving Boilers 4, 5, 6, and 11. The CEMS shall be operated in accordance with the procedures specified in 326 IAC 3-4 and 326 IAC 3-5, with the exception of the three (3) hour block period reporting requirements under 326 IAC 3-5-7. Records of daily average emissions data shall be:
    - (A) maintained for a minimum of five (5) years; and
    - (B) made available to the department and U.S. EPA upon request.
  - (3) NIPSCO Dean H. Mitchell Generating Station shall submit a written report to the department within thirty (30) days after the end of each calendar quarter. The report shall contain the daily weighted average emission rate in units of pounds per MMBtu as measured by the CEMS for each stack venting emissions from those boilers specified in subdivision (2). The hourly gross megawatt power production from the units connected to each stack may be used as the weighting factor in determining the daily weighted average. Records of the hourly gross megawatt power production shall be:
    - (A) maintained for a minimum of five (5) years; and
    - (B) made available to the department and U.S. EPA upon request.

*(Air Pollution Control Division; 326 IAC 7-4.1-14; filed May 25, 2005, 10:50 a.m.: 28 IR 2960)*

### **326 IAC 7-4.1-15 Rhodia sulfur dioxide emission limitations**

Authority: IC 13-14-8; IC 13-17-3-4; IC 13-17-3-11

Affected: IC 13-15; IC 13-17

Sec. 15. (a) Rhodia, Source Identification Number 00242, shall comply with the sulfur dioxide emission limit for the Spent Acid Regeneration Unit 4 of seven hundred eighty-two (782) pounds per hour.

(b) Rhodia shall operate a continuous emission monitoring system (CEMS) in each stack serving Unit 4. Rhodia shall submit a report to the department within thirty (30) days after the end of each calendar quarter. The report shall contain the following information:

- (1) Three (3) hour average sulfur dioxide emission rate in pounds per hour as measured by the CEMS from Unit 4 for each three (3) hour period during the calendar quarter in which the average emissions exceed the allowable rates specified in subsection (a).
- (2) The daily average emission rate in units of pounds per ton as determined from CEMS and production data for Unit 4 for each day of the calendar quarter.

*(Air Pollution Control Division; 326 IAC 7-4.1-15; filed May 25, 2005, 10:50 a.m.: 28 IR 2960)*

**326 IAC 7-4.1-16 Safety-Kleen Oil Recovery Company sulfur dioxide emission limitations**

Authority: IC 13-14-8; IC 13-17-3-4; IC 13-17-3-11

Affected: IC 13-15; IC 13-17

Sec. 16. Safety-Kleen Oil Recovery Company, Source Identification Number 00301, shall comply with the sulfur dioxide emission limits in pounds per hour and other requirements as follows:

- (1) Boilers SB-801, SB-820, SB-821, and SB-823, and Process Heaters H-302 and H-404 shall use natural gas only.
- (2) Process Heater H-201, with a capacity of twenty-seven and three-tenths (27.3) MMBtu per hour, shall use a combination of natural gas, No. 2 fuel oil equivalent, and off-gases. Process Heater H-301, with a capacity of twenty and zero-tenths (20.0) MMBtu per hour, shall use a combination of natural gas and No. 2 fuel oil equivalent. The combined sulfur dioxide emissions from these two (2) process heaters shall not exceed fourteen (14) pounds per hour and sixty (60) tons per year.
- (3) Process Heater H-401, with a capacity of fifteen and three-tenths (15.3) MMBtu per hour, shall use a combination of natural gas, No. 2 fuel oil equivalent, and off-gases. Process Heater H-402, with a capacity of eleven and seven-tenths (11.7) MMBtu per hour, shall use a combination of natural gas and No. 2 fuel oil equivalent. The combined sulfur dioxide emissions from these two (2) process heaters shall not exceed ten and eight-tenths (10.8) pounds per hour and forty-seven and three-tenths (47.3) tons per year.
- (4) Process Heater H-406, with a capacity of twenty (20.0) MMBtu per hour, shall use a combination of natural gas and off-gases. The sulfur dioxide emissions shall not exceed eight (8) pounds per hour.
- (5) Within thirty (30) days after the effective date of this rule, Safety-Kleen shall choose one (1) of the following compliance options for Process Heaters H-201, H-301, H-401, H-402, and H-406 and submit a letter to the department identifying which option will be used to demonstrate compliance of these process heaters with this rule. With the letter, Safety-Kleen shall submit a fuel and sampling analysis protocol for the selected option for approval by the department. Safety-Kleen shall comply with the approved compliance method by December 31, 2005, and after that date shall use only the selected method to demonstrate compliance of the process heaters in accordance with the approved fuel and sampling analysis protocol. The department shall notify U.S. EPA of the approved option. The options are as follows:
  - (A) Safety-Kleen shall demonstrate compliance through monitoring as follows:
    - (i) Monitor sulfur content in the off-gas streams for Process Heaters H-201, H-401, and H-406.
    - (ii) Prior to sampling the fuel in the fuel tank, mix the contents of the tank to ensure consistent composition of the fuel throughout the tank.
    - (iii) Perform fuel sampling and analysis for the sulfur content of the fuel in each fuel tank:
      - (AA) prior to the first time the fuel is burned; and
      - (BB) subsequently, prior to burning the fuel whenever additional fuel has been added to the tank since the last sampling event.
    - (iv) Maintain records sufficient to demonstrate compliance for at least three (3) years.
    - (v) Submit an excess emissions report to the department within thirty (30) days after the end of each calendar quarter.
  - (B) Safety-Kleen shall demonstrate compliance through monitoring as follows:
    - (i) Install sulfur dioxide CEMS on the stacks for Process Heaters H-201, H-401, and H-406. The CEMS shall be installed, calibrated, operated, and maintained in accordance with 326 IAC 3-5.
    - (ii) Conduct fuel sampling for heat input and sulfur content and measure the quantity of fuel oil burned in the four (4) process heaters in order to calculate the heat input rate in MMBtu/hr for Process Heaters H-201 and H-401, as well as the SO<sub>2</sub> emission rate in Process Heaters H-301 and H-402.
    - (iii) Prior to sampling the fuel in the fuel tank, mix the contents of the tank to ensure consistent composition of the fuel throughout the tank.
    - (iv) Perform fuel sampling and analysis for the sulfur content of the fuel in each fuel tank:
      - (AA) prior to the first time the fuel is burned; and
      - (BB) subsequently, prior to burning the fuel whenever additional fuel has been added to the tank since the last sampling event.
    - (v) Maintain records sufficient to demonstrate compliance for at least three (3) years.

(vi) Submit an excess emissions report to the department within thirty (30) days after the end of each calendar quarter.

(C) Safety-Kleen shall demonstrate compliance through monitoring as follows:

(i) Install sulfur dioxide CEMS on the stacks for Process Heaters H-201, H-301, H-401, H-402, and H-406. The CEMS shall be installed, calibrated, operated, and maintained in accordance with 326 IAC 3-5.

(ii) Maintain records sufficient to demonstrate compliance for at least three (3) years.

(iii) Submit an excess emissions report to the department within thirty (30) days after the end of each calendar quarter.

*(Air Pollution Control Division; 326 IAC 7-4.1-16; filed May 25, 2005, 10:50 a.m.: 28 IR 2961)*

**326 IAC 7-4.1-17 SCA Tissue North America LLC sulfur dioxide emission limitations**

Authority: IC 13-14-8; IC 13-17-3-4; IC 13-17-3-11

Affected: IC 13-15; IC 13-17

Sec. 17. SCA Tissue North America LLC, Source Identification Number 00106, shall comply with the sulfur dioxide emission limits for Boiler 1 of one and two-tenths (1.2) pounds per million British thermal units and eighty-seven and twenty-four hundredths (87.24) pounds per hour. *(Air Pollution Control Division; 326 IAC 7-4.1-17; filed May 25, 2005, 10:50 a.m.: 28 IR 2962)*

**326 IAC 7-4.1-18 State Line Energy, LLC sulfur dioxide emission limitations**

Authority: IC 13-14-8; IC 13-17-3-4; IC 13-17-3-11

Affected: IC 13-15; IC 13-17

Sec. 18. State Line Energy, LLC, Source Identification Number 00210, shall comply with the sulfur dioxide emission limits in pounds per million British thermal units (MMBtu) and pounds per hour as follows:

(1) The Auxiliary Emergency Generator shall be limited to three-tenths (0.3) pound per MMBtu and one and thirty-five hundredths (1.35) pounds per hour.

(2) Boiler 3 shall be limited to one and two-tenths (1.2) pounds per MMBtu and two thousand five hundred fifty-six (2,556) pounds per hour.

(3) Boiler 4 shall be limited to one and two-tenths (1.2) pounds per MMBtu and four thousand fifty-four and eight-tenths (4,054.8) pounds per hour.

*(Air Pollution Control Division; 326 IAC 7-4.1-18; filed May 25, 2005, 10:50 a.m.: 28 IR 2962)*

**326 IAC 7-4.1-19 Unilever HPC USA sulfur dioxide emission limitations**

Authority: IC 13-14-8; IC 13-17-3-4; IC 13-17-3-11

Affected: IC 13-15; IC 13-17

Sec. 19. Unilever HPC USA, Source Identification Number 00229, shall comply with the sulfur dioxide emission limits in pounds per million British thermal units (MMBtu), hours per year, and pounds per hour as follows:

(1) Boiler 4 shall be limited to one and fifty-two hundredths (1.52) pounds per MMBtu and one hundred twenty-five and three-tenths (125.3) pounds per hour.

(2) Power House Boiler No. 1 shall be limited to five-tenths (0.5) pounds per MMBtu and sixty (60) pounds per hour for a total of six hundred ninety-five (695) hours per year at full capacity.

(3) American Hydrotherm Boiler No. 2 shall be limited to three-tenths (0.3) pound per MMBtu and three and sixty-six hundredths (3.66) pounds per hour.

*(Air Pollution Control Division; 326 IAC 7-4.1-19; filed May 25, 2005, 10:50 a.m.: 28 IR 2962)*

---

SULFUR DIOXIDE RULES

---

**326 IAC 7-4.1-20 U. S. Steel-Gary Works sulfur dioxide emission limitations**

Authority: IC 13-14-8; IC 13-17-3-4; IC 13-17-3-11

Affected: IC 13-15; IC 13-17

Sec. 20. (a) U. S. Steel-Gary Works, Source Identification Number 00121, shall comply with the following sulfur dioxide emission limitations in pounds per million British thermal units (MMBtu) and pounds per hour when the coke oven gas desulfurization emissions unit is not operating during the following periods:

| Emissions Unit Description                                                                                                                                                     | Emission Limit<br>lbs/MMBtu | Emission Limit<br>lbs/hour |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------|----------------------------|
| (1) During January through December:                                                                                                                                           |                             |                            |
| (A) Turboblower Boiler House Boiler No. 6                                                                                                                                      | 0.115                       | 81.7                       |
| (B) No. 4 Boiler House Boiler Nos. 1, 2, and 3:                                                                                                                                |                             |                            |
| (i) During periods when Blast Furnace No. 13 Stoves are combusting blast furnace gas:                                                                                          |                             |                            |
| (AA) When three (3) boilers are operating                                                                                                                                      | 0.115                       | 172.5 total                |
| (BB) When two (2) boilers are operating                                                                                                                                        | 0.173                       | 172.5 total                |
| (CC) When one (1) boiler is operating                                                                                                                                          | 0.345                       | 172.5 total                |
| (ii) During periods when Blast Furnace No. 13 Stoves are not combusting blast furnace gas and Hot Strip Mill Waste Heat Boiler Nos. 1 and 2 are combusting coke oven gas:      |                             |                            |
| (AA) When three (3) boilers are operating                                                                                                                                      | 0.200                       | 300.0 total                |
| (BB) When two (2) boilers are operating                                                                                                                                        | 0.300                       | 300.0 total                |
| (CC) When one (1) boiler is operating                                                                                                                                          | 0.600                       | 300.0 total                |
| (iii) During periods when Blast Furnace No. 13 Stoves are not combusting blast furnace gas and Hot Strip Mill Waste Heat Boiler Nos. 1 and 2 are not combusting coke oven gas: |                             |                            |
| (AA) When three (3) boilers are operating                                                                                                                                      | 0.195                       | 293.0 total                |
| (BB) When two (2) boilers are operating                                                                                                                                        | 0.293                       | 293.0 total                |
| (CC) When one (1) boiler is operating                                                                                                                                          | 0.586                       | 293.0 total                |
| (C) Number 2 Coke Plant Boiler House:                                                                                                                                          |                             |                            |
| (i) Boiler No. 8                                                                                                                                                               | 1.270                       | 316.2                      |
| (ii) Boiler No. 9                                                                                                                                                              | 1.270                       | 298.45                     |
| (iii) Boiler No. 10                                                                                                                                                            | 1.270                       | 298.45                     |
| (D) Coke Oven Underfiring Stacks:                                                                                                                                              |                             |                            |
| (i) Nos. 2 and 3                                                                                                                                                               | 1.270                       | 251.5 each                 |
| (ii) Nos. 5 and 7                                                                                                                                                              | 1.270                       | 158.75 each                |
| (E) During periods when the 84-inch Hot Strip Mill Continuous Reheat Furnaces Nos. 1, 2, 3, and 4 are not combusting coke oven gas:                                            |                             |                            |
| (i) Hot Strip Mill Waste Heat Boiler No. 1 or 2                                                                                                                                | 1.270                       | 287.0                      |
| (ii) Remaining Hot Strip Mill Waste Heat Boiler                                                                                                                                | 0.704                       | 159.0                      |
| (F) Hot Strip Mill Continuous Reheat Furnace Nos. 1, 2, 3, and 4 during periods when combusting coke oven gas:                                                                 |                             |                            |
| (i) When four (4) furnaces are operating                                                                                                                                       | 0.256                       | 615.0 total                |
| (ii) When three (3) furnaces are operating                                                                                                                                     | 0.342                       | 615.0 total                |
| (iii) When two (2) furnaces are operating                                                                                                                                      | 0.513                       | 615.0 total                |
| (iv) When one (1) furnace is operating                                                                                                                                         | 1.025                       | 615.0 total                |

---

SULFUR DIOXIDE RULES

---

|                                                                                                                              |                               |               |
|------------------------------------------------------------------------------------------------------------------------------|-------------------------------|---------------|
| (G) Number 3 Sinter Plant Windbox Gas Cleaning Systems                                                                       |                               | 260.0 total   |
| (H) Coke Oven Gas Desulfurization Facility Tail Gas Incinerator                                                              |                               | 22.0          |
| (I) Blast Furnace Stove Stacks:                                                                                              |                               |               |
| (i) No. 4                                                                                                                    | 0.115                         | 40.25 total   |
| (ii) No. 6                                                                                                                   | 0.115                         | 40.25 total   |
| (iii) No. 8                                                                                                                  | 0.115                         | 37.38 total   |
| (J) Blast Furnace Stove Stack 13 during periods when combusting blast furnace gas                                            | 0.134                         | 93.50 total   |
| (K) No. 13 Blast Furnace Casthouse Baghouse during periods when Blast Furnace No. 13 Stoves are combusting blast furnace gas |                               | 115.0         |
| (L) No. 2 Q-BOP Shop Hot Metal Desulf Baghouse                                                                               | 0.05 pounds per ton hot metal | 28.54         |
| (M) No. 1 BOP Shop Hot Metal Desulf Baghouse                                                                                 | 0.05 pounds per ton hot metal | 28.54         |
| (2) During specified periods:                                                                                                |                               |               |
| (A) Turboblower Boiler House Boiler Nos. 1, 2, 3, and 5:                                                                     |                               |               |
| (i) During periods when the Hot Strip Mill Waste Heat Boiler Nos. 1 and 2 are not combusting coke oven gas:                  |                               |               |
| (AA) January through April:                                                                                                  |                               |               |
| (aa) When four (4) boilers are operating                                                                                     | 0.594                         | 974.5 total   |
| (bb) When three (3) boilers are operating                                                                                    | 0.792                         | 974.5 total   |
| (cc) When two (2) boilers or less are operating                                                                              | 1.188                         | 974.5 total   |
| (BB) May through October:                                                                                                    |                               |               |
| (aa) When four (4) boilers are operating                                                                                     | 1.006                         | 1,650.0 total |
| (bb) When three (3) boilers are operating                                                                                    | 1.341                         | 1,650.0 total |
| (cc) When two (2) boilers or less are operating                                                                              | 2.012                         | 1,650.0 total |
| (CC) November through December:                                                                                              |                               |               |
| (aa) When four (4) boilers are operating                                                                                     | 0.384                         | 630.0 total   |
| (bb) When three (3) boilers are operating                                                                                    | 0.512                         | 630.0 total   |
| (cc) When two (2) boilers or less are operating                                                                              | 0.768                         | 630.0 total   |
| (ii) During periods when the Hot Strip Mill Waste Heat Boiler Nos. 1 and 2 are combusting coke oven gas:                     |                               |               |
| (AA) January through April:                                                                                                  |                               |               |
| (aa) When four (4) boilers are operating                                                                                     | 0.625                         | 1,025.0 total |
| (bb) When three (3) boilers are operating                                                                                    | 0.833                         | 1,025.0 total |
| (cc) When two (2) boilers or less are operating                                                                              | 1.250                         | 1,025.0 total |
| (BB) May through October:                                                                                                    |                               |               |
| (aa) When four (4) boilers are operating                                                                                     | 0.994                         | 1,630.0 total |
| (bb) When three (3) boilers are operating                                                                                    | 1.325                         | 1,630.0 total |
| (cc) When two (2) boilers or less are operating                                                                              | 1.988                         | 1,630.0 total |
| (CC) November through December:                                                                                              |                               |               |
| (aa) When four (4) boilers are operating                                                                                     | 0.351                         | 575.0 total   |
| (bb) When three (3) boilers are operating                                                                                    | 0.467                         | 575.0 total   |
| (cc) When two (2) boilers or less are operating                                                                              | 0.701                         | 575.0 total   |
| (B) Number 2 Coke Plant Boiler House Boiler Nos. 4 and 5:                                                                    |                               |               |
| (i) January through April                                                                                                    | 0.444                         | 150.0 total   |

## SULFUR DIOXIDE RULES

| (ii) May through October                                                                                                                                                                                  | 0.385                       | 130.0 total                |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------|----------------------------|
| (iii) November through December                                                                                                                                                                           | 0.0006                      | 0.203 total                |
| (C) Number 2 Coke Plant Boiler House Boiler No. 6:                                                                                                                                                        |                             |                            |
| (i) January through April                                                                                                                                                                                 | 1.27                        | 214.6                      |
| (ii) May through October                                                                                                                                                                                  | 1.27                        | 214.6                      |
| (iii) November through December                                                                                                                                                                           | 1.18                        | 200.0                      |
| (b) U.S. Steel-Gary Works shall comply with the following sulfur dioxide emission limitations in pounds per MMBtu and pounds per hour when the coke oven gas desulfurization emissions unit is operating: |                             |                            |
| Emissions Unit Description                                                                                                                                                                                | Emission Limit<br>lbs/MMBtu | Emission Limit<br>lbs/hour |
| (1) Turboblower Boiler House:                                                                                                                                                                             |                             |                            |
| (A) Boilers Nos. 1, 2, 3, and 5:                                                                                                                                                                          |                             |                            |
| (i) When four (4) boilers are operating                                                                                                                                                                   | 0.427                       | 700.0 total                |
| (ii) When three (3) boilers are operating                                                                                                                                                                 | 0.569                       | 700.0 total                |
| (iii) When two (2) boilers or less are operating                                                                                                                                                          | 0.854                       | 700.0 total                |
| (B) Boiler No. 6                                                                                                                                                                                          | 0.115                       | 81.7                       |
| (2) Number 4 Boiler House Boiler Nos. 1, 2, and 3:                                                                                                                                                        |                             |                            |
| (A) When three (3) boilers are operating                                                                                                                                                                  | 0.353                       | 529.0 total                |
| (B) When two (2) boilers are operating                                                                                                                                                                    | 0.529                       | 529.0 total                |
| (C) When one (1) boiler is operating                                                                                                                                                                      | 1.058                       | 529.0 total                |
| (3) Number 2 Coke Plant Boiler House:                                                                                                                                                                     |                             |                            |
| (A) Boiler No. 3                                                                                                                                                                                          | 0.260                       | 40.6                       |
| (B) Boiler Nos. 4 and 5                                                                                                                                                                                   | 0.260                       | 87.9 total                 |
| (C) Boiler No. 6                                                                                                                                                                                          | 0.260                       | 44.0                       |
| (D) Boiler No. 7                                                                                                                                                                                          | 0.260                       | 42.1                       |
| (E) Boiler No. 8                                                                                                                                                                                          | 0.260                       | 64.7                       |
| (F) Boiler No. 9                                                                                                                                                                                          | 0.260                       | 61.10                      |
| (G) Boiler No. 10                                                                                                                                                                                         | 0.260                       | 61.10                      |
| (4) Coke Battery Number 2, 3, 5, and 7 Underfiring:                                                                                                                                                       |                             |                            |
| (A) Nos. 2 and 3                                                                                                                                                                                          | 0.260                       | 51.5 each                  |
| (B) No. 5                                                                                                                                                                                                 | 0.270                       | 33.8                       |
| (C) No. 7                                                                                                                                                                                                 | 0.260                       | 32.5                       |
| (5) Blast Furnace Stove Stacks:                                                                                                                                                                           |                             |                            |
| (A) No. 4                                                                                                                                                                                                 | 0.115                       | 40.25 total                |
| (B) No. 6                                                                                                                                                                                                 | 0.115                       | 40.25 total                |
| (C) No. 8                                                                                                                                                                                                 | 0.115                       | 37.38 total                |
| (D) No. 13                                                                                                                                                                                                | 0.134                       | 93.50 total                |
| (6) 84-inch Hot Strip Mill:                                                                                                                                                                               |                             |                            |
| (A) Waste Heat Boiler Nos. 1 and 2                                                                                                                                                                        | 0.260                       | 58.8 each                  |
| (B) Continuous Reheat Furnaces Nos. 1, 2, 3, and 4:                                                                                                                                                       |                             |                            |
| (i) When four (4) furnaces are operating                                                                                                                                                                  | 0.182                       | 436.5 total                |
| (ii) When three (3) furnaces are operating                                                                                                                                                                | 0.243                       | 436.5 total                |
| (iii) When two (2) furnaces are operating                                                                                                                                                                 | 0.354                       | 436.5 total                |
| (iv) When one (1) furnace is operating                                                                                                                                                                    | 0.728                       | 436.5 total                |

---

SULFUR DIOXIDE RULES

---

|                                                                 |                                  |           |
|-----------------------------------------------------------------|----------------------------------|-----------|
| (7) Number 3 Sinter Plant Windbox Gas Cleaning Systems          |                                  | 200 total |
| (8) Coke Oven Gas Desulfurization Facility Tail Gas Incinerator |                                  | 295       |
| (9) No. 13 Blast Furnace Casthouse Baghouse                     |                                  | 115       |
| (10) No. 2 Q-BOP Shop Hot Metal Desulf Baghouse                 | 0.05 pounds per<br>ton hot metal | 28.54     |
| (11) No. 1 BOP Shop Hot Metal Desulf Baghouse                   | 0.05 pounds per<br>ton hot metal | 28.54     |

(c) U. S. Steel-Gary Works shall comply with additional sulfur dioxide emission requirements as follows:

(1) U. S. Steel shall record and make available to IDEM, upon request, process and fuel use information pertaining to each emissions unit, process, or combustion unit identified in this section, including the following:

(A) Identification of the applicable limit.

(B) The amount and type of each fuel used for each emissions unit for each calendar day of operation.

(C) The operating scenario chosen for the U. S. Steel-Gary Works.

(D) The hourly sulfur dioxide emission rate in pounds of sulfur dioxide per hour calculated by dividing the total daily sulfur dioxide emissions in pounds of sulfur dioxide per day by twenty-four (24) hours.

(E) The hourly sulfur dioxide emission rate in pounds of sulfur dioxide per MMBtu for those emissions units with a pounds of sulfur dioxide per MMBtu limit in this rule calculated by dividing the total daily sulfur dioxide emissions in pounds of sulfur dioxide per day by the total heat input per day in MMBtu.

(2) U. S. Steel-Gary Works shall submit an exception report to the department within thirty (30) days of an exceedance of the limitations in this section that includes the following:

(A) Identification of the applicable limit or limits being exceeded.

(B) Identification of any emissions unit exceeding the applicable limit and the dates when the limits were exceeded.

(C) The calculated sulfur dioxide emission rate in pounds per hour for each emissions unit exceeding the limitations for the days that the pounds per hour limitations were exceeded.

(D) The calculated sulfur dioxide emission rate in pounds per MMBtu for each combustion unit, furnace, boiler, or process operation for each emissions unit exceeding the pounds per MMBtu limitations for the days that the limitations were exceeded.

(E) The actual daily fuel usage for each combustion unit, furnace, boiler, or process operation for each emissions unit exceeding the limitations for the days that the limitations were exceeded.

(3) An emission unit shall burn natural gas only:

(A) if it is not listed in this rule; or

(B) under any operating condition not specifically listed in this rule.

(4) The desulfurization facility is restricted to no more than nine hundred fifty (950) hours of downtime in a calendar year.

*(Air Pollution Control Division; 326 IAC 7-4.1-20; filed May 25, 2005, 10:50 a.m.: 28 IR 2962)*

**326 IAC 7-4.1-21 Walsh and Kelly sulfur dioxide emission limitations**

Authority: IC 13-14-8; IC 13-17-3-4; IC 13-17-3-11

Affected: IC 13-15; IC 13-17

Sec. 21. (a) Walsh and Kelly, Source Identification Number 03215, shall comply with the sulfur dioxide emission limits for the aggregate dryer of less than:

(1) twenty-five (25) tons per year; and

(2) forty-two (42) pounds per hour.

(b) The input of re-refined waste oil and its calculated #2 fuel oil equivalents in the one hundred fifteen (115) million British thermal units (MMBtu) per hour burner for the aggregate dryer shall be limited to less than seven hundred forty thousand seven hundred twenty-five (740,725) gallons per twelve (12) consecutive month period, rolled on a monthly basis, based on maximum sulfur content of forty-five hundredths percent (0.45%) for re-refined waste oil. *(Air Pollution Control Division; 326 IAC 7-4.1-21; filed May 25, 2005, 10:50 a.m.: 28 IR 2965; filed Apr 29, 2015, 3:30 p.m.: 20150527-IR-326140256FRA)*

## SULFUR DIOXIDE RULES

---

\*