

Document: Proposed Rule, **Register Page Number:** 28 IR 1308

Source: January 1, 2005, Indiana Register, Volume 28, Number 4

Disclaimer: This document was created from the files used to produce the official CD-ROM Indiana Register.

**TITLE 675 FIRE PREVENTION AND BUILDING
SAFETY COMMISSION**

Proposed Rule
LSA Document #04-217

DIGEST

Amends 675 IAC 18-1.4, the 2003 Indiana Mechanical Code, to make numerous substantive and clarifying changes. Effective 30 days after filing with the secretary of state.

675 IAC 18-1.4-10.5 **675 IAC 18-1.4-32.5**
675 IAC 18-1.4-11.5 **675 IAC 18-1.4-49.5**
675 IAC 18-1.4-32.3

SECTION 1. 675 IAC 18-1.4-10.5 IS ADDED TO READ AS FOLLOWS:

675 IAC 18-1.4-10.5 Section 304.3; elevation of ignition source

Authority: IC 22-13-2-2; IC 22-13-2-13

Affected: IC 22-12; IC 22-13; IC 22-14; IC 22-15; IC 36-7

Sec. 10.5. In the second sentence of Section 304.3, Elevation of ignition source, before “Group”, delete “use”. (Fire Prevention and Building Safety Commission; 675 IAC 18-1.4-10.5)

SECTION 2. 675 IAC 18-1.4-11.5 IS ADDED TO READ AS FOLLOWS:

675 IAC 18-1.4-11.5 Section 310; explosion venting

Authority: IC 22-13-2-2; IC 22-13-2-13

Affected: IC 22-12; IC 22-13; IC 22-14; IC 22-15; IC 36-7

Sec. 11.5. Change the title of Section 310 to read “Explosion Control”. (Fire Prevention and Building Safety Commission; 675 IAC 18-1.4-11.5)

SECTION 3. 675 IAC 18-1.4-32.3 IS ADDED TO READ AS FOLLOWS:

675 IAC 18-1.4-32.3 Section 607.5.4; corridors/smoke barriers

Authority: IC 22-13-2-2; IC 22-13-2-13

Affected: IC 22-12; IC 22-13; IC 22-14; IC 22-15; IC 36-7

Sec. 32.3. Delete the text of Exception 2 in Section 607.5.4 and substitute “Smoke dampers shall not be required in duct penetration of smoke barriers in fully ducted heating, ventilating, and air conditioning systems.”. (Fire Prevention and Building Safety Commission; 675 IAC 18-1.4-32.3)

SECTION 4. 675 IAC 18-1.4-32.5 IS ADDED TO READ AS FOLLOWS:

675 IAC 18-1.4-32.5 Section 607.5.5.1; penetrations of shaft enclosures

Authority: IC 22-13-2-2; IC 22-13-2-13

Affected: IC 22-12; IC 22-13; IC 22-14; IC 22-15; IC 36-7

Sec. 32.5. In the first sentence of Section 607.5.5.1, delete “and smoke” without substitution. (Fire Prevention and Building

Safety Commission; 675 IAC 18-1.4-32.5)

SECTION 5. 675 IAC 18-1.4-49.5 IS ADDED TO READ AS FOLLOWS:

675 IAC 18-1.4-49.5 Section 1403.2; flammable gases and liquids

Authority: IC 22-13-2-2; IC 22-13-2-13

Affected: IC 22-12; IC 22-13; IC 22-14; IC 22-15; IC 36-7

Sec. 49.5. In the second sentence of Section 1403.2, delete “Use”. (*Fire Prevention and Building Safety Commission; 675 IAC 18-1.4-49.5*)

Notice of Public Hearing

Under IC 4-22-2-24, notice is hereby given that on March 17, 2005, at 10:00 a.m., at the Indiana Government Center-South, 402 West Washington Street, Conference Center Room A, Indianapolis, Indiana; AND on May 4, 2005 at 10:00 a.m., at the Indiana Government Center-South, 402 West Washington Street, Conference Center Room B, Indianapolis, Indiana the Fire Prevention and Building Safety Commission will hold a public hearing on proposed amendments to the 2003 Indiana Mechanical Code. Copies of these rules are now on file at the Indiana Government Center-South, 402 West Washington Street, Room W246 and Legislative Services Agency, One North Capitol, Suite 325, Indianapolis, Indiana and are open for public inspection.

Luther J. Taylor, Sr.
Secretary
Fire Prevention and Building Safety Commission