Document: Proposed Rule, **Register Page Number:** 28 IR 1309

Source: January 1, 2005, Indiana Register, Volume 28, Number 4

Disclaimer: This document was created from the files used to produce the official CD-ROM Indiana Register.

TITLE 675 FIRE PREVENTION AND BUILDING SAFETY COMMISSION

Proposed Rule

LSA Document #04-218

DIGEST

Amends 675 IAC 25-1, the 2003 Indiana Fuel Gas Code, to make numerous substantive and clarifying changes. Effective 30 days after filing with the secretary of state.

675 IAC 25-1-7.2	675 IAC 25-1-9.3
675 IAC 25-1-7.4	675 IAC 25-1-9.5
675 IAC 25-1-7.6	675 IAC 25-1-9.7
675 IAC 25-1-9.1	675 IAC 25-1-9.9

SECTION 1. 675 IAC 25-1-7.2 IS ADDED TO READ AS FOLLOWS:

675 IAC 25-1-7.2 Table 308.2

Authority: IC 22-13-2-2; IC 22-13-2-13

Affected: IC 22-12; IC 22-13; IC 22-14; IC 22-15; IC 36-7

Sec. 7.2. In Table 308.2, delete "0.024" and insert "0.024 inch (24 gage)" in the left column in item numbers 3, 5, 7, and 8. (Fire Prevention and Building Safety Commission; 675 IAC 25-1-7.2)

SECTION 2. 675 IAC 25-1-7.4 IS ADDED TO READ AS FOLLOWS:

675 IAC 25-1-7.4 Figure 308.2(3)

Authority: IC 22-13-2-2; IC 22-13-2-13

Affected: IC 22-12; IC 22-13; IC 22-14; IC 22-15; IC 36-7

Sec. 7.4. Change the title of Figure 308.2(3) to read: "Masonry clearance reduction system". (Fire Prevention and Building Safety Commission; 675 IAC 25-1-7.4)

SECTION 3. 675 IAC 25-1-7.6 IS ADDED TO READ AS FOLLOWS:

675 IAC 25-1-7.6 Section 403.11; plastic piping, joints, and fittings

Authority: IC 22-13-2-2; IC 22-13-2-13

Affected: IC 22-12; IC 22-13; IC 22-14; IC 22-15; IC 36-7

Sec. 7.6. In Section 403.11, Plastic piping, joints and fittings, change the third sentence in item number 3 to read: "The stiffener shall be flush with the end of the pipe or tubing and shall extend at least to the outside end of the compression fitting when installed.". (Fire Prevention and Building Safety Commission; 675 IAC 25-1-7.6)

SECTION 4. 675 IAC 25-1-9.1 IS ADDED TO READ AS FOLLOWS:

675 IAC 25-1-9.1 Section 503.5.3; masonry chimneys

Authority: IC 22-13-2-2; IC 22-13-2-13

Affected: IC 22-12; IC 22-13; IC 22-14; IC 22-15; IC 36-7

Sec. 9.1. In Section 503.5.3, masonry chimneys, change, in the last sentence (after exception), the referenced section number to 503.6.5. (Fire Prevention and Building Safety Commission; 675 IAC 25-1-9.1)

SECTION 5. 675 IAC 25-1-9.3 IS ADDED TO READ AS FOLLOWS:

675 IAC 25-1-9.3 Table/Figure 503.6.6 Authority: IC 22-13-2-2; IC 22-13-2-13

Affected: IC 22-12; IC 22-13; IC 22-14; IC 22-15; IC 36-7

Sec. 9.3. In the second row of Table/Figure 503.6.6, before 6/12 to 7/12, insert "over". (Fire Prevention and Building Safety Commission: 675 IAC 25-1-9.3)

SECTION 6. 675 IAC 25-1-9.5 IS ADDED TO READ AS FOLLOWS:

675 IAC 25-1-9.5 Section 503.6.9.1; Category I appliances

Authority: IC 22-13-2-2; IC 22-13-2-13

Affected: IC 22-12; IC 22-13; IC 22-14; IC 22-15; IC 36-7

Sec. 9.5. In Section 503.6.9.1, Category I appliances, in Exception number 2, in the fifth line, delete "outlets" and insert "outlet" and, in the sixth line, delete "smallest" and insert "smaller". (Fire Prevention and Building Safety Commission; 675 IAC 25-1-9.5)

SECTION 7. 675 IAC 25-1-9.7 IS ADDED TO READ AS FOLLOWS:

675 IAC 25-1-9.7 Section 503.7.5; roof penetrations

Authority: IC 22-13-2-2; IC 22-13-2-13

Affected: IC 22-12; IC 22-13; IC 22-14; IC 22-15; IC 36-7

Sec. 9.7. In the third line of Section 503.7.5, Roof penetrations, delete "jacket" and insert "jack". (Fire Prevention and Building Safety Commission; 675 IAC 25-1-9.7)

SECTION 8. 675 IAC 25-1-9.9 IS ADDED TO READ AS FOLLOWS:

675 IAC 25-1-9.9 Section 504.2.9; chimney and vent locations

Authority: IC 22-13-2-2; IC 22-13-2-13

Affected: IC 22-12; IC 22-13; IC 22-14; IC 22-15; IC 36-7

Sec. 9.9. In Section 504.2.9, Chimney and vent locations, change, in item 4, the second line to read: given by Table 504.2(3). (Fire Prevention and Building Safety Commission; 675 IAC 25-1-9.9)

Notice of Public Hearing

Under IC 4-22-2-24, notice is hereby given that on March 17, 2005, at 10:30 a.m., at the Indiana Government Center-South, 402 West Washington Street, Conference Center Room A, Indianapolis, Indiana; AND on May 4, 2005 at 10:00 a.m., at the Indiana Government Center-South, 402 West Washington Street, Conference Center Room B, Indianapolis, Indiana the Fire Prevention and Building Safety Commission will hold a public hearing on proposed amendments to the 2003 Indiana Fuel Gas Code. Copies of these rules are now on file at the Indiana Government Center-South, 402 West Washington Street, Room W246 and Legislative Services Agency, One North Capitol, Suite 325, Indianapolis, Indiana and are open for public inspection.

Luther J. Taylor, Sr.

Secretary

Fire Prevention and Building Safety Commission