

**Document:** Final Rule, **Register Page Number:** 28 IR 2369

**Source:** May 1, 2005, Indiana Register, Volume 28, Number 8

**Disclaimer:** This document was created from the files used to produce the official CD-ROM Indiana Register.

**TITLE 675 FIRE PREVENTION AND BUILDING  
SAFETY COMMISSION**

LSA Document #04-56(F)

**DIGEST**

Amends 675 IAC 22-2.3, the 2003 Indiana Fire Code, to make substantive and clarifying changes and to add provisions concerning haunted houses. Repeals 675 IAC 22-2.2-49.5, 675 IAC 22-2.2-134.5, 675 IAC 22-2.2-183, 675 IAC 22-2.2-221.5, 675 IAC 22-2.2-245.2, 675 IAC 22-2.2-245.5, 675 IAC 22-2.2-365.2, 675 IAC 22-2.2-365.5, 675 IAC 22-2.2-369.5, 675 IAC 22-2.2-378.5, 675 IAC 22-2.2-412.5, 675 IAC 22-2.2-437.5, 675 IAC 22-2.2-437.7, 675 IAC 22-2.2-443.5, and 675 IAC 22-2.2-540. Effective 30 days after filing with the secretary of state.

675 IAC 22-2.2-49.5	675 IAC 22-2.3-29.5
675 IAC 22-2.2-134.5	675 IAC 22-2.3-35.5
675 IAC 22-2.2-183	675 IAC 22-2.3-36
675 IAC 22-2.2-221.5	675 IAC 22-2.3-36.3
675 IAC 22-2.2-245.2	675 IAC 22-2.3-36.4
675 IAC 22-2.2-245.5	675 IAC 22-2.3-36.6
675 IAC 22-2.2-365.2	675 IAC 22-2.3-36.8
675 IAC 22-2.2-365.5	675 IAC 22-2.3-140.5
675 IAC 22-2.2-369.5	675 IAC 22-2.3-147.5
675 IAC 22-2.2-378.5	675 IAC 22-2.3-147.6
675 IAC 22-2.2-412.5	675 IAC 22-2.3-148
675 IAC 22-2.2-437.5	675 IAC 22-2.3-148.5
675 IAC 22-2.2-437.7	675 IAC 22-2.3-237.5
675 IAC 22-2.2-443.5	675 IAC 22-2.3-298.5
675 IAC 22-2.2-540	675 IAC 22-2.3-304.5

SECTION 1. 675 IAC 22-2.3-29.5 IS ADDED TO READ AS FOLLOWS:

**675 IAC 22-2.3-29.5 Section 308.3.6; Group A occupancies**

**Authority:** IC 22-13-2-2; IC 22-13-2-13

**Affected:** IC 22-12; IC 22-13; IC 22-14; IC 22-15; IC 36-7; IC 36-8

**Sec. 29.5. Amend Section 308.3.6 as follows:**

**(1) Delete the section heading “Group A Occupancies” and insert “Affected Occupancies”.**

**(2) In the first sentence, delete “a Group A Occupancy” and insert “any occupancy other than all Group “R” occupancies”.**  
*(Fire Prevention and Building Safety Commission; 675 IAC 22-2.3-29.5; filed Mar 21, 2005, 9:15 a.m.: 28 IR 2369)*

SECTION 2. 675 IAC 22-2.3-35.5 IS ADDED TO READ AS FOLLOWS:

**675 IAC 22-2.3-35.5 Section 315.2.1; ceiling clearance**

**Authority:** IC 22-13-2-2; IC 22-13-2-13

**Affected:** IC 22-12; IC 22-13; IC 22-14; IC 22-15; IC 36-7; IC 36-8

**Sec. 35.5. Add an exception to Section 315.2.1 as follows: EXCEPTION: Sidewall storage to a maximum depth of thirty (30) inches (seventy-six and two-tenths (76.2) centimeters) of in-rack storage shall be acceptable to the ceiling.** *(Fire Prevention and Building Safety Commission; 675 IAC 22-2.3-35.5; filed Mar 21, 2005, 9:15 a.m.: 28 IR 2370)*

SECTION 3. 675 IAC 22-2.3-36 IS AMENDED TO READ AS FOLLOWS:

**675 IAC 22-2.3-36 Section 316; outdoor carnivals and fairs**

**Authority:** IC 22-13-2-2; IC 22-13-2-13

**Affected:** IC 22-12; IC 22-13; IC 22-14; IC 22-15; IC 36-7; IC 36-8

Sec. 36. ~~Add~~ **Change** Section 316 Outdoor Carnivals and Fairs to read as follows: SECTION 316. CARNIVALS AND FAIRS

316.1 General. The grounds of carnivals and fairs, including concession booths, shall be in accordance with Section 316.

316.2 Grounds.

316.2.1 General. Grounds shall be in accordance with Section 316.2.

316.2.2 Access. Fire apparatus access roads shall be provided in accordance with Section 503.

316.2.3 Fire appliances.

316.2.3.1 General. Fire appliances shall be provided for the entire midway, as required by the chief.

316.2.3.2 Location. Maximum travel distance to a portable fire extinguisher shall not exceed seventy-five (75) feet (~~twenty-two thousand eight hundred sixty (22,860) mm~~): **(twenty-two and eighty-six hundredths (22.86) meters)**.

316.2.4 Electrical equipment. Electrical equipment and installations shall comply with the Electrical Code (675 IAC 17).

316.3 Concession Stands.

316.3.1 General. Concession stands shall be in accordance with Section 316.3.

316.3.2 Location. Concession stands utilized for cooking shall have a minimum of ten (10) feet (~~three thousand forty-eight (3,048) mm~~) **(three and forty-eight thousandths (3.048) meters)** of clearance on two (2) sides and shall not be located within ten (10) feet (~~three thousand forty-eight (3,048) mm~~) **(three and forty-eight thousandths (3.048) meters)** of amusement rides or devices.

316.3.3 Fire extinguishers. A 40-B:C-rated dry chemical fire extinguisher shall be provided where deep-fat fryers are used.

**316.3.4 Hinges, awnings, and braces must be safety keyed. Nails shall not be used for hinge or support pins.**

**316.3.5 When tent stakes and ropes extend into traffic areas, highly visible covers shall be provided.**

316.4 Internal Combustion Power Sources.

316.4.1 General. Internal combustion power sources, including motor vehicles, generators, and similar equipment, shall be in accordance with Section 316.4.

~~315.4.2~~ **316.4.2 Fueling.** Fuel tanks shall be of adequate capacity to permit uninterrupted operation during normal operating hours. Refueling shall be conducted only when the ride is not in use.

316.4.3 Protection. Internal combustion power sources shall be isolated from contact with the public by either physical guards, fencing, or an enclosure.

316.4.4 Fire extinguishers. A minimum of one (1) fire extinguisher with a rating of not less than 2-A:10-B:C shall be provided.

**316.4.5 Notification.** The servicing fire department shall be notified not less than seventy-two (72) hours prior to the admission of the public.

**316.4.6 Vehicular traffic.** No vehicle except emergency fire or rescue equipment shall be permitted on the midway from the time the midway opens until closing (including owners, operators, vendors, and service vehicles). *(Fire Prevention and Building Safety Commission; 675 IAC 22-2.3-36; filed Apr 17, 2003, 5:00 p.m.: 26 IR 2972; filed Mar 21, 2005, 9:15 a.m.: 28 IR 2370)*

SECTION 4. 675 IAC 22-2.3-36.3 IS ADDED TO READ AS FOLLOWS:

**675 IAC 22-2.3-36.3 Section 317; haunted houses and similar temporary installations**

**Authority:** IC 22-13-2-2; IC 22-13-2-13

**Affected:** IC 22-12; IC 22-13; IC 22-14; IC 22-15; IC 36-7; IC 36-8

Sec. 36.3. **Add** Section 317 Haunted Houses and Similar Temporary Installations to read as follows: SECTION 317 HAUNTED HOUSES AND SIMILAR TEMPORARY INSTALLATIONS

This section applies to haunted houses and similar installations set up for temporary use, not exceeding ninety (90) days. Any interior within a structure not designed for this specific use shall comply with the following and all other applicable rules:

(1) In any facility using the maze concept, there shall be no dead-end corridors and there shall be an obvious exit out of the maze for every fifty (50) feet (fifteen and twenty-four hundredths (15.24) meters) of linear travel. All stairways shall be illuminated at a level of at least one (1) foot-candle (eleven (11) lux).

(2) A group shall consist of twenty (20) individuals or fewer. Each group shall be accompanied or supervised by a staff person who is eighteen (18) years of age or older. This staff person shall have in his or her possession an operable flashlight and shall be completely familiar with the facility.

- (3) There shall be no smoking allowed at any time by anyone inside the building.
- (4) All electrical installations shall meet 675 IAC 17, the Indiana Electrical Code.
- (5) The servicing fire department shall be contacted at least three (3) working days prior to the placing of the facility in operation for an inspection and planning of evacuation procedures. A sketch of the floor plan shall be provided to the servicing fire department to facilitate these procedures.
- (6) The total number of occupants in the facility at any time shall be limited to the number allowed by the total exits from the installation, as determined by the Indiana Building Code (675 IAC 13) in effect at the time of construction of the building, building system, or alterations.
- (7) Fire extinguishers shall be distributed throughout the building so that no more than seventy-five (75) feet (twenty-two and eighty-six hundredths (22.86) meters) must be traversed to each fire extinguisher.
- (8) There shall be no open flame devices or temporary heaters used in the building.
- (9) Automatic smoke detectors shall be installed in accordance with NFPA 72 (675 IAC 22-2.2). All smoke detectors shall be interconnected so that when one is activated, all are activated. When activated, the alarm shall be loud enough to be heard over all other sounds or the activation shall automatically shut down all sound devices within the facility.
- (10) All areas of a maze shall be at least three (3) feet (ninety-one and four-tenths (91.4) centimeters) wide and five (5) feet (one and five hundred twenty-four thousandths (1.524) meters) high, except that a section not exceeding four (4) feet (one and twenty-two hundredths (1.22) meters) in length may be two (2) feet (sixty and ninety-six hundredths (60.96) centimeters) high and two (2) feet (sixty and ninety-six hundredths (60.96) centimeters) wide. There shall not be more than one (1) such four (4) foot (one and twenty-two hundredths (1.22) meter) section in every fifty (50) linear feet (fifteen and twenty-four hundredths (15.24) meters).
- (11) All material used in all display areas of a haunted house and all material used in the construction of a maze shall be inherently flame-resistant or made so by treatment with a flame retardant. All substances used to make materials flame-resistant shall be applied in accordance with the manufacturer's instructions, and the containers and proof of purchase of the substances shall be retained for inspection by the code official.

*(Fire Prevention and Building Safety Commission; 675 IAC 22-2.3-36.3; filed Mar 21, 2005, 9:15 a.m.: 28 IR 2370)*

SECTION 5. 675 IAC 22-2.3-36.4 IS ADDED TO READ AS FOLLOWS:

**675 IAC 22-2.3-36.4 Section 318; fire safety in racetrack stables**

**Authority:** IC 22-13-2-2; IC 22-13-2-13

**Affected:** IC 22-12; IC 22-13; IC 22-14; IC 22-15; IC 36-7; IC 36-8

**Sec. 36.4. Add Section 318 Fire Safety in Racetrack Stables to read as follows: SECTION 318 FIRE SAFETY IN RACETRACK STABLES**

**318.1 Scope.** Racetrack stables shall be in accordance with this section.

**318.2 Definitions**

For purposes of this section, the following definitions apply:

**ASSIGNED BARN.** The barn area where a trainer has been allocated stalls and space for the trainer's horses and equipment.

**ASSISTANT TRAINER.** The person next to the listed trainer of record, and the one who frequently handles the day-to-day affairs in training a horse or horses.

**CONCESSIONAIRES.** The holders of a concession, such as the track kitchen, granted by the racetrack management.

**HALTER.** Piece of equipment that fits around a horse's head, like a bridle, but lacking a bit. It is used in handling horses around the stable. In the event of a fire, horses can be led from stalls by halters.

**MECHANICAL HOTWALKER.** An electrical device that automatically walks a horse or several horses in a circle with an approximate radius of ten (10) to fifteen (15) feet (three and forty-eight thousandths (3.048) to four and fifty-seven hundredths (4.57) meters).

**MIXED OCCUPANCY.** A building or stable area where both horses and humans reside.

**RACETRACK MANAGEMENT.** The persons who control or execute the affairs of the track itself.

**TACK.** Stable gear; also rider's racing equipment.

**TACK ROOM.** A storage area for tack and stable equipment.

**TRACK SECURITY.** Persons employed to protect racetrack property and to ensure the proper passage of licensed personnel; track security may be internal or external.

**TRAINER.** The person responsible for the care and training of a horse or horses.

**318.3 Management responsibilities.**

**318.3.1 All trainers or a designated assistant and all concessionaires or a designated assistant shall serve as liaison between the track security and fire protection supervisors and the employees of the trainers and concessionaires.**

**318.3.2 All trainers or their assistants and all concessionaires or their assistants shall acquaint themselves with and brief their employees as to the following:**

- (1) Smoking regulations.**
- (2) Location of fire alarm notification system devices in the immediate area of an assigned barn.**
- (3) Location of all fire extinguishers and extinguishing equipment in assigned barn area.**
- (4) Regulations regarding occupancy, use of extension cords for extending electrical circuits, and use of electrical appliances.**
- (5) Regulations regarding storage and use of feed, straw, tack, and supplies.**
- (6) Track regulations with regard to fire and security, copies of which shall be provided to all trainers or their assistants and concessionaires or their assistants. These regulations shall be used in instructing members of the trainers' and concessionaires' staffs assigned to the barn area.**

**318.3.3 Open burning. Open burning is prohibited. Open flame heating devices are prohibited. Unvented portable oil-burning heating appliances are not permitted in stables.**

**318.3.4 Smoking. Smoking is prohibited in assigned barns. Approved "No Smoking" signs shall be posted in assigned barns.**

**318.3.5 Trash removal. All combustible trash and waste shall be removed from all buildings daily. Noncombustible trash and waste containers shall be provided for other than stall waste and shall be emptied daily.**

**318.3.6 Hay or straw storage. Storage shall not exceed the amount for two (2) days' use by the horses in the assigned barn. All other hay and straw must be in a separate, approved outside storage area. Hay and straw piles shall not exceed twenty (20) bales (rectangular) per pile and shall not exceed seven (7) feet (two and thirteen-hundredths (2.13) meters) in height. Each pile must be separated by a distance of not less than fifty (50) feet (fifteen and twenty-four hundredths (15.24) meters). Hay and straw shall not be stored in aisle space or in aisles.**

**318.3.7 Electrical systems and appliances.**

**318.3.7.1 The use of any portable electrical appliance shall be as follows:**

- (1) Multiple-outlet adapters are prohibited.**
- (2) Not more than one (1) continuous extension cord shall be used to connect one (1) appliance to the fixed electrical receptacle, and such cord shall be listed for hard service and properly sized for the intended application.**
- (3) Extension cords shall not be used as a substitute for permanent wiring.**

**318.3.7.2 Extension cords shall not be supported by any metal object, such as a nail, screw, hook, or pipe.**

**318.3.7.3 Plug caps and receptacles used in extension cords shall be heavy-duty type equipped with a reliable grounding pole and attached to the cord in a manner to provide strain relief.**

**318.3.7.4 All electrical appliances used in the stable area shall be listed for the use.**

**318.3.7.5 Outdoor electrical appliances, for example, mechanical hotwalkers, served by the barn electrical system shall be installed in accordance with the Indiana Electrical Code (675 IAC 17).**

**318.3.7.6 Portable cooking and heating appliances shall not be used in assigned barns.**

**318.3.7.7 Use of exposed-element heating appliances is prohibited.**

**318.3.7.8 The storage of flammable and combustible liquids, except those used for medicinal purposes, is prohibited.**

**318.3.7.9 Vehicles shall not be permitted in assigned barns. Aisles shall be maintained clear of obstructions at all times, and access to fire equipment shall not be blocked.**

**318.4 Animal evacuation.**

**318.4.1 Every horse shall wear a halter at all times while inside the assigned barn.**

**318.4.2 Horses shall be restricted to ground level stalls.**

**318.4.3 An assigned barn escape plan shall be established for each stable building.**

**318.4.4 The assigned barn escape plan shall be posted by each exit from the assigned barn, and a copy shall be given to all stall renters.**

**318.4.5 A fire safety and evacuation drill shall be conducted quarterly for employees only.**

**318.4.6 A predetermined location shall be designated for placement of horses when they are evacuated from the assigned barns.**

**318.4.7 Racetrack management shall ensure that all employees are trained in the assigned barn escape plan.**

**318.5 Where automatic sprinklers are installed, they shall be installed, tested, and maintained in accordance with the applicable rules of the commission.**

**318.6 Fire extinguishers shall be provided in all assigned barns as follows:**

- (1) Fire extinguishers shall have a minimum 2A rating.**
- (2) Fire extinguishers shall be placed so that travel distance shall be not more than seventy-five (75) feet (twenty-two and**

eighty-six hundredths (22.86) meters) from any point within a building.

(3) Fire extinguishers within twenty (20) feet (six and ninety-six thousandths (6.096) meters) of electrical control boxes shall have a Class C rating.

(4) Fire extinguishers shall be installed, tested, and maintained in accordance with the applicable rules of the commission.

*(Fire Prevention and Building Safety Commission; 675 IAC 22-2.3-36.4; filed Mar 21, 2005, 9:15 a.m.: 28 IR 2371)*

SECTION 6. 675 IAC 22-2.3-36.6 IS ADDED TO READ AS FOLLOWS:

**675 IAC 22-2.3-36.6 Section 403.3; fire watch**

**Authority:** IC 22-13-2-2; IC 22-13-2-13

**Affected:** IC 22-12; IC 22-13; IC 22-14; IC 22-15; IC 36-7; IC 36-8

**Sec. 36.6. Add a new Section 403.3 Fire Watch to read as follows: Whenever it is essential for public safety in any Class 1 structure, due to the number of persons or the nature of the activity being conducted, the chief may require the owner or lessee to employ one (1) or more qualified persons, to be approved by the chief, to be on duty in such Class 1 structure to serve as a fire watch. Such persons shall:**

**(1) be subject to the chief's orders at all times;**

**(2) be in uniform; and**

**(3) remain on duty at all times that such Class 1 structure is open to the public.**

**Such persons shall not be required or permitted, while on duty, to perform any duties other than the fire watch. Such persons shall be provided at the ratio of one (1) qualified person per five hundred (500) occupant load.** *(Fire Prevention and Building Safety Commission; 675 IAC 22-2.3-36.6; filed Mar 21, 2005, 9:15 a.m.: 28 IR 2372)*

SECTION 7. 675 IAC 22-2.3-36.8 IS ADDED TO READ AS FOLLOWS:

**675 IAC 22-2.3-36.8 Section 403.4; overcrowding**

**Authority:** IC 22-13-2-2; IC 22-13-2-13

**Affected:** IC 22-12; IC 22-13; IC 22-14; IC 22-15; IC 36-7; IC 36-8

**Sec. 36.8. Add a new Section 403.4 Overcrowding to read as follows: Section 403.4 Overcrowding**

**Overcrowding and admittance of persons beyond the approved occupant load are prohibited. The code official, upon finding:**

**(1) overcrowding conditions or obstructions in aisles, corridors, or other means of egress; or**

**(2) a condition that constitutes a serious menace to life;**

**is authorized to cause all activities in the room or space to cease until such overcrowding, obstructions, or conditions are corrected. The code official is also authorized to order the evacuation of the building, if necessary, to eliminate the overcrowding.** *(Fire Prevention and Building Safety Commission; 675 IAC 22-2.3-36.8; filed Mar 21, 2005, 9:15 a.m.: 28 IR 2373)*

SECTION 8. 675 IAC 22-2.3-140.5 IS ADDED TO READ AS FOLLOWS:

**675 IAC 22-2.3-140.5 Section 1003.3.1.3.4; access-controlled egress doors**

**Authority:** IC 22-13-2-2; IC 22-13-2-13

**Affected:** IC 22-12; IC 22-13; IC 22-14; IC 22-15; IC 36-7; IC 36-8

**Sec. 140.5. Delete Section 1003.3.1.3.4 without substitution.** *(Fire Prevention and Building Safety Commission; 675 IAC 22-2.3-140.5; filed Mar 21, 2005, 9:15 a.m.: 28 IR 2373)*

SECTION 9. 675 IAC 22-2.3-147.5 IS ADDED TO READ AS FOLLOWS:

**675 IAC 22-2.3-147.5 Section 1005.3.2.2**

**Authority:** IC 22-13-2-2; IC 22-13-2-13

**Affected:** IC 22-12; IC 22-13; IC 22-14; IC 22-15; IC 36-7; IC 36-8

**Sec. 147.5. Delete the last sentence of Section 1005.3.2.2 and insert the following: The open space under exit stairways shall not be used for any purpose.** *(Fire Prevention and Building Safety Commission; 675 IAC 22-2.3-147.5; filed Mar 21, 2005, 9:15 a.m.: 28 IR 2373)*

SECTION 10. 675 IAC 22-2.3-147.6 IS ADDED TO READ AS FOLLOWS:

**675 IAC 22-2.3-147.6 Section 1005.3.7; fire escapes**

**Authority:** IC 22-13-2-2; IC 22-13-2-13

**Affected:** IC 22-12; IC 22-13; IC 22-14; IC 22-15; IC 36-7; IC 36-8

**Sec. 147.6. Add Section 1005.3.7 Fire escapes to read as follows: Section 1005.3.7 Fire escapes**

**A fire escape that is used as an exit shall comply with the provisions of this section as follows:**

**(1) The fire escape shall not be the primary or the only exit.**

**(2) The fire escape shall not take the place of stairways required by the applicable rules of the commission or its predecessors in effect at the time the building was built.**

**(3) Access to a fire escape from a corridor shall not be through an intervening room.**

**EXCEPTION:** Access through an intervening room may be permitted if the intervening door is not lockable and an exit sign is installed above the door directing occupants to the fire escape.

**(4) No encumbrances or obstacles of any kind shall be placed on or in front of any fire escape.**

**(5) Fire escapes shall be kept clear and unobstructed and shall be maintained in a fully operational working condition at all times.**

**(6) Exit signs shall be maintained in accordance with the Indiana Fire Code, 675 IAC 22, or the code in effect at the time of construction. All doors and windows providing access to a fire escape shall be provided with signs stating "FIRE ESCAPE" in letters at least as large as those required for exit signs under the current rules of the commission.**

**(7) Fire escape stairways and their balconies shall support their dead load plus a live load of not less than one hundred (100) pounds per square foot (four hundred eighty-eight (488) kilograms per square meter) or a concentrated load of three hundred (300) pounds (one hundred thirty-six (136) kilograms) placed anywhere on the balcony or stairway so as to produce the maximum stress condition.**

**(8) Fire escape stairways and balconies shall be provided with a top and intermediate handrail on the open side. All stair and balcony railings shall support a horizontal force of not less than fifty (50) pounds per linear foot (seventy-four and four-tenths (74.4) kilograms per meter) applied to the top handrail.**

**(9) Documentation evidencing compliance with subsections (7) and (8) shall be maintained on site for review by the code official.**

**(10) Tubular fire escapes shall comply with subsections (1) through (9) and shall be kept rust free.**

*(Fire Prevention and Building Safety Commission; 675 IAC 22-2.3-147.6; filed Mar 21, 2005, 9:15 a.m.: 28 IR 2373)*

SECTION 11. 675 IAC 22-2.3-148 IS AMENDED TO READ AS FOLLOWS:

**675 IAC 22-2.3-148 Section 1008.10; seat stability**

**Authority:** IC 22-13-2-2; IC 22-13-2-13

**Affected:** IC 22-12; IC 22-13; IC 22-14; IC 22-15; IC 36-7; IC 36-8

**Sec. 148. In Section 1008.10 Seat stability:**

**(1) in Exception 3, after "less than three", insert "tied or staked to the floor"; and**

**(2) delete the last sentence of Exception 4.**

*(Fire Prevention and Building Safety Commission; 675 IAC 22-2.3-148; filed Apr 17, 2003, 5:00 p.m.: 26 IR 2986; filed Mar 21, 2005, 9:15 a.m.: 28 IR 2374)*

SECTION 12. 675 IAC 22-2.3-148.5 IS ADDED TO READ AS FOLLOWS:

**675 IAC 22-2.3-148.5 Section 1008.10.1; chairs and benches**

**Authority:** IC 22-13-2-2; IC 22-13-2-13

**Affected:** IC 22-12; IC 22-13; IC 22-14; IC 22-15; IC 36-7; IC 36-8

**Sec. 148.5. Add subsection 1008.10.1 Chairs and benches to read as follows: 1008.10.1 Chairs and benches**

**Chairs and benches used on raised stands or platforms shall be secured to the stands or platforms upon which they are placed.** *(Fire Prevention and Building Safety Commission; 675 IAC 22-2.3-148.5; filed Mar 21, 2005, 9:15 a.m.: 28 IR 2374)*

SECTION 13. 675 IAC 22-2.3-237.5 IS ADDED TO READ AS FOLLOWS:

**675 IAC 22-2.3-237.5 Section 2416.1; crowd managers**

**Authority:** IC 22-13-2-2; IC 22-13-2-13

**Affected:** IC 22-12; IC 22-13; IC 22-14; IC 22-15; IC 36-7; IC 36-8

**Sec. 237.5. Delete Section 2416.1 without substitution.** (*Fire Prevention and Building Safety Commission; 675 IAC 22-2.3-237.5; filed Mar 21, 2005, 9:15 a.m.: 28 IR 2374*)

SECTION 14. 675 IAC 22-2.3-298.5 IS ADDED TO READ AS FOLLOWS:

**675 IAC 22-2.3-298.5 Section 3404.3.2.3; number of storage cabinets**

**Authority:** IC 22-13-2-2; IC 22-13-2-13

**Affected:** IC 22-12; IC 22-13; IC 22-14; IC 22-15; IC 36-7; IC 36-8

**Sec. 298.5. Delete Section 3404.3.2.3 without substitution.** (*Fire Prevention and Building Safety Commission; 675 IAC 22-2.3-298.5; filed Mar 21, 2005, 9:15 a.m.: 28 IR 2374*)

SECTION 15. 675 IAC 22-2.3-304.5 IS ADDED TO READ AS FOLLOWS:

**675 IAC 22-2.3-304.5 Section 3405.3.7.5.3; spill control and secondary containment**

**Authority:** IC 22-13-2-2; IC 22-13-2-13

**Affected:** IC 22-12; IC 22-13; IC 22-14; IC 22-15; IC 36-7; IC 36-8

**Sec. 304.5. Change the first sentence of Section 3405.3.7.5.3 to read as follows: Spill control shall be provided in accordance with Section 3403.4 where Class I, II, or IIIA liquids are dispensed into containers exceeding a two (2) gallon (seven and six-tenths (7.6) liter) capacity or mixed or used in open containers or systems exceeding five and three-tenths (5.3) gallon (twenty (20) liter) capacity.** (*Fire Prevention and Building Safety Commission; 675 IAC 22-2.3-304.5; filed Mar 21, 2005, 9:15 a.m.: 28 IR 2374*)

SECTION 16. THE FOLLOWING ARE REPEALED: 675 IAC 22-2.2-49.5; 675 IAC 22-2.2-134.5; 675 IAC 22-2.2-183; 675 IAC 22-2.2-221.5; 675 IAC 22-2.2-245.2; 675 IAC 22-2.2-245.5; 675 IAC 22-2.2-365.2; 675 IAC 22-2.2-365.5; 675 IAC 22-2.2-369.5; 675 IAC 22-2.2-378.5; 675 IAC 22-2.2-412.5; 675 IAC 22-2.2-437.5; 675 IAC 22-2.2-437.7; 675 IAC 22-2.2-443.5; 675 IAC 22-2.2-540.

*LSA Document #04-56(F)*

*Notice of Intent Published: April 1, 2004; 27 IR 2303*

*Proposed Rule Published: June 1, 2004; 27 IR 2859*

*Hearing Held: August 17, 2004 AND January 4, 2005*

*Approved by Attorney General: February 23, 2005*

*Approved by Governor: March 17, 2005*

*Filed with Secretary of State: March 21, 2005, 9:15 a.m.*

*IC 4-22-7-5(c) Notice from Secretary of State Regarding Documents Incorporated by Reference: None Received by Publisher*