Retail Food Inspection Report

Floyd County Health Department
Telephone (812) 948-4726

Establishment Name	Telephone Number	Date of Inspection	ID#
STARBUCKS COFFEE #6670	Est	03/01/2023	
Address 4401 CHARLESTOWN RD, NEW ALBANY IN 47150	Own		

Owner	Purpose	Follow Up	Released
STARBUCKS COFFEE	___Routine		03/11/2023
Owner's Address PO BOX 34442-TAX2 SEATTLE, WA 98124	___Follow-up		
Person in Charge DANA BIDDLE/BRAD ESTES	___Complaint		
	X Pre-Operational		
Responsible Person's Email US36898531@GMAIL.COM	___Temporary	**Menu Type**	
	___HACCP	1 X 2 __ 3 __ 4 __ 5 __	
Certified Food Handler	___Other (list)		

CRITICAL ITEMS ARE IDENTIFIED IN THE CHECKLIST AND NARRATIVE COLUMNS MARKED "C"
VIOLATION(S) REPEATED FROM PREVIOUS INSPECTIONS ARE DENOTED IN THE "SUMMARY OF VIOLATIONS" AND IN THE NARRAIVE COLUMN MARKED AS "R"

Section #	C	NC	R	Narrative	To Be Corrected
NOTE		X		No violations. NOTE: The way the sanitizer is hooked up to the mop sink faucet makes the line under pressure. Having an AVB alone will not work and the mop sink will need a PVB.	

Summary of Violations C 0 NC 1 R 0 1

Received by (name and title printed):	Inspected by (name and title printed):
DANA BIDDLE/BRAD ESTES	Christa Manus EHS
Received by (signature):	Inspected by (signature): Christa L Manus

cc:	cc:	cc: