Floyd County Health Department Telephone (812) 948-4726

					-			
Establishment Nam BURGER KING #8				Telephone Number Est 812/949-2803		Date of Inspection	ID#	
Address 2309 STATE STREET, NEW ALBANY IN 47150					Own 315-424-0513		03/14/2024	
Owner CARROLS LLC					Purpose <u>X</u> Routi	ne	Follow Up	Released 03/14/2024
Owner's Address 968 JAMES STREET SYRACUSE, NY 13203-					Follo Com	-		
Person in Charge JOSHUA STRUNK						perational		
Responsible Person's Email THEDINGER@CARROLS.COM					Temporary HACCP		Menu Type 1 _ 2 _ 3 <u>X</u> 4 _ 5 _	
Certified Food Handler HEATHER DIBENDETTO ANDREW MCCOY TERRI SIMPSON					Other	· (list)		
CRITICAL ITEMS ARE IDENTIFIED IN THE CHECKLIST AND NARRATIVE COLUMNS MARKED "C" VIOLATION(S) REPEATED FROM PREVIOUS INSPECTIONS ARE DENOTED IN THE "SUMMARY OF VIOLATIONS" AND IN THE NARRAIVE COLUMN MARKED AS "R"								
Section #	ction # C NC R Narrative						To Be Co	orrected
294	×		Corrected: Perso Observed the mo Atmospheric Va recommends ins	nary ammonium sanitize on in charge had the sanit op sink faucet had a line cuum breaker on the fau stalling a bleeder valve to hoses may also be discor	izer drained and to a chemical dis cet is not designe the faucet or co	refilled. spenser with the ed for constant pr nnecting the disp	faucets left on. The ressure. FCHD penser to an independe	
Summary of Violati	ions	С	<u>1</u> NC	<u>0</u> R <u>0</u>			1	
Received by (name a TYLER HEDINGE	orinted)	:	Inspected by (name and title printed): Carrie Fischer EHS					
Received by (signate				Inspected by (signature):				
cc: cc:							сс:	
							;	