Retail Food Inspection Report

Floyd County Health Department
Telephone (812) 948-4726

Establishment Name	Telephone Number	Date of Inspection	ID#
GOODBOWL / PLUCK'D	Est	02/20/2025	
Address 2441 STATE ST, NEW ALBANY IN 47150	Own		
Owner	**Purpose**	**Follow Up**	**Released** 03/02/2025
Owner's Address ,	___ Routine ___ Follow-up		
Person in Charge BEAU KERLEY	___ Complaint _X_ Pre-Operational		
Responsible Person's Email	___ Temporary ___ HACCP	**Menu Type** 1 _X_ 2 __ 3 __ 4 __ 5 __	
Certified Food Handler	___ Other (list)		

CRITICAL ITEMS ARE IDENTIFIED IN THE CHECKLIST AND NARRATIVE COLUMNS MARKED "C"
VIOLATION(S) REPEATED FROM PREVIOUS INSPECTIONS ARE DENOTED IN THE "SUMMARY OF VIOLATIONS" AND IN THE NARRAIVE COLUMN MARKED AS "R"

Section #	C	NC	R	Narrative	To Be Corrected
324		X		Observed missing drain pipes on the restroom sinks in the men's room.	BEFORE OPENING
411		X		Measured lighting in the back prep area of the kitchen at 20 FC of light. 60 FC is required in areas of food prep.	2-27-25
295		X		Observed rust and chipping paint on wire storage racks in the walkin cooler and near the walkin in the prep area.	before used

GOODBOWL COUNTERTOPS ARE TO BE SEALED WITH MINERAL OIL. IF THIS BECOMES INSUFFICENT AND THEY CAN'T BE MAINTAINED CLEAN. A DIFFERENT SEALANT MAY BE NEEDED. THE GOODBOWL SIDE IS PERMITTED TO OPEN. A SECOND PRE-OP INSPECTION IS NEED BEFORE PLUCK'D MAY OPEN.

Summary of Violations C 0 NC 3 R 0 **3**

Received by (name and title printed):	Inspected by (name and title printed):
BEAU KERLEY	Thomas Snider CFS
Received by (signature):	Inspected by (signature):

cc:	cc:	cc: