

◆ ◆ ◆ **REQUIRED INSPECTIONS** ◆ ◆ ◆

Decks

1. **FOOTER INSPECTION:** After holes are dug, prior to setting the posts, pre-fab columns or pouring for wet-sets. Posts must have treated 2x6 uplift blocks on 2 opposite sides at the bottom of the hole. (Post holes must be below frost line – 36” or to design requirements. Posts must be supported on 14” minimum diameter concrete cookies 6” thick or equivalent (ex: poured concrete or concrete mix). Engineered pads are also acceptable.
2. **FRAMING AND FINAL INSPECTION FOR DECKS:** Can be done at the same time after deck is complete with railings and steps. For more detail on building codes for decks please request “Noble County Building Department Deck Requirements Handout.”

◆ ◆ ◆ **A TWENTY-FOUR (24) HOUR NOTICE IS REQUIRED ON ALL INSPECTIONS.** ◆ ◆ ◆