



“REGULAR” TENTS

Use this section to answer the following questions:

- ... What code section requires a tent in excess of 400 sq. ft. to meet everything in Chapter 31 ?
- ... May a charcoal grill be used for cooking in a tent which is in excess of 400 sq. ft. ?
- ... May a coffee pot and a pop corn machine be used in a tent which is in excess of 400 sq. ft. ?

SCOPE

TENTS



**THIS GROUP HAS TO COMPLY
WITH EVERYTHING IN CH. 31**

IN EXCESS OF 400 SQ. FT.





FT

OPEN OR EXPOSED FLAME

Amendment; LSA Doc. # 13 - 341 (F)
675 IAC 22 - 2.5 (eff. 12 - 01 - 14)

- THIS SCENARIO IS A “REGULAR” TENT; IN EXCESS OF 400 SQ. FT.
- WITH “NO OPEN FLAME” EQUIPMENT INSIDE THE TENT
- THE “NO OPEN FLAME” EQUIPMENT IS OK IN THE TENT
- BECAUSE SEC. 3104.7 DOES NOT APPLY TO THIS TYPE OF EQUIPMENT



COOKING TENTS

**Amendment; LSA Doc. # 13 - 341 (F)
675 IAC 22 - 2.5 (eff. 12 - 01 - 14)**

- **BECAUSE THIS TENT DOES NOT HAVE SIDEWALLS OR DROPS**
- **SEC. 3104.15.5 DOES NOT APPLY TO THIS SCENARIO**
- **THEREFORE, THERE IS NO SEPARATION DISTANCE**
- **BETWEEN THIS TENT AND OTHER TENTS OR MEMBRANE ...**



LOCATION

**Amendment; LSA Doc. # 13 - 341 (F)
675 IAC 22 - 2.5 (eff. 12 - 01 - 14)**

- BECAUSE THIS IS A “REGULAR” TENT, THERE IS ONE MORE CODE SECTION TO STUDY
- SEC. 3103.8.2, EXCEPTION 1, *LOCATION*, IS APPLICABLE TO THIS TENT
- AS LONG AS THE FLOOR AREA OF THIS TENT DOES NOT EXCEED 15,000 SQUARE FEET, AND



LOCATION

**Amendment; LSA Doc. # 13 - 341 (F)
675 IAC 22 - 2.5 (eff. 12 - 01 - 14)**

- **AS LONG AS “OPEN OR EXPOSED FLAME” EQUIPMENT IS NOT USED (IN THIS SCENARIO THAT IS TRUE)**
- **THERE IS NO SEPARATION DISTANCE BETWEEN THIS TENT AND LOT LINES, BUILDINGS,**
- **OTHER TEMP MEMBRANE STRUCTURES, OTHER TENTS, PARKED VEHICLES OR INTERNAL COMBUSTION ENGINES**



SUMMARY: the following code sections govern this scenario

■ **Sec. 3101.1 – Scope**

■ **Sec. 3102.1 – Definitions**

→ Cooking.

■ **Sec. 3103.8.2, Excp. 1 – Location**

→ Applicable to this scenario.

■ **Sec. 3104.7 – Open or exposed flame**

→ Not applicable to this type of cooking.

■ **Sec. 3104.15.5 – Cooking tents**

→ Not applicable because there are no sidewalls or drops.


■ **Sec. 3104.15.6 – Outdoor cooking**

→ Not applicable because this is not outdoor cooking.




“NO OPEN FLAME” EQUIPMENT
UNDER A “REGULAR” TENT

SUMMARY: COOKING TENTS





SUMMARY: LOCATION



THE "NO OPEN FLAME"
EQUIPMENT IS
PERMITTED UNDER
THE TENT.

THE AREA OF THIS
TENT IS IN EXCESS OF 400
SQUARE FEET AND
DOES NOT EXCEED 15,000
SQUARE FEET



**THERE IS NO SEPARATION DISTANCE BETWEEN
THIS TENT AND THE OTHER ITEMS**



FT

OPEN OR EXPOSED FLAME

Amendment; LSA Doc. # 13 - 341 (F)
675 IAC 22 - 2.5 (eff. 12 - 01 - 14)

- THIS SCENARIO IS A “REGULAR” TENT; IN EXCESS OF 400 SQ. FT.
- WITH “NO OPEN FLAME” EQUIPMENT INSIDE THE TENT
- THE “NO OPEN FLAME” EQUIPMENT IS OK IN THE TENT
- BECAUSE SEC. 3104.7 DOES NOT APPLY TO THIS TYPE OF EQUIPMENT



COOKING TENTS

**Amendment; LSA Doc. # 13 - 341 (F)
675 IAC 22 - 2.5 (eff. 12 - 01 - 14)**

- **BECAUSE THIS TENT HAS
SIDEWALLS OR DROPS**
- **SEC. 3104.15.5 APPLIES
TO THIS SCENARIO**
- **THERE IS A MINIMUM SEPARATION
DISTANCE OF 10 FEET**
- **BETWEEN THIS TENT AND OTHER
TENTS OR MEMBRANE ...**



LOCATION

Amendment; LSA Doc. # 13 - 341 (F)
675 IAC 22 - 2.5 (eff. 12 - 01 - 14)

- BECAUSE THIS IS A “REGULAR” TENT, THERE IS ONE MORE CODE SECTION TO STUDY
- SEC. 3103.8.2, EXCEPTION 1, *LOCATION*, IS APPLICABLE TO THIS TENT
- AS LONG AS THE FLOOR AREA OF THIS TENT DOES NOT EXCEED 15,000 SQUARE FEET, AND



LOCATION

**Amendment; LSA Doc. # 13 - 341 (F)
675 IAC 22 - 2.5 (eff. 12 - 01 - 14)**

- **AS LONG AS “OPEN OR EXPOSED FLAME” EQUIPMENT IS NOT USED (IN THIS SCENARIO THAT IS TRUE)**
- **THERE IS NO SEPARATION DISTANCE BETWEEN THIS TENT AND LOT LINES, BUILDINGS,**
- **PARKED VEHICLES OR INTERNAL COMBUSTION ENGINES. (NOTE: SEC. 3104.15.5 STILL APPLIES)**



SUMMARY: the following code sections govern this scenario

■ **Sec. 3101.1 – Scope**

■ **Sec. 3102.1 – Definitions**

→ Cooking.

■ **Sec. 3103.8.2, Excp. 1 – Location**

→ Applicable to this scenario.

■ **Sec. 3104.7 – Open or exposed flame**

→ Not applicable to this type of cooking.

■ **Sec. 3104.15.5 – Cooking tents**

→ There is a minimum separation distance of 10 feet.


■ **Sec. 3104.15.6 – Outdoor cooking**

→ Not applicable because this is not outdoor cooking.




“NO OPEN FLAME” EQUIPMENT
UNDER A “REGULAR” TENT

SUMMARY: COOKING TENTS




SUMMARY: LOCATION



THE “NO OPEN FLAME”
EQUIPMENT IS
PERMITTED UNDER
THE TENT.

THE AREA OF THIS
TENT IS IN EXCESS OF 400
SQUARE FEET AND
DOES NOT EXCEED 15,000
SQUARE FEET



**THERE IS NO SEPARATION DISTANCE BETWEEN
THIS TENT AND THE OTHER ITEMS**

V

FT



OPEN OR EXPOSED FLAME

V

Amendment; LSA Doc. # 13 - 341 (F)
675 IAC 22 - 2.5 (eff. 12 - 01 - 14)


- THIS SCENARIO IS A “REGULAR” TENT; IN EXCESS OF 400 SQ. FT.
- WITH “OPEN FLAME” EQUIPMENT INSIDE THE TENT
- THE “OPEN FLAME” EQUIPMENT MAY NOT OCCUR INSIDE THE TENT
- THIS SCENARIO IS A VIOLATION OF SEC. 3104.7, *OPEN OR EXPOSED FLAME*



OPEN OR EXPOSED FLAME

Amendment; LSA Doc. # 13 - 341 (F)
675 IAC 22 - 2.5 (eff. 12 - 01 - 14)


- THE “OPEN FLAME” EQUIPMENT, CHARCOAL GRILLS,
- MUST BE MOVED OUTSIDE OF THE TENT
- THE OPEN FLAME EQUIPMENT IS NOW OK IN THIS LOCATION, BUT
- THERE IS A MINIMUM SEPARATION DISTANCE REQUIREMENT



OPEN OR EXPOSED FLAME

Amendment; LSA Doc. # 13 - 341 (F)
675 IAC 22 - 2.5 (eff. 12 - 01 - 14)

- THERE IS A MINIMUM 10 FOOT SEPARATION DISTANCE
- BETWEEN THE OPEN FLAME OR OTHER DEVICES EMITTING
- FLAME, FIRE OR HEAT OR ANY FLAMMABLE OR COMBUSTIBLE, ETC.
- AND THE TENT OR MEMBRANE STRUCTURES WHILE OPEN TO THE PUBLIC



OPEN OR EXPOSED FLAME

Amendment; LSA Doc. # 13 - 341 (F)
675 IAC 22 - 2.5 (eff. 12 - 01 - 14)




THERE IS A REQUIRED SEPARATION DISTANCE OF 10 FT.

OUTDOOR COOKING



OUTDOOR COOKING THAT PRODUCES SPARKS OR GREASE – LADEN VAPORS SHALL NOT BE PERFORMED WITHIN 10 FEET OF A TENT OR A MEMBRANE STRUCTURE.

- THE 3 CODE SECTIONS AMENDED IN THE *SCOPE* ARE 3104.7, 3104.15.5 AND 3104.15.6
- THIS SPECIFIC SECTION, 3104.15.6 IS ONE OF THOSE LISTED IN THE *SCOPE*
- THIS SECTION REINFORCES THE SEPARATION DISTANCE OF 10 FEET FOUND IN SEC. 3104.7




THE GRILLS MUST BE 10 FEET FROM THE TENT

LOCATION

**Amendment; LSA Doc. # 13 - 341 (F)
675 IAC 22 - 2.5 (eff. 12 - 01 - 14)**


- **BECAUSE THIS IS A “REGULAR” TENT, THERE IS ONE MORE CODE SECTION TO STUDY**
- **SEC. 3103.8.2, EXCEPTION 1, *LOCATION*, IS APPLICABLE TO THIS TENT**
- **AS LONG AS THE FLOOR AREA OF THIS TENT DOES NOT EXCEED 15,000 SQUARE FEET, AND**



LOCATION

**Amendment; LSA Doc. # 13 - 341 (F)
675 IAC 22 - 2.5 (eff. 12 - 01 - 14)**

- **AS LONG AS “OPEN OR EXPOSED FLAME” EQUIPMENT IS NOT USED (THERE IS NO COOKING EQUIPMENT UNDER THE TENT)**
- **THERE IS NO SEPARATION DISTANCE BETWEEN THIS TENT AND LOT LINES, BUILDINGS, PARKED VEHICLES OR INTERNAL COMBUSTION ENGINES**



SUMMARY: the following code sections govern this scenario

■ **Sec. 3101.1 – Scope**

■ **Sec. 3102.1 – Definitions**

- Cooking.
- Open or exposed flame equipment.

■ **Sec. 3103.8.2, Excp. 1 – Location**

- Applicable to this scenario.

■ **Sec. 3104.7 – Open or exposed flame**


- Applicable to this type of cooking.

■ **Sec. 3104.15.5 – Cooking tents**

- Not applicable because the cooking equipment is not in the tent.


■ **Sec. 3104.15.6 – Outdoor cooking**

- Applicable to this type of cooking.




“OPEN OR EXPOSED FLAME” EQUIPMENT
OUTSIDE OF A “REGULAR” TENT

SUMMARY: COOKING TENTS



**THERE IS NO SEPARATION DISTANCE BETWEEN
THIS TENT AND THE OTHER TENTS**


SUMMARY: LOCATION



THERE IS NO COOKING
EQUIPMENT UNDER
THE TENT.



THE AREA OF THIS
TENT IS IN EXCESS OF 400
SQUARE FEET AND
DOES NOT EXCEED 15,000
SQUARE FEET



**THERE IS NO SEPARATION DISTANCE BETWEEN
THIS TENT AND THE OTHER ITEMS**

V

FT



OPEN OR EXPOSED FLAME

V

Amendment; LSA Doc. # 13 - 341 (F)
675 IAC 22 - 2.5 (eff. 12 - 01 - 14)


- THIS SCENARIO IS A “REGULAR” TENT; IN EXCESS OF 400 SQ. FT.
- WITH “OPEN FLAME” EQUIPMENT INSIDE THE TENT
- THE “OPEN FLAME” EQUIPMENT MAY NOT OCCUR INSIDE THE TENT
- THIS SCENARIO IS A VIOLATION OF SEC. 3104.7, *OPEN OR EXPOSED FLAME*



OPEN OR EXPOSED FLAME

Amendment; LSA Doc. # 13 - 341 (F)
675 IAC 22 - 2.5 (eff. 12 - 01 - 14)


- THE “OPEN FLAME” EQUIPMENT, CHARCOAL GRILLS,
- MUST BE MOVED OUTSIDE OF THE TENT
- THE OPEN FLAME EQUIPMENT IS NOW OK IN THIS LOCATION, BUT
- THERE IS A MINIMUM SEPARATION DISTANCE REQUIREMENT



OPEN OR EXPOSED FLAME

Amendment; LSA Doc. # 13 - 341 (F)
675 IAC 22 - 2.5 (eff. 12 - 01 - 14)

- THERE IS A MINIMUM 10 FOOT SEPARATION DISTANCE
- BETWEEN THE OPEN FLAME OR OTHER DEVICES EMITTING
- FLAME, FIRE OR HEAT OR ANY FLAMMABLE OR COMBUSTIBLE, ETC.
- AND THE TENT OR MEMBRANE STRUCTURES WHILE OPEN TO THE PUBLIC



OPEN OR EXPOSED FLAME

Amendment; LSA Doc. # 13 - 341 (F)
675 IAC 22 - 2.5 (eff. 12 - 01 - 14)




THERE IS A REQUIRED SEPARATION DISTANCE OF 10 FT.

OUTDOOR COOKING



OUTDOOR COOKING THAT PRODUCES SPARKS OR GREASE – LADEN VAPORS SHALL NOT BE PERFORMED WITHIN 10 FEET OF A TENT OR A MEMBRANE STRUCTURE.

- THE 3 CODE SECTIONS AMENDED IN THE *SCOPE* ARE 3104.7, 3104.15.5 AND 3104.15.6
- THIS SPECIFIC SECTION, 3104.15.6 IS ONE OF THOSE LISTED IN THE *SCOPE*
- THIS SECTION REINFORCES THE SEPARATION DISTANCE OF 10 FEET FOUND IN SEC. 3104.7




THE GRILLS MUST BE 10 FEET FROM THE TENT

LOCATION

Amendment; LSA Doc. # 13 - 341 (F)
675 IAC 22 - 2.5 (eff. 12 - 01 - 14)


- BECAUSE THIS IS A “REGULAR” TENT, THERE IS ONE MORE CODE SECTION TO STUDY
- SEC. 3103.8.2, EXCEPTION 1, *LOCATION*, IS APPLICABLE TO THIS TENT
- AS LONG AS THE FLOOR AREA OF THIS TENT DOES NOT EXCEED 15,000 SQUARE FEET, AND



LOCATION

**Amendment; LSA Doc. # 13 - 341 (F)
675 IAC 22 - 2.5 (eff. 12 - 01 - 14)**

- **AS LONG AS “OPEN OR EXPOSED FLAME” EQUIPMENT IS NOT USED (THERE IS NO COOKING EQUIPMENT UNDER THE TENT)**
- **THERE IS NO SEPARATION DISTANCE BETWEEN THIS TENT AND LOT LINES, BUILDINGS, PARKED VEHICLES OR INTERNAL COMBUSTION ENGINES**



SUMMARY: the following code sections govern this scenario

■ **Sec. 3101.1 – Scope**

■ **Sec. 3102.1 – Definitions**

- Cooking.
- Open or exposed flame equipment.

■ **Sec. 3103.8.2, Excp. 1 – Location**

- Applicable to this scenario.

■ **Sec. 3104.7 – Open or exposed flame**


- Applicable to this type of cooking.

■ **Sec. 3104.15.5 – Cooking tents**

- Not applicable because the cooking equipment is not in the tent.

■ **Sec. 3104.15.6 – Outdoor cooking**

- Applicable to this type of cooking.



“OPEN OR EXPOSED FLAME” EQUIPMENT
OUTSIDE OF A “REGULAR” TENT

SUMMARY: COOKING TENTS

THERE IS NO COOKING EQUIPMENT UNDER THE TENT.

THE AREA OF THIS TENT IS IN EXCESS OF 400 SQUARE FEET

* Go to the np

THERE IS NO SEPARATION DISTANCE BETWEEN THIS TENT AND THE OTHER TENTS

2014 Indiana Fire Code
Effective 12-01-2014

Sec. 3104.15.5

np
Rev Web 7
01-01-2019

SUMMARY: COOKING TENTS

THERE IS NO COOKING EQUIPMENT UNDER THE TENT.

THE AREA OF THIS TENT IS IN EXCESS OF 400 SQUARE FEET

* Go to the np

THERE IS NO SEPARATION DISTANCE BETWEEN THIS TENT AND THE OTHER TENTS

2014 Indiana Fire Code
Effective 12-01-2014

Sec. 3104.15.5

np
Rev Web 7
01-01-2019

SUMMARY: COOKING TENTS

THERE IS NO COOKING EQUIPMENT UNDER THE TENT.

THE AREA OF THIS TENT IS IN EXCESS OF 400 SQUARE FEET

* Go to the np

THERE IS NO SEPARATION DISTANCE BETWEEN THIS TENT AND THE OTHER TENTS

2014 Indiana Fire Code
Effective 12-01-2014

Sec. 3104.15.5

np
Rev Web 7
01-01-2019

SUMMARY: COOKING TENTS

THERE IS NO COOKING EQUIPMENT UNDER THE TENT.

THE AREA OF THIS TENT IS IN EXCESS OF 400 SQUARE FEET

* Go to the np

THERE IS NO SEPARATION DISTANCE BETWEEN THIS TENT AND THE OTHER TENTS

2014 Indiana Fire Code
Effective 12-01-2014

Sec. 3104.15.5

np
Rev Web 7
01-01-2019

SUMMARY: COOKING TENTS

THERE IS NO COOKING EQUIPMENT UNDER THE TENT.

THE AREA OF THIS TENT IS IN EXCESS OF 400 SQUARE FEET

* Go to the np


THERE IS NO SEPARATION DISTANCE BETWEEN THIS TENT AND THE OTHER TENTS

2014 Indiana Fire Code
Effective 12-01-2014

Sec. 3104.15.5

np
Rev Web 7
01-01-2019


SUMMARY: LOCATION



THERE IS NO COOKING
EQUIPMENT UNDER
THE TENT.



THE AREA OF THIS
TENT IS IN EXCESS OF 400
SQUARE FEET AND
DOES NOT EXCEED 15,000
SQUARE FEET



**THERE IS NO SEPARATION DISTANCE BETWEEN
THIS TENT AND THE OTHER ITEMS**

V

FT




OPEN OR EXPOSED FLAME

V

Amendment; LSA Doc. # 13 - 341 (F)
675 IAC 22 - 2.5 (eff. 12 - 01 - 14)


- THIS SCENARIO IS A “REGULAR” TENT; IN EXCESS OF 400 SQ. FT. WITH BOTH TYPES OF COOKING INSIDE
- THE “OPEN FLAME” EQUIPMENT MAY NOT OCCUR INSIDE THE TENT. THIS SCENARIO IS A VIOLATION OF SEC. 3104.7, *OPEN OR EXPOSED FLAME*
- THE “NO OPEN FLAME” EQUIPMENT IS OK IN THE TENT BECAUSE SEC. 3104.7 DOES NOT APPLY



OPEN OR EXPOSED FLAME

Amendment; LSA Doc. # 13 - 341 (F)
675 IAC 22 - 2.5 (eff. 12 - 01 - 14)

- THE “OPEN FLAME” EQUIPMENT, CHARCOAL GRILLS,
- MUST BE MOVED OUTSIDE OF THE TENT
- THE OPEN FLAME EQUIPMENT IS NOW OK IN THIS LOCATION, BUT
- THERE IS A MINIMUM SEPARATION DISTANCE REQUIREMENT



OPEN OR EXPOSED FLAME

Amendment; LSA Doc. # 13 - 341 (F)
675 IAC 22 - 2.5 (eff. 12 - 01 - 14)

- THERE IS A MINIMUM 10 FOOT SEPARATION DISTANCE
- BETWEEN THE OPEN FLAME OR OTHER DEVICES EMITTING
- FLAME, FIRE OR HEAT OR ANY FLAMMABLE OR COMBUSTIBLE, ETC.
- AND THE TENT OR MEMBRANE STRUCTURES WHILE OPEN TO THE PUBLIC



OPEN OR EXPOSED FLAME

Amendment; LSA Doc. # 13 - 341 (F)
675 IAC 22 - 2.5 (eff. 12 - 01 - 14)




THERE IS A REQUIRED SEPARATION DISTANCE OF 10 FT.

OPEN OR EXPOSED FLAME

**Amendment; LSA Doc. # 13 - 341 (F)
675 IAC 22 - 2.5 (eff. 12 - 01 - 14)**

- **THE “NO OPEN FLAME”
EQUIPMENT IS OK IN THE TENT
BECAUSE SEC. 3104.7 DOES NOT
APPLY**
- **BECAUSE THIS TENT DOES NOT
HAVE SIDEWALLS OR DROPS SEC.
3104.15.5 DOES NOT APPLY TO
THIS SCENARIO**
- **THEREFORE, THERE IS NO
SEPARATION DISTANCE BETWEEN
THIS TENT AND OTHER TENTS ...**



OUTDOOR COOKING



OUTDOOR COOKING THAT PRODUCES SPARKS OR GREASE – LADEN VAPORS SHALL NOT BE PERFORMED WITHIN 10 FEET OF A TENT OR A MEMBRANE STRUCTURE.

- THE 3 CODE SECTIONS AMENDED IN THE *SCOPE* ARE 3104.7, 3104.15.5 AND 3104.15.6
- THIS SPECIFIC SECTION, 3104.15.6 IS ONE OF THOSE LISTED IN THE *SCOPE*
- THIS SECTION REINFORCES THE SEPARATION DISTANCE OF 10 FEET FOUND IN SEC. 3104.7



THE GRILLS MUST BE 10 FEET FROM THE TENT

LOCATION

Amendment; LSA Doc. # 13 - 341 (F)
675 IAC 22 - 2.5 (eff. 12 - 01 - 14)

- BECAUSE THIS IS A “REGULAR” TENT, THERE IS ONE MORE CODE SECTION TO STUDY
- SEC. 3103.8.2, EXCEPTION 1, *LOCATION*, IS APPLICABLE TO THIS TENT
- AS LONG AS THE FLOOR AREA OF THIS TENT DOES NOT EXCEED 15,000 SQUARE FEET, AND



LOCATION

**Amendment; LSA Doc. # 13 - 341 (F)
675 IAC 22 - 2.5 (eff. 12 - 01 - 14)**

- **AS LONG AS “OPEN OR EXPOSED FLAME” EQUIPMENT IS NOT USED (IN THIS SCENARIO THAT IS TRUE)**
- **THERE IS NO SEPARATION DISTANCE BETWEEN THIS TENT AND LOT LINES, BUILDINGS,**
- **OTHER TEMP MEMBRANE STRUCTURES, OTHER TENTS, PARKED VEHICLES OR INTERNAL COMBUSTION ENGINES**



SUMMARY: the following code sections govern this scenario

■ **Sec. 3101.1 – Scope**

■ **Sec. 3102.1 – Definitions**

- Cooking.
- Open or exposed flame equipment.

■ **Sec. 3103.8.2, Excp. 1 – Location**

- Applicable to this scenario.

■ **Sec. 3104.7 – Open or exposed flame**


- Applicable to this type of cooking.

■ **Sec. 3104.15.5 – Cooking tents**

- Not applicable because there are no sidewalls or drops.


■ **Sec. 3104.15.6 – Outdoor cooking**

- Applicable to this type of cooking.




BOTH TYPES OF EQUIPMENT
AND A “REGULAR” TENT

SUMMARY: COOKING TENTS





SUMMARY: LOCATION



THE "NO OPEN FLAME"
EQUIPMENT IS
PERMITTED UNDER
THE TENT.

THE AREA OF THIS
TENT IS IN EXCESS OF 400
SQUARE FEET AND
DOES NOT EXCEED 15,000
SQUARE FEET



**THERE IS NO SEPARATION DISTANCE BETWEEN
THIS TENT AND THE OTHER ITEMS**

V

FT



OPEN OR EXPOSED FLAME

V

Amendment; LSA Doc. # 13 - 341 (F)
675 IAC 22 - 2.5 (eff. 12 - 01 - 14)


- THIS SCENARIO IS A “REGULAR” TENT; IN EXCESS OF 400 SQ. FT. WITH BOTH TYPES OF COOKING INSIDE
- THE “OPEN FLAME” EQUIPMENT MAY NOT OCCUR INSIDE THE TENT. THIS SCENARIO IS A VIOLATION OF SEC. 3104.7, *OPEN OR EXPOSED FLAME*
- THE “NO OPEN FLAME” EQUIPMENT IS OK IN THE TENT BECAUSE SEC. 3104.7 DOES NOT APPLY



OPEN OR EXPOSED FLAME

Amendment; LSA Doc. # 13 - 341 (F)
675 IAC 22 - 2.5 (eff. 12 - 01 - 14)


- THE “OPEN FLAME” EQUIPMENT, CHARCOAL GRILLS,
- MUST BE MOVED OUTSIDE OF THE TENT
- THE OPEN FLAME EQUIPMENT IS NOW OK IN THIS LOCATION, BUT
- THERE IS A MINIMUM SEPARATION DISTANCE REQUIREMENT



OPEN OR EXPOSED FLAME

Amendment; LSA Doc. # 13 - 341 (F)
675 IAC 22 - 2.5 (eff. 12 - 01 - 14)

- THERE IS A MINIMUM 10 FOOT SEPARATION DISTANCE
- BETWEEN THE OPEN FLAME OR OTHER DEVICES EMITTING
- FLAME, FIRE OR HEAT OR ANY FLAMMABLE OR COMBUSTIBLE, ETC.
- AND THE TENT OR MEMBRANE STRUCTURES WHILE OPEN TO THE PUBLIC



OPEN OR EXPOSED FLAME

Amendment; LSA Doc. # 13 - 341 (F)
675 IAC 22 - 2.5 (eff. 12 - 01 - 14)



THERE IS A REQUIRED SEPARATION DISTANCE OF 10 FT.

COOKING TENTS

V

Amendment; LSA Doc. # 13 - 341 (F)
675 IAC 22 - 2.5 (eff. 12 - 01 - 14)

- THE “NO OPEN FLAME”
EQUIPMENT IS OK IN THE TENT
BECAUSE SEC. 3104.7 DOES NOT
APPLY
- BECAUSE THIS TENT HAS
SIDEWALLS OR DROPS SEC.
3104.15.5 DOES APPLY TO THIS
SCENARIO
- THEREFORE, THERE IS A 10 FOOT
SEPARATION DISTANCE BETWEEN
THIS TENT AND OTHER TENTS ...




OUTDOOR COOKING



OUTDOOR COOKING THAT PRODUCES SPARKS OR GREASE – LADEN VAPORS SHALL NOT BE PERFORMED WITHIN 10 FEET OF A TENT OR A MEMBRANE STRUCTURE.

- THE 3 CODE SECTIONS AMENDED IN THE *SCOPE* ARE 3104.7, 3104.15.5 AND 3104.15.6
- THIS SPECIFIC SECTION, 3104.15.6 IS ONE OF THOSE LISTED IN THE *SCOPE*
- THIS SECTION REINFORCES THE SEPARATION DISTANCE OF 10 FEET FOUND IN SEC. 3104.7




THE GRILLS MUST BE 10 FEET FROM THE TENT

LOCATION

Amendment; LSA Doc. # 13 - 341 (F)
675 IAC 22 - 2.5 (eff. 12 - 01 - 14)


- BECAUSE THIS IS A “REGULAR” TENT, THERE IS ONE MORE CODE SECTION TO STUDY
- SEC. 3103.8.2, EXCEPTION 1, *LOCATION*, IS APPLICABLE TO THIS TENT
- AS LONG AS THE FLOOR AREA OF THIS TENT DOES NOT EXCEED 15,000 SQUARE FEET, AND



LOCATION

**Amendment; LSA Doc. # 13 - 341 (F)
675 IAC 22 - 2.5 (eff. 12 - 01 - 14)**

- **AS LONG AS “OPEN OR EXPOSED FLAME” EQUIPMENT IS NOT USED (IN THIS SCENARIO THAT IS TRUE)**
- **THERE IS NO SEPARATION DISTANCE BETWEEN THIS TENT AND LOT LINES, BUILDINGS, PARKED VEHICLES OR INTERNAL COMBUSTION ENGINES**



SUMMARY: the following code sections govern this scenario

■ **Sec. 3101.1 – Scope**

■ **Sec. 3102.1 – Definitions**

- Cooking.
- Open or exposed flame equipment.

■ **Sec. 3103.8.2, Excp. 1 – Location**

- Applicable to this scenario.

■ **Sec. 3104.7 – Open or exposed flame**

- Applicable to this type of cooking.

■ **Sec. 3104.15.5 – Cooking tents**

- There is a minimum separation distance of 10 feet.


■ **Sec. 3104.15.6 – Outdoor cooking**

- Applicable to this type of cooking.




BOTH TYPES OF EQUIPMENT
AND A “REGULAR” TENT

SUMMARY: COOKING TENTS




SUMMARY: LOCATION



THE "NO OPEN FLAME"
EQUIPMENT IS
PERMITTED UNDER
THE TENT.



THE AREA OF THIS
TENT IS IN EXCESS OF 400
SQUARE FEET AND
DOES NOT EXCEED 15,000
SQUARE FEET



**THERE IS NO SEPARATION DISTANCE BETWEEN
THIS TENT AND THE OTHER ITEMS**



Chapter 31, 2014 Ed. Indiana Fire Code

Tents And Other Membrane Structures

Presented by the State Fire Marshal's Office

Division of Fire and Building Safety