To: Carlie Hopper May 24, 2010

From: Bill Fox

There should be a preface to the Title CHAPTER 11 along the lines of the paragraph I show below that explains that our modifications or amendments do not conflict with the ARRA.

This Chapter has been modified to comply with the Energy requirements of the American Rescue and Reinvestment Act (ARRA). There are added modifications which are deletions of Energy provisions that do not apply to the Indiana Climate Zones which should make compliance with this Energy Chapter somewhat simpler to use.

The promised instructions are as follows: Use the existing approved proposed Code changes as listed below and provide new ones where so stated. The Revision Committee will probably need to approve the new proposals.

- 1) Code change 52.3.2 (N1101.1 Scope).
- **2)** Code change 52.3.3-09 (**Figure 1102.1**).
- 3) Code change 52.3.4-09 (**Table 1102.1**).
- 4) Need a Code change to delete the last sentence of the first paragraph of N1102.1.3. (**Total UA alternative**). Reason: not required in Indiana.
- 5) Code change 52.3.6.5-09 which adds a second paragraph to 1102.1.3. (Total UA alternative)
- 6) Code change 52.3.5-09 (**Table N1102.1**) (including the re-lettering of the footnotes).
- 7) Code change 52.3.3-09 (**Table N1102.1.2**). Modify with 52.3.6.1.
- 8) Code change 52.3.8-09. (**Ceilings without attic spaces**) Check with Wagner why he left out last sentence
- 9) Need Code change to delete entire Section N1102.3.2 **Glazed fenestration.** Reason: SHGC not required in Indiana
- **10)** Need Code change for N1102.3.3 (**Glazed fenestration exemption**). Modify by removing "**and SHGC**" from the first sentence.
- 11) Need Code change N1102.3.6 Replacement fenestration to delete "and solar heat gain coefficient (SHGC)". Not required in Indiana.
- **12)** Code change 52.3.10-09 added to (**Table 1102.4.2**)
- 13) Code change 52.3.11-09. Modify by removing the last sentence and removing "SHGC" from the label
- 14) Need Code change for N1103.8.3 Pool Covers. Add -
- 15) Exception: Pools deriving over 60 percent of the energy for heating from site-recovered energy or solar energy source. This exception was derived from 2009 IECC, Chapters 4 and 5.