



PROPOSAL FOR CODE CHANGE

State Form 41186 (R3 / 5-10)

RECEIVED

IDHS

SEP 23 2019

COMMISSION
STAFF



- INSTRUCTIONS:
1. Only a TYPED copy will be accepted.
 2. ~~Dashed line through material to be deleted~~; underline or bold face material to be added.
 3. Use a second sheet for any material requiring more space.
 4. Return this completed form to: Indiana Department of Homeland Security, Code Services, 402 West Washington Street, Room W246, Indianapolis, Indiana 46204.

FOR OFFICE USE ONLY

Received	9 / 23 / 2019	Code	2018 IRC	Proposal number	
----------	---------------	------	----------	-----------------	--

Code title International Residential Code		Edition 2018
Section number and title Chapter 44, Referenced Standards		Page number 785
Proponent Jonathan Sargeant	Representing (if applicable) Omegaflex	
Address (number and street, city, state, and ZIP code) 1801 Crystal Drive, Apartment 711, Arlington, VA 22202		Telephone number (703) 946-5848

PROPOSED CODE CHANGE (check one)

- ☒ Change to read as follows ☐ Add to read as follows ☐ Delete and substitute as follows ☐ Delete without substitution

LC1/CSA 6.26—~~13~~ 18: Fuel Gas Piping Systems Using Corrugated Stainless Steel Tubing (CSST)

G2414.5.4, G2411.3, G2415.5

REASON STATEMENT AND FISCAL IMPACT

This is an update to the product standard which was overlooked by ICC staff. The change is necessary because there is a new product incorporating an arc resistant jacket, the installation of which is detailed by the 2018 IFGC and IRC, which is not addressed by the 2013 standard. The 2018 LC-1 covers both the traditional product and the new arc resistant product where as the 2013 LC-1 covers only the traditional product.

REVIEW RECOMMENDATION

Approve
Reject
Approve as amended
Further study