From: building
To: Lynn Madden; inspectorsouth; Greg Furnish
Cc: Boyle, Douglas J (DHS)
Subject: RE: IRC amendments
Date: Thursday, October 10, 2019 8:23:28 AM

**** This is an EXTERNAL email. Exercise caution. DO NOT open attachments or click links from unknown senders or unexpected email. ****

To the IRC Code amendment committee:

Upon purchasing the 2018 IRC first printing and downloading the draft amendments, please note the following items I believe that are TYPO's, need clarity or conflict with other code sections.

At this time I have NOT finished updating my new code book but only making it to the plumbing section as of sending this. I will have more to send you later but wanted to give you a start on what I have found if others have not already sent it to you.

Draft amendments downloaded from web portal:

Page 13 675 IAC 14-4.4-15 Section R311.3.1 ; floor elevations at other exterior doors Correct R311.3.1 to say R311.3.2 in text and amendment
Page 13 675 IAC 14-4.4-17 Section R311.7.5.2; treads Correct to say ADD Exception #2 to Section R311.7.5.2 (not R11.7.5.2)
Page 19 675 IAC 14-4.4-34 Section R 322.1.6; protection of mechanical and plumbing systems Correct to say ; protection of mechanical, plumbing and electrical systems
Page 19 675 IAC 14-4.4-34 Section R322.1.6; When it says to change the text of a section to read… without mention of exceptions… does that include removing exceptions?
Page 20 675 IAC 14-4.4-36 Section R322.2.1; elevation requirements…. When it says to delete the text of Section R322.2.1 and substitute to read…. Does that remove exceptions?
Page 66 675 IAC 14-4.4-63 Section R502.11.4; truss design drawings… This is for floor trusses.. unlike roof trusses in R802.10.1, you removed the requirement for the contractor to provide the inspector with the drawings for required permanent field installed bracing. Without this information, bracing could be misses and cause structural failure.
Page 68 675 IAC 14-4.4-72 Section R602.10; Wall Bracing…added exception to allow alternative method APA SR-102 V5. Unable to located V5 (version 5 ?) on APA website
Page 70 675 IAC 14-4.4-79 Section R703.8.6; Drained Cavity…. Should say Section R703.8.6; Weepholes.. Delete and substitute to read as follows SECTION R703.8.6 Drained Cavity
Page 75 675 IAC 14-4.4-92 Table N1102.1.4; equivalent u-factors … Says delete Table N1102.1.2… should say Delete Table N1102.1.4.
Page 81 675 IAC 14-4.4-112 … Says Section M1201.2; applications….. Should say Section M1202 Existing Mechanical Systems
Page 90 675 IAC 14-4.4-144 Section G2427.8; Venting System Termination Location … Item #2 has duplication of text lines making hard to understand.
Page 90 675 IAC 14-4.4-145 Section G2428.1; venting system termination location…..should say..

Section G2428.1; Definitions
Page 92 675 IAC 14-4.4-152 Section P2503.2; Concealment. .. Are you REALLY saying that inspectors do not have to inspect and approve under slab plumbing and won't see change of direction fittings or slope? Also could a contractor cover a failed frame R/I inspection on walls before re-inspection if only plumbing violations and plumber reports corrected?

Michael Schroeder
Building Inspector (25 years)
Harrison County
812-738-8927

From: Lynn Madden [mailto:lmadden@hallmarkhomes.com]
Sent: Thursday, October 10, 2019 6:30 AM
To: building <Building@harrisoncounty.in.gov>
Subject: Re: IRC amendments

Oh gosh Mike, I thought I had and it was in my drafts.....here it is

DoBoyle@dhs.in.gov

Please send any proposals/corrections to me as well if you don't mind.

Sorry about that

Sincerely

Lynn

On Wed, Oct 9, 2019 at 3:17 PM building <Building@harrisoncounty.in.gov> wrote:

> Lynn,
>
> Could you please forward contact information for Doug Boyle?
> Thanks
> Mike schroeder
>
> **From:** Lynn Madden [mailto:lmadden@hallmarkhomes.com]
> **Sent:** Friday, September 27, 2019 2:32 PM
> **To:** building <Building@harrisoncounty.in.gov>
> **Subject:** Call
>
> Mike
>
> My cell number is the same
>
> 765-623-1640

> **Notice: Nothing herein shall be construed or deemed to constitute: (I) An agreement to offer or sell any home or construction services, or (II) An amendment or modification to any written agreement for the sale, purchase or construction services of a home. Offers to purchase, amendments to a construction agreement, or otherwise altering the terms of an existing agreement shall only be made and accepted by execution of written agreement by the parties thereto.**

Notice: Nothing herein shall be construed or deemed to constitute: (I) An agreement to offer or sell any home or construction services, or (II) An amendment or modification to any written agreement for the sale, purchase or construction services of a home. Offers to purchase, amendments to a construction agreement, or otherwise altering the terms of an existing agreement shall only be made and accepted by execution of written agreement by the parties thereto.