

**Name** Dave Cook, RA, NCARB

**Representing** myself

**Email Address** dave@dc-codes.com

**Phone Number** 3177873750

**Address** 7021 Grosvenor Place

**Code You Are Commenting On** Building Codes

**Section Within the Code You Are Commenting On** Chapter 30, Sections 3006.2 and 3006.2.1

**Comment or Proposal** Sec 3006.2, Add exception to #6....++++"Exception: R Use Groups protected throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2"+++

Sec 3006.2.1, Add exception to #6....++++"Exception: R Use Groups protected throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2"+++

**Reason Statement and Fiscal Impact Statement** For many code cycles, going back a couple decades, Elevator Lobbies have NOT been required in non-high-rise R Use Groups, that were protected with 13 or 13R sprinkler systems, based on well documented NIST reports, and a good track record since its inception. Recently groups who are trying to "sell their products" have worked their way back into hearings and thus this new unnecessary code language that is unfounded, except to sell their products.