



IDHS VARIANCE DETERMINATIONS REPORT

Variance Determinations issued between April 2, 2026, and May 5, 2026.

Reported at the May 13, 2026 Fire Prevention and Building Safety Commission meeting.

IDHS VARIANCE DETERMINATIONS ISSUED BETWEEN APRIL 2, 2026 AND MAY 5, 2026.

Variance Number	Project Name	County	Code	Section	Action	Reason	Date Order Issued
26-03-59	Riley						
26-03-60	Aramark – IMS 2026	Marion	2014 Fire Cod Ch. 31	3103.5	Approved with IDHS Condition(s)	1. The applicant shall comply with all state and manufacturer's requirements for operation of tent. 2. The tent shall be inspected weekly for purposes of ensuring its structural stability and identifying any apparent safety hazards. If during an inspection it is found that the tent's structural stability has been compromised or another safety hazard exists, the tent shall not be occupied until the issue has been remedied. 3. The tent shall not be occupied in the event of any actual or forecasted accumulating snow or high wind event, which exceeds any manufacturer or installer recommendations or, if neither exist any limit acceptable by the authority having jurisdiction. The tent must be reinspected in the event of any high wind or accumulating snow. 4. Open flame and heating and cooking sources are not permitted within the tent.	04/06/2026

**IDHS Variance Determinations Report
Determinations Issued Between April 2, 2026, May 5, 2026**

						5. This variance shall be in effect from April 20, 2026 until August 5, 2026.	
26-03-61	Holiday Farms Senior Living	Boone	2014 IBC	1008.1.9.7	Withdrawn		04/06/2026
26-03-62	I Tre Mori – Smart Pergola	Hamilton	Indiana Energy Conservation Code, 2010 Edition	5.7.1(a)	Approved as Submitted		04/06/2026
26-03-63	Jersey 32	Hamilton	2014 IBC	1209.2	Not Approved	Applicant has not demonstrated that non-compliance with the rule will not be adverse to the public health, safety, or welfare.	04/06/2026
26-03-64	City of Wabash – Fire Station 2 – Solar PV	Wabash	2014 IBC	1013.6	Approved with IDHS Condition(s)	Safety anchors shall be provided on the roof structure to provide secure tie-offs for maintenance personnel, in compliance with OSHA/ANSI requirements.	04/06/2026
26-03-65(a)	Transportation Center Expansion and Renovation	Allen	InBC 2014	706.2	Approved as Submitted		04/06/2026
26-03-65(b)	Transportation Center Expansion and Renovation	Allen	InBC 2014	706.5.1	Approved as Submitted		04/06/2026
26-03-66	Harley Davidson Tent Sale	Allen	2014 Fire Cod Ch. 31	3103.5	Approved with IDHS Condition(s)	1. The applicant shall comply with all state and manufacturer's requirements for operation of tent. 2. The tent shall be inspected weekly for purposes of ensuring its structural stability and identifying any apparent safety hazards. If during an inspection it is found that the tent's structural stability has been compromised or another safety hazard exists, the tent shall not be occupied until the issue has been remedied. 3. The tent shall not be occupied in the event of any actual or forecasted accumulating snow or high wind event, which exceeds any manufacturer or installer recommendations or, if neither exist any limit acceptable by the authority having	04/06/2026

**IDHS Variance Determinations Report
Determinations Issued Between April 2, 2026, May 5, 2026**

						<p>jurisdiction. The tent must be reinspected in the event of any high wind or accumulating snow.</p> <p>4. Open flame and heating and cooking sources are not permitted within the tent.</p> <p>5. This structure shall not be erected for more than one hundred and eighty (180) days in a calendar year.</p>	
26-03-67	Master Spas Temporary Warehouse	Allen	2014 Fire Cod Ch. 31	3103.5	Approved with IDHS Condition(s)	<p>1. The applicant shall comply with all state and manufacturer's requirements for operation of tent.</p> <p>2. The tent shall be inspected weekly for purposes of ensuring its structural stability and identifying any apparent safety hazards. If during an inspection it is found that the tent's structural stability has been compromised or another safety hazard exists, the tent shall not be occupied until the issue has been remedied.</p> <p>3. The tent shall not be occupied in the event of any actual or forecasted accumulating snow or high wind event, which exceeds any manufacturer or installer recommendations or, if neither exist any limit acceptable by the authority having jurisdiction. The tent must be reinspected in the event of any high wind or accumulating snow.</p> <p>4. Open flame and heating and cooking sources are not permitted within the tent.</p> <p>5. This variance shall expire on July 31, 2026.</p>	04/06/2026
26-03-68(a)	Little Ridge School	Ripley	2014 IBC	903.2.8	No Variance Required	Based on plans submitted, there is no group R occupancy in the building.	04/06/2026

IDHS Variance Determinations Report
Determinations Issued Between April 2, 2026, May 5, 2026

26-03-68(b)	Little Ridge School	Ripley	2014 IBC	1011.3	Approved as Submitted	04/06/2026
26-03-68(c)	Little Ridge School	Ripley	2014 IBC	1006.1	Approved as Submitted	04/06/2026
26-03-68(d)	Little Ridge School	Ripley	2014 IBC	907.2.3	Approved as Submitted	04/06/2026
26-03-68(e)	Little Ridge School	Ripley	2012 IPC	Table 2902.1	Approved as Submitted	04/06/2026
26-03-69(a)	Arrow McLaren Renovation & Addition	Marion	A-117.1, 2009	608.2.3.1	Approved as Submitted	04/06/2026
26-03-69(b)	Arrow McLaren Renovation & Addition	Marion	A-117.1, 2009	604.2	Approved as Submitted	04/06/2026
26-03-69(c)	Arrow McLaren Renovation & Addition	Marion	2012 Indiana Plumbing Cod, (675 IAC 16-1.4)	420.3	Approved as Submitted	04/06/2026
26-03-69(d)	Arrow McLaren Renovation & Addition	Marion	A-117.1, 2009	308.2.1	Approved as Submitted	04/06/2026
26-03-69(e)	Arrow McLaren Renovation & Addition	Marion	2014 IBC	2902.3.6	Approved as Submitted	04/06/2026
26-03-70	SIA North Warehouse Addition	Tippecanoe	2014 IBC	1016.2	Approved as Submitted	04/08/2026
26-03-71	CityView	Hamilton	2014 IBC	716.5	Approved as Submitted	04/08/2026
26-03-72	The Gardens Phase 2 1 Bedroom Bldgs 4 8 & 9	Monroe	2014 IBC	714.4.1.2	Approved as Submitted	04/08/2026
26-03-73	The Woods at West Carmel	Hamilton	675 IAC	20-2- 17(b)(3)	Approved as Submitted	04/08/2026
26-03-74(a)	Ten20 North	Bartholomew	2014 IMC	1102.2	Approved as Submitted	04/08/2026
26-03-74(b)	Ten20 North	Bartholomew	2014 IBC	3004.1	Approved as Submitted	04/08/2026
26-03-74(c)	Ten20 North	Bartholomew	2014 IBC	706.5, exc.1	Approved as Submitted	04/08/2026

IDHS Variance Determinations Report
Determinations Issued Between April 2, 2026, May 5, 2026

26-03-74(d)	Ten20 North	Bartholomew	2014 IBC	714.4.1.2	Approved as Submitted		04/08/2026
26-03-74(e)	Ten20 North	Bartholomew	2014 IBC	1007.2.1	Approved as Submitted		04/08/2026
26-03-74(f)	Ten20 North	Bartholomew	2004 NFPA 82 Incinerators, Waste and Linen Handling Systems and Equipment (675 IAC 28-1-30)	5.2.4.2, 5.2.5.3, 5.2.7.1	Approved as Submitted		04/08/2026
26-03-75	Tractor Supply Tent Sale	Kosciusko	2014 Fire Cod Ch. 31	3103.5	Approved with IDHS Condition(s)	<p>1. The applicant shall comply with all state and manufacturer's requirements for operation of tent.</p> <p>2. The tent shall be inspected weekly for purposes of ensuring its structural stability and identifying any apparent safety hazards. If during an inspection it is found that the tent's structural stability has been compromised or another safety hazard exists, the tent shall not be occupied until the issue has been remedied.</p> <p>3. The tent shall not be occupied in the event of any actual or forecasted accumulating snow or high wind event, which exceeds any manufacturer or installer recommendations or, if neither exist any limit acceptable by the authority having jurisdiction. The tent must be reinspected in the event of any high wind or accumulating snow.</p> <p>4. Open flame and heating and cooking sources are not permitted within the tent.</p> <p>5. This variance shall expire on June 26, 2026.</p>	04/08/2026
26-03-76	Tractor Supply Tent Sale	Adams	2014 Fire Cod Ch. 31	3103.5	Approved with IDHS Condition(s)	<p>1. The applicant shall comply with all state and manufacturer's requirements for operation of tent.</p> <p>2. The tent shall be inspected weekly for purposes of ensuring its structural stability</p>	04/08/2026

**IDHS Variance Determinations Report
Determinations Issued Between April 2, 2026, May 5, 2026**

						<p>and identifying any apparent safety hazards. If during an inspection it is found that the tent's structural stability has been compromised or another safety hazard exists, the tent shall not be occupied until the issue has been remedied.</p> <p>3. The tent shall not be occupied in the event of any actual or forecasted accumulating snow or high wind event, which exceeds any manufacturer or installer recommendations or, if neither exist any limit acceptable by the authority having jurisdiction. The tent must be reinspected in the event of any high wind or accumulating snow.</p> <p>4. Open flame and heating and cooking sources are not permitted within the tent.</p> <p>5. This variance shall expire on June 26, 2026.</p>	
26-03-77	Tractor Supply Tent Sale	Hancock	2014 Fire Cod Ch. 31	3103.5	Approved with IDHS Condition(s)	<p>1. The applicant shall comply with all state and manufacturer's requirements for operation of tent.</p> <p>2. The tent shall be inspected weekly for purposes of ensuring its structural stability and identifying any apparent safety hazards. If during an inspection it is found that the tent's structural stability has been compromised or another safety hazard exists, the tent shall not be occupied until the issue has been remedied.</p> <p>3. The tent shall not be occupied in the event of any actual or forecasted accumulating snow or high wind event, which exceeds any manufacturer or installer recommendations or, if neither exist any limit acceptable by the authority having</p>	04/08/2026

**IDHS Variance Determinations Report
Determinations Issued Between April 2, 2026, May 5, 2026**

						<p>jurisdiction. The tent must be reinspected in the event of any high wind or accumulating snow.</p> <p>4. Open flame and heating and cooking sources are not permitted within the tent.</p> <p>5. This variance shall expire on June 26, 2026.</p>	
26-03-78	Tractor Supply Tent Sale	Hamilton	2014 Fire Cod Ch. 31	3103.5	Approved with IDHS Condition(s)	<p>1. The applicant shall comply with all state and manufacturer's requirements for operation of tent.</p> <p>2. The tent shall be inspected weekly for purposes of ensuring its structural stability and identifying any apparent safety hazards. If during an inspection it is found that the tent's structural stability has been compromised or another safety hazard exists, the tent shall not be occupied until the issue has been remedied.</p> <p>3. The tent shall not be occupied in the event of any actual or forecasted accumulating snow or high wind event, which exceeds any manufacturer or installer recommendations or, if neither exist any limit acceptable by the authority having jurisdiction. The tent must be reinspected in the event of any high wind or accumulating snow.</p> <p>4. Open flame and heating and cooking sources are not permitted within the tent.</p> <p>5. This variance shall expire on June 26, 2026.</p>	04/08/2026
26-03-79	Tractor Supply Tent Sale	Johnson	2014 Fire Cod Ch. 31	3103.5	Approved with IDHS Condition(s)	<p>1. The applicant shall comply with all state and manufacturer's requirements for operation of tent.</p> <p>2. The tent shall be inspected weekly for purposes of ensuring its structural stability and identifying any apparent</p>	04/08/2026

**IDHS Variance Determinations Report
Determinations Issued Between April 2, 2026, May 5, 2026**

						<p>safety hazards. If during an inspection it is found that the tent's structural stability has been compromised or another safety hazard exists, the tent shall not be occupied until the issue has been remedied.</p> <p>3. The tent shall not be occupied in the event of any actual or forecasted accumulating snow or high wind event, which exceeds any manufacturer or installer recommendations or, if neither exist any limit acceptable by the authority having jurisdiction. The tent must be reinspected in the event of any high wind or accumulating snow.</p> <p>4. Open flame and heating and cooking sources are not permitted within the tent.</p> <p>5. This variance shall expire on June 26, 2026.</p>	
26-03-80	Tractor Supply Tent Sale	Morgan	2014 Fire Cod Ch. 31	3103.5	Approved with IDHS Condition(s)	<p>1. The applicant shall comply with all state and manufacturer's requirements for operation of tent.</p> <p>2. The tent shall be inspected weekly for purposes of ensuring its structural stability and identifying any apparent safety hazards. If during an inspection it is found that the tent's structural stability has been compromised or another safety hazard exists, the tent shall not be occupied until the issue has been remedied.</p> <p>3. The tent shall not be occupied in the event of any actual or forecasted accumulating snow or high wind event, which exceeds any manufacturer or installer recommendations or, if neither exist any limit acceptable by the authority having jurisdiction. The tent must be</p>	04/08/2026

**IDHS Variance Determinations Report
Determinations Issued Between April 2, 2026, May 5, 2026**

						<p>reinspected in the event of any high wind or accumulating snow.</p> <p>4. Open flame and heating and cooking sources are not permitted within the tent.</p> <p>5. This variance shall expire on June 26, 2026.</p>	
26-03-81	Tractor Supply Tent Sale	Hendricks	2014 Fire Cod Ch. 31	3103.5	Approved with IDHS Condition(s)	<p>1. The applicant shall comply with all state and manufacturer's requirements for operation of tent.</p> <p>2. The tent shall be inspected weekly for purposes of ensuring its structural stability and identifying any apparent safety hazards. If during an inspection it is found that the tent's structural stability has been compromised or another safety hazard exists, the tent shall not be occupied until the issue has been remedied.</p> <p>3. The tent shall not be occupied in the event of any actual or forecasted accumulating snow or high wind event, which exceeds any manufacturer or installer recommendations or, if neither exist any limit acceptable by the authority having jurisdiction. The tent must be reinspected in the event of any high wind or accumulating snow.</p> <p>4. Open flame and heating and cooking sources are not permitted within the tent.</p> <p>5. This variance shall expire on June 26, 2026.</p>	04/08/2026
26-03-82	Tractor Supply Tent Sale	Boone	2014 Fire Cod Ch. 31	3103.5	Approved with IDHS Condition(s)	<p>1. The applicant shall comply with all state and manufacturer's requirements for operation of tent.</p> <p>2. The tent shall be inspected weekly for purposes of ensuring its structural stability and identifying any apparent safety hazards. If during an</p>	04/08/2026

**IDHS Variance Determinations Report
Determinations Issued Between April 2, 2026, May 5, 2026**

						<p>inspection it is found that the tent's structural stability has been compromised or another safety hazard exists, the tent shall not be occupied until the issue has been remedied.</p> <p>3. The tent shall not be occupied in the event of any actual or forecasted accumulating snow or high wind event, which exceeds any manufacturer or installer recommendations or, if neither exist any limit acceptable by the authority having jurisdiction. The tent must be reinspected in the event of any high wind or accumulating snow.</p> <p>4. Open flame and heating and cooking sources are not permitted within the tent.</p> <p>5. This variance shall expire on June 26, 2026.</p>	
26-03-83	Tractor Supply Tent Sale	Boone	2014 Fire Cod Ch. 31	3103.5	Approved with IDHS Condition(s)	<p>1. The applicant shall comply with all state and manufacturer's requirements for operation of tent.</p> <p>2. The tent shall be inspected weekly for purposes of ensuring its structural stability and identifying any apparent safety hazards. If during an inspection it is found that the tent's structural stability has been compromised or another safety hazard exists, the tent shall not be occupied until the issue has been remedied.</p> <p>3. The tent shall not be occupied in the event of any actual or forecasted accumulating snow or high wind event, which exceeds any manufacturer or installer recommendations or, if neither exist any limit acceptable by the authority having jurisdiction. The tent must be reinspected in the event of any</p>	04/08/2026

**IDHS Variance Determinations Report
Determinations Issued Between April 2, 2026, May 5, 2026**

						<p>high wind or accumulating snow. 4. Open flame and heating and cooking sources are not permitted within the tent. 5. This variance shall expire on June 26, 2026.</p>	
26-03-84	Tractor Supply Tent Sale	Warrick	2014 Fire Cod Ch. 31	3103.5	Approved with IDHS Condition(s)	<p>1. The applicant shall comply with all state and manufacturer's requirements for operation of tent. 2. The tent shall be inspected weekly for purposes of ensuring its structural stability and identifying any apparent safety hazards. If during an inspection it is found that the tent's structural stability has been compromised or another safety hazard exists, the tent shall not be occupied until the issue has been remedied. 3. The tent shall not be occupied in the event of any actual or forecasted accumulating snow or high wind event, which exceeds any manufacturer or installer recommendations or, if neither exist any limit acceptable by the authority having jurisdiction. The tent must be reinspected in the event of any high wind or accumulating snow. 4. Open flame and heating and cooking sources are not permitted within the tent. 5. This variance shall expire on June 26, 2026.</p>	04/08/2026
26-03-85	Tractor Supply Tent Sale	Clark	2014 Fire Cod Ch. 31	3103.5	Approved with IDHS Condition(s)	<p>1. The applicant shall comply with all state and manufacturer's requirements for operation of tent. 2. The tent shall be inspected weekly for purposes of ensuring its structural stability and identifying any apparent safety hazards. If during an inspection it is found that the</p>	04/08/2026

**IDHS Variance Determinations Report
Determinations Issued Between April 2, 2026, May 5, 2026**

						<p>tent's structural stability has been compromised or another safety hazard exists, the tent shall not be occupied until the issue has been remedied.</p> <p>3. The tent shall not be occupied in the event of any actual or forecasted accumulating snow or high wind event, which exceeds any manufacturer or installer recommendations or, if neither exist any limit acceptable by the authority having jurisdiction. The tent must be reinspected in the event of any high wind or accumulating snow.</p> <p>4. Open flame and heating and cooking sources are not permitted within the tent.</p> <p>5. This variance shall expire on June 26, 2026.</p>	
26-03-86	Tractor Supply Tent Sale	Jackson	2014 Fire Cod Ch. 31	3103.5	Approved with IDHS Condition(s)	<p>1. The applicant shall comply with all state and manufacturer's requirements for operation of tent.</p> <p>2. The tent shall be inspected weekly for purposes of ensuring its structural stability and identifying any apparent safety hazards. If during an inspection it is found that the tent's structural stability has been compromised or another safety hazard exists, the tent shall not be occupied until the issue has been remedied.</p> <p>3. The tent shall not be occupied in the event of any actual or forecasted accumulating snow or high wind event, which exceeds any manufacturer or installer recommendations or, if neither exist any limit acceptable by the authority having jurisdiction. The tent must be reinspected in the event of any</p>	04/08/2026

**IDHS Variance Determinations Report
Determinations Issued Between April 2, 2026, May 5, 2026**

						<p>high wind or accumulating snow. 4. Open flame and heating and cooking sources are not permitted within the tent. 5. This variance shall expire on June 26, 2026.</p>	
26-03-87	Tractor Supply Tent Sale	Dearborn	2014 Fire Cod Ch. 31	3103.5	Approved with IDHS Condition(s)	<p>1. The applicant shall comply with all state and manufacturer's requirements for operation of tent. 2. The tent shall be inspected weekly for purposes of ensuring its structural stability and identifying any apparent safety hazards. If during an inspection it is found that the tent's structural stability has been compromised or another safety hazard exists, the tent shall not be occupied until the issue has been remedied. 3. The tent shall not be occupied in the event of any actual or forecasted accumulating snow or high wind event, which exceeds any manufacturer or installer recommendations or, if neither exist any limit acceptable by the authority having jurisdiction. The tent must be reinspected in the event of any high wind or accumulating snow. 4. Open flame and heating and cooking sources are not permitted within the tent. 5. This variance shall expire on June 26, 2026.</p>	04/08/2026
26-03-88	Tractor Supply Tent Sale	Wayne	2014 Fire Cod Ch. 31	3103.5	Approved with IDHS Condition(s)	<p>1. The applicant shall comply with all state and manufacturer's requirements for operation of tent. 2. The tent shall be inspected weekly for purposes of ensuring its structural stability and identifying any apparent safety hazards. If during an inspection it is found that the</p>	04/08/2026

**IDHS Variance Determinations Report
Determinations Issued Between April 2, 2026, May 5, 2026**

						<p>tent's structural stability has been compromised or another safety hazard exists, the tent shall not be occupied until the issue has been remedied.</p> <p>3. The tent shall not be occupied in the event of any actual or forecasted accumulating snow or high wind event, which exceeds any manufacturer or installer recommendations or, if neither exist any limit acceptable by the authority having jurisdiction. The tent must be reinspected in the event of any high wind or accumulating snow.</p> <p>4. Open flame and heating and cooking sources are not permitted within the tent.</p> <p>5. This variance shall expire on June 26, 2026.</p>	
26-03-89	Tractor Supply Tent Sale	Elkhart	2014 Fire Cod Ch. 31	3103.5	Approved with IDHS Condition(s)	<p>1. The applicant shall comply with all state and manufacturer's requirements for operation of tent.</p> <p>2. The tent shall be inspected weekly for purposes of ensuring its structural stability and identifying any apparent safety hazards. If during an inspection it is found that the tent's structural stability has been compromised or another safety hazard exists, the tent shall not be occupied until the issue has been remedied.</p> <p>3. The tent shall not be occupied in the event of any actual or forecasted accumulating snow or high wind event, which exceeds any manufacturer or installer recommendations or, if neither exist any limit acceptable by the authority having jurisdiction. The tent must be reinspected in the event of any</p>	04/08/2026

**IDHS Variance Determinations Report
Determinations Issued Between April 2, 2026, May 5, 2026**

						<p>high wind or accumulating snow. 4. Open flame and heating and cooking sources are not permitted within the tent. 5. This variance shall expire on June 26, 2026.</p>	
26-03-90	Tractor Supply Tent Sale	Henry	2014 Fire Cod Ch. 31	3103.5	Approved with IDHS Condition(s)	<p>1. The applicant shall comply with all state and manufacturer's requirements for operation of tent. 2. The tent shall be inspected weekly for purposes of ensuring its structural stability and identifying any apparent safety hazards. If during an inspection it is found that the tent's structural stability has been compromised or another safety hazard exists, the tent shall not be occupied until the issue has been remedied. 3. The tent shall not be occupied in the event of any actual or forecasted accumulating snow or high wind event, which exceeds any manufacturer or installer recommendations or, if neither exist any limit acceptable by the authority having jurisdiction. The tent must be reinspected in the event of any high wind or accumulating snow. 4. Open flame and heating and cooking sources are not permitted within the tent. 5. This variance shall expire on June 26, 2026.</p>	04/08/2026
26-03-91	Tractor Supply Tent Sale	Steuben	2014 Fire Cod Ch. 31	3103.5	Approved with IDHS Condition(s)	<p>1. The applicant shall comply with all state and manufacturer's requirements for operation of tent. 2. The tent shall be inspected weekly for purposes of ensuring its structural stability and identifying any apparent safety hazards. If during an inspection it is found that the</p>	04/08/2026

**IDHS Variance Determinations Report
Determinations Issued Between April 2, 2026, May 5, 2026**

						<p>tent's structural stability has been compromised or another safety hazard exists, the tent shall not be occupied until the issue has been remedied.</p> <p>3. The tent shall not be occupied in the event of any actual or forecasted accumulating snow or high wind event, which exceeds any manufacturer or installer recommendations or, if neither exist any limit acceptable by the authority having jurisdiction. The tent must be reinspected in the event of any high wind or accumulating snow.</p> <p>4. Open flame and heating and cooking sources are not permitted within the tent.</p> <p>5. This variance shall expire on June 26, 2026.</p>	
26-03-92	Tractor Supply Tent Sale	Madison	2014 Fire Cod Ch. 31	3103.5	Approved with IDHS Condition(s)	<p>1. The applicant shall comply with all state and manufacturer's requirements for operation of tent.</p> <p>2. The tent shall be inspected weekly for purposes of ensuring its structural stability and identifying any apparent safety hazards. If during an inspection it is found that the tent's structural stability has been compromised or another safety hazard exists, the tent shall not be occupied until the issue has been remedied.</p> <p>3. The tent shall not be occupied in the event of any actual or forecasted accumulating snow or high wind event, which exceeds any manufacturer or installer recommendations or, if neither exist any limit acceptable by the authority having jurisdiction. The tent must be reinspected in the event of any</p>	04/08/2026

**IDHS Variance Determinations Report
Determinations Issued Between April 2, 2026, May 5, 2026**

						<p>high wind or accumulating snow. 4. Open flame and heating and cooking sources are not permitted within the tent. 5. This variance shall expire on June 26, 2026.</p>	
26-03-93	Tractor Supply Tent Sale	Whitley	2014 Fire Cod Ch. 31	3103.5	Approved with IDHS Condition(s)	<p>1. The applicant shall comply with all state and manufacturer's requirements for operation of tent. 2. The tent shall be inspected weekly for purposes of ensuring its structural stability and identifying any apparent safety hazards. If during an inspection it is found that the tent's structural stability has been compromised or another safety hazard exists, the tent shall not be occupied until the issue has been remedied. 3. The tent shall not be occupied in the event of any actual or forecasted accumulating snow or high wind event, which exceeds any manufacturer or installer recommendations or, if neither exist any limit acceptable by the authority having jurisdiction. The tent must be reinspected in the event of any high wind or accumulating snow. 4. Open flame and heating and cooking sources are not permitted within the tent. 5. This variance shall expire on June 26, 2026.</p>	04/08/2026
26-03-94	Tractor Supply Tent Sale	Noble	2014 Fire Cod Ch. 31	3103.5	Approved with IDHS Condition(s)	<p>1. The applicant shall comply with all state and manufacturer's requirements for operation of tent. 2. The tent shall be inspected weekly for purposes of ensuring its structural stability and identifying any apparent safety hazards. If during an inspection it is found that the</p>	04/08/2026

**IDHS Variance Determinations Report
Determinations Issued Between April 2, 2026, May 5, 2026**

						<p>tent's structural stability has been compromised or another safety hazard exists, the tent shall not be occupied until the issue has been remedied.</p> <p>3. The tent shall not be occupied in the event of any actual or forecasted accumulating snow or high wind event, which exceeds any manufacturer or installer recommendations or, if neither exist any limit acceptable by the authority having jurisdiction. The tent must be reinspected in the event of any high wind or accumulating snow.</p> <p>4. Open flame and heating and cooking sources are not permitted within the tent.</p> <p>5. This variance shall expire on June 26, 2026.</p>	
26-03-95	Tractor Supply Tent Sale	Grant	2014 Fire Cod Ch. 31	3103.5	Approved with IDHS Condition(s)	<p>1. The applicant shall comply with all state and manufacturer's requirements for operation of tent.</p> <p>2. The tent shall be inspected weekly for purposes of ensuring its structural stability and identifying any apparent safety hazards. If during an inspection it is found that the tent's structural stability has been compromised or another safety hazard exists, the tent shall not be occupied until the issue has been remedied.</p> <p>3. The tent shall not be occupied in the event of any actual or forecasted accumulating snow or high wind event, which exceeds any manufacturer or installer recommendations or, if neither exist any limit acceptable by the authority having jurisdiction. The tent must be reinspected in the event of any</p>	04/08/2026

**IDHS Variance Determinations Report
Determinations Issued Between April 2, 2026, May 5, 2026**

						<p>high wind or accumulating snow. 4. Open flame and heating and cooking sources are not permitted within the tent. 5. This variance shall expire on June 26, 2026.</p>	
26-03-96	Tractor Supply Tent Sale	St Joseph	2014 Fire Cod Ch. 31	3103.5	Approved with IDHS Condition(s)	<p>1. The applicant shall comply with all state and manufacturer's requirements for operation of tent. 2. The tent shall be inspected weekly for purposes of ensuring its structural stability and identifying any apparent safety hazards. If during an inspection it is found that the tent's structural stability has been compromised or another safety hazard exists, the tent shall not be occupied until the issue has been remedied. 3. The tent shall not be occupied in the event of any actual or forecasted accumulating snow or high wind event, which exceeds any manufacturer or installer recommendations or, if neither exist any limit acceptable by the authority having jurisdiction. The tent must be reinspected in the event of any high wind or accumulating snow. 4. Open flame and heating and cooking sources are not permitted within the tent. 5. This variance shall expire on June 26, 2026.</p>	04/08/2026
26-03-97	Tractor Supply Tent Sale	Tipton	2014 Fire Cod Ch. 31	3103.5	Approved with IDHS Condition(s)	<p>1. The applicant shall comply with all state and manufacturer's requirements for operation of tent. 2. The tent shall be inspected weekly for purposes of ensuring its structural stability and identifying any apparent safety hazards. If during an inspection it is found that the</p>	04/08/2026

**IDHS Variance Determinations Report
Determinations Issued Between April 2, 2026, May 5, 2026**

						<p>tent's structural stability has been compromised or another safety hazard exists, the tent shall not be occupied until the issue has been remedied.</p> <p>3. The tent shall not be occupied in the event of any actual or forecasted accumulating snow or high wind event, which exceeds any manufacturer or installer recommendations or, if neither exist any limit acceptable by the authority having jurisdiction. The tent must be reinspected in the event of any high wind or accumulating snow.</p> <p>4. Open flame and heating and cooking sources are not permitted within the tent.</p> <p>5. This variance shall expire on June 26, 2026.</p>	
26-03-98	Tractor Supply Tent Sale	Randolph	2014 Fire Cod Ch. 31	3103.5	Approved with IDHS Condition(s)	<p>1. The applicant shall comply with all state and manufacturer's requirements for operation of tent.</p> <p>2. The tent shall be inspected weekly for purposes of ensuring its structural stability and identifying any apparent safety hazards. If during an inspection it is found that the tent's structural stability has been compromised or another safety hazard exists, the tent shall not be occupied until the issue has been remedied.</p> <p>3. The tent shall not be occupied in the event of any actual or forecasted accumulating snow or high wind event, which exceeds any manufacturer or installer recommendations or, if neither exist any limit acceptable by the authority having jurisdiction. The tent must be reinspected in the event of any</p>	04/08/2026

**IDHS Variance Determinations Report
Determinations Issued Between April 2, 2026, May 5, 2026**

						<p>high wind or accumulating snow. 4. Open flame and heating and cooking sources are not permitted within the tent. 5. This variance shall expire on June 26, 2026.</p>	
26-03-99	Tractor Supply Tent Sale	Elkhart	2014 Fire Cod Ch. 31	3103.5	Approved with IDHS Condition(s)	<p>1. The applicant shall comply with all state and manufacturer's requirements for operation of tent. 2. The tent shall be inspected weekly for purposes of ensuring its structural stability and identifying any apparent safety hazards. If during an inspection it is found that the tent's structural stability has been compromised or another safety hazard exists, the tent shall not be occupied until the issue has been remedied. 3. The tent shall not be occupied in the event of any actual or forecasted accumulating snow or high wind event, which exceeds any manufacturer or installer recommendations or, if neither exist any limit acceptable by the authority having jurisdiction. The tent must be reinspected in the event of any high wind or accumulating snow. 4. Open flame and heating and cooking sources are not permitted within the tent. 5. This variance shall expire on June 26, 2026.</p>	04/08/2026
26-04-01	Tractor Supply Tent Sale	Allen	2014 Fire Cod Ch. 31	3103.5	Approved with IDHS Condition(s)	<p>1. The applicant shall comply with all state and manufacturer's requirements for operation of tent. 2. The tent shall be inspected weekly for purposes of ensuring its structural stability and identifying any apparent safety hazards. If during an inspection it is found that the</p>	04/08/2026

**IDHS Variance Determinations Report
Determinations Issued Between April 2, 2026, May 5, 2026**

						<p>tent's structural stability has been compromised or another safety hazard exists, the tent shall not be occupied until the issue has been remedied.</p> <p>3. The tent shall not be occupied in the event of any actual or forecasted accumulating snow or high wind event, which exceeds any manufacturer or installer recommendations or, if neither exist any limit acceptable by the authority having jurisdiction. The tent must be reinspected in the event of any high wind or accumulating snow.</p> <p>4. Open flame and heating and cooking sources are not permitted within the tent.</p> <p>5. This variance shall expire on June 26, 2026.</p>	
26-04-02	Tractor Supply Tent Sale	Noble	2014 Fire Cod Ch. 31	3103.5	Approved with IDHS Condition(s)	<p>1. The applicant shall comply with all state and manufacturer's requirements for operation of tent.</p> <p>2. The tent shall be inspected weekly for purposes of ensuring its structural stability and identifying any apparent safety hazards. If during an inspection it is found that the tent's structural stability has been compromised or another safety hazard exists, the tent shall not be occupied until the issue has been remedied.</p> <p>3. The tent shall not be occupied in the event of any actual or forecasted accumulating snow or high wind event, which exceeds any manufacturer or installer recommendations or, if neither exist any limit acceptable by the authority having jurisdiction. The tent must be reinspected in the event of any</p>	04/08/2026

**IDHS Variance Determinations Report
Determinations Issued Between April 2, 2026, May 5, 2026**

						<p>high wind or accumulating snow. 4. Open flame and heating and cooking sources are not permitted within the tent. 5. This variance shall expire on June 26, 2026.</p>	
26-04-03	Tractor Supply Tent Sale	Jay	2014 Fire Cod Ch. 31	3103.5	Approved with IDHS Condition(s)	<p>1. The applicant shall comply with all state and manufacturer's requirements for operation of tent. 2. The tent shall be inspected weekly for purposes of ensuring its structural stability and identifying any apparent safety hazards. If during an inspection it is found that the tent's structural stability has been compromised or another safety hazard exists, the tent shall not be occupied until the issue has been remedied. 3. The tent shall not be occupied in the event of any actual or forecasted accumulating snow or high wind event, which exceeds any manufacturer or installer recommendations or, if neither exist any limit acceptable by the authority having jurisdiction. The tent must be reinspected in the event of any high wind or accumulating snow. 4. Open flame and heating and cooking sources are not permitted within the tent. 5. This variance shall expire on June 26, 2026.</p>	04/08/2026
26-04-04	Tractor Supply Tent Sale	Huntington	2014 Fire Cod Ch. 31	3103.5	Approved with IDHS Condition(s)	<p>1. The applicant shall comply with all state and manufacturer's requirements for operation of tent. 2. The tent shall be inspected weekly for purposes of ensuring its structural stability and identifying any apparent safety hazards. If during an inspection it is found that the</p>	04/08/2026

**IDHS Variance Determinations Report
Determinations Issued Between April 2, 2026, May 5, 2026**

						<p>tent's structural stability has been compromised or another safety hazard exists, the tent shall not be occupied until the issue has been remedied.</p> <p>3. The tent shall not be occupied in the event of any actual or forecasted accumulating snow or high wind event, which exceeds any manufacturer or installer recommendations or, if neither exist any limit acceptable by the authority having jurisdiction. The tent must be reinspected in the event of any high wind or accumulating snow.</p> <p>4. Open flame and heating and cooking sources are not permitted within the tent.</p> <p>5. This variance shall expire on June 26, 2026.</p>	
26-04-05	Tractor Supply Tent Sale	Starke	2014 Fire Cod Ch. 31	3103.5	Approved with IDHS Condition(s)	<p>1. The applicant shall comply with all state and manufacturer's requirements for operation of tent.</p> <p>2. The tent shall be inspected weekly for purposes of ensuring its structural stability and identifying any apparent safety hazards. If during an inspection it is found that the tent's structural stability has been compromised or another safety hazard exists, the tent shall not be occupied until the issue has been remedied.</p> <p>3. The tent shall not be occupied in the event of any actual or forecasted accumulating snow or high wind event, which exceeds any manufacturer or installer recommendations or, if neither exist any limit acceptable by the authority having jurisdiction. The tent must be reinspected in the event of any</p>	04/08/2026

**IDHS Variance Determinations Report
Determinations Issued Between April 2, 2026, May 5, 2026**

						<p>high wind or accumulating snow. 4. Open flame and heating and cooking sources are not permitted within the tent. 5. This variance shall expire on June 26, 2026.</p>	
26-04-06	Tractor Supply Tent Sale	Delaware	2014 Fire Cod Ch. 31	3103.5	Approved with IDHS Condition(s)	<p>1. The applicant shall comply with all state and manufacturer's requirements for operation of tent. 2. The tent shall be inspected weekly for purposes of ensuring its structural stability and identifying any apparent safety hazards. If during an inspection it is found that the tent's structural stability has been compromised or another safety hazard exists, the tent shall not be occupied until the issue has been remedied. 3. The tent shall not be occupied in the event of any actual or forecasted accumulating snow or high wind event, which exceeds any manufacturer or installer recommendations or, if neither exist any limit acceptable by the authority having jurisdiction. The tent must be reinspected in the event of any high wind or accumulating snow. 4. Open flame and heating and cooking sources are not permitted within the tent. 5. This variance shall expire on June 26, 2026.</p>	04/08/2026
26-04-07							
26-04-08	301 Columbia Restaurant	Tippecanoe	2014 IMC	507.9	Approved as Submitted		04/08/2026
26-04-09	Ft Branch Fire Station Upgrade	Gibson	12-4-12 Existing Buildings; Additions or Alterations 2014 IBC	1109.2	Approved as Submitted		04/08/2026

**IDHS Variance Determinations Report
Determinations Issued Between April 2, 2026, May 5, 2026**

26-04-10(a)	Stop Venezuelan Food	Hamilton	1989 Indiana Plumbing Code (675 IAC 16-1.2)	407 407.1	Not Approved	Applicant has not demonstrated that non-compliance with the rule will not be adverse to the public health, safety, or welfare.	04/10/2026
26-04-10(b)	Stop Venezuelan Food	Hamilton	2014 InBC	2902.1	Not Approved	Applicant has not demonstrated that non-compliance with the rule will not be adverse to the public health, safety, or welfare.	04/10/2026
26-04-11(a)	Lyons Hall Selective Renovation	St Joseph	2014 IBC	3004.1	Approved as Submitted		04/10/2026
26-04-11(b)	Lyons Hall Selective Renovation	St Joseph	2014 IBC	Table 803.9	Approved as Submitted		04/10/2026
26-04-11(c)	Lyons Hall Selective Renovation	St Joseph	2014 IBC	716.5	Approved as Submitted		04/10/2026
26-04-11(d)	Lyons Hall Selective Renovation	St Joseph	2014 IBC	1018.6	Approved as Submitted		04/10/2026
26-04-12	Tractor Supply Tent Sale	Vanderburgh	2014 Fire Cod Ch. 31	3103.5	Approved with IDHS Condition(s)	<p>1. The applicant shall comply with all state and manufacturer's requirements for operation of tent.</p> <p>2. The tent shall be inspected weekly for purposes of ensuring its structural stability and identifying any apparent safety hazards. If during an inspection it is found that the tent's structural stability has been compromised or another safety hazard exists, the tent shall not be occupied until the issue has been remedied.</p> <p>3. The tent shall not be occupied in the event of any actual or forecasted accumulating snow or high wind event, which exceeds any manufacturer or installer recommendations or, if neither exist any limit acceptable by the authority having jurisdiction. The tent must be reinspected in the event of any high wind or accumulating snow.</p>	04/10/2026

**IDHS Variance Determinations Report
Determinations Issued Between April 2, 2026, May 5, 2026**

						<p>4. Open flame and heating and cooking sources are not permitted within the tent. 5. This variance shall expire on June 26, 2026.</p>	
26-04-13	Tractor Supply Tent Sale	Allen	2014 Fire Cod Ch. 31	3103.5	Approved with IDHS Condition(s)	<p>1. The applicant shall comply with all state and manufacturer's requirements for operation of tent. 2. The tent shall be inspected weekly for purposes of ensuring its structural stability and identifying any apparent safety hazards. If during an inspection it is found that the tent's structural stability has been compromised or another safety hazard exists, the tent shall not be occupied until the issue has been remedied. 3. The tent shall not be occupied in the event of any actual or forecasted accumulating snow or high wind event, which exceeds any manufacturer or installer recommendations or, if neither exist any limit acceptable by the authority having jurisdiction. The tent must be reinspected in the event of any high wind or accumulating snow. 4. Open flame and heating and cooking sources are not permitted within the tent. 5. This variance shall expire on June 26, 2026.</p>	04/10/2026
26-04-14(a)	Lille Boone Community Center	Marion	2014 IBC	1208.2	Approved with IDHS Condition(s)	<p>Signage stating low clearance shall be posted at all affected areas.</p>	04/10/2026
26-04-14(b)	Lille Boone Community Center	Marion	2014 IBC	505.2	Approved with IDHS Condition(s)	<p>Signage stating low clearance shall be posted at all affected areas.</p>	04/10/2026
26-04-15(a)	The Alan (Kilgore Place)	Delaware	ASME A17.1-2007	2.22.1.1	Approved as Submitted		04/10/2026
26-04-15(b)	The Alan (Kilgore Place)	Delaware	ASME A17.1	2.18.5.1	Approved as Submitted		04/10/2026

IDHS Variance Determinations Report
Determinations Issued Between April 2, 2026, May 5, 2026

26-04-15(c)	The Alan (Kilgore Place)	Delaware	ASME A17.1-2007	2.20.1	Approved as Submitted		04/10/2026
26-04-16(a)	Lebanon Plant (LMF) Building LW103	Boone	2014 IFC	5004.7	Approved as Submitted		04/15/2026
26-04-16(b)	Lebanon Plant (LMF) Building LW103	Boone	2014 IFC	5004.3.1	Approved as Submitted		04/15/2026
26-04-17(a)	Lebanon Plant (LMF) Building LW105	Boone	2014 IFC	5004.7	Approved as Submitted		04/15/2026
26-04-17(b)	Lebanon Plant (LMF) Building LW105	Boone	2014 IFC	5004.3.1	Approved as Submitted		04/15/2026
26-04-18	Lebanon Plant (LMF) Building LW107	Boone	2014 IFC	5004.3.1	Approved as Submitted		04/15/2026
26-04-19	Lebanon Plant (LMF) Building LW107	Boone	2014 IFC	5004.7	Approved as Submitted		04/15/2026
26-04-20	Lebanon Plant (LMF) Building LW101	Boone	2014 IFC	5004.7	Approved as Submitted		04/15/2026
26-04-21	Lebanon Plant (LMF) Building LW106	Boone	2014 IFC	5004.3.1	Approved as Submitted		04/15/2026
26-04-22	Lebanon Plant (LMF) Building LW106	Boone	2014 IFC	5004.7	Approved as Submitted		04/15/2026
26-04-23	Project Louie 2	Morgan	675 IAC	12-6-11-(c)	Approved as Submitted		04/15/2026
26-04-24(a)	Elmwood Primary Early Learning Ctr Renovation	Miami	2014 IBC	716.5	Approved as Submitted		04/15/2026
26-04-24(b)	Elmwood Primary Early Learning Ctr Renovation	Miami	2014 IBC	1018.1	Approved as Submitted		04/15/2026
26-04-25(a)	Blair Pointe Upper Elementary School Renovations	Miami	2014 IBC	716.5	Approved as Submitted		04/15/2026
26-04-25(b)	Blair Pointe Upper Elementary School Renovations	Miami	2014 IBC	1018.1	Approved as Submitted		04/15/2026
26-04-26(a)	Howard County Sheriff's Office & Jail	Howard	2014 IBC	408.9	Approved as Submitted		04/15/2026

IDHS Variance Determinations Report
Determinations Issued Between April 2, 2026, May 5, 2026

26-04-26(b)	Howard County Sheriff's Office & Jail	Howard	2010 NFPA 13 Installation of Sprinkler Systems (675 IAC 28-1-5)	8.5.5.3.1	Approved as Submitted		04/15/2026
26-04-26(c)	Howard County Sheriff's Office & Jail	Howard	2014 IBC	904.2	Approved as Submitted		04/15/2026
26-04-26(d)	Howard County Sheriff's Office & Jail	Howard	2014 IBC	Table 509	Approved as Submitted		04/15/2026
26-04-26(e)	Howard County Sheriff's Office & Jail	Howard	2014 IBC	408.7	Approved as Submitted		04/15/2026
26-04-27	Kilgore Place	Delaware	2014 IFC	905.4.1	Approved as Submitted		04/15/2026
26-04-28	AutoZone #615 – Muncie	Delaware	2010 Indiana Energy Conservation Code (675 IAC 19-4)	5.4.3.4 – VESTIBULES	Approved as Submitted		04/15/2026
26-04-29	Wabash Village Condos HVAC	Tippecanoe	2014 IMC	1102.2	Approved as Submitted		04/15/2026
26-04-30	Arlington Road Apartments	Monroe	InBC 2014	1009.9	Approved as Submitted		04/15/2026
26-04-31	CBK Enterprises Fuel Tank	Allen	2014 InFC	2306.2.3	Not Approved	Applicant has not demonstrated undo hardship. Applicant has not demonstrated that non-compliance with the rule will not be adverse to the public health, safety, or welfare.	04/15/2026
26-04-32(a)	Discovery World Inc.	Marion	2010 NFPA 13 Installation of Sprinkler Systems (675 IAC 28-1-5)		Withdrawn		04/15/2026
26-04-32(b)	Discovery World Inc.	Marion	2002 NFPA 72 National Fire Alarm Code (675 IAC 28-1-28)		Withdrawn		04/15/2026
26-04-32(c)	Discovery World Inc.	Marion	2014 IBC	907.2.6	Withdrawn		04/15/2026
26-04-32(d)	Discovery World Inc.	Marion			Withdrawn		04/15/2026
26-04-32(e)	Discovery World Inc.	Marion	2014 IBC	903.2.6	Withdrawn		04/15/2026
26-04-32(f)	Discovery World Inc.	Marion			Withdrawn		04/15/2026

IDHS Variance Determinations Report
Determinations Issued Between April 2, 2026, May 5, 2026

26-04-33	Solar Installation for Kyle Elementary School	Porter	2009 Indiana Electrical Code (675 IAC 17-1.8)	110.13(A)	Approved as Submitted		04/15/2026
26-04-34	Solar Installation for Central Elementary Sch	Porter	2009 Indiana Electrical Code (675 IAC 17-1.8)	110.13(A)	Approved as Submitted		04/15/2026
26-04-35	AutoZone 10787	Hamilton	2010 Indiana Energy Conservation Code (675 IAC 19-4)	5.4.3.4 – VESTIBULES	Approved as Submitted		04/15/2026
26-04-36(a)	Home 2 Suites	Dearborn	ASME A17.1-2007	2.18.5.1	Approved as Submitted		04/16/2026
26-04-36(b)	Home 2 Suites	Dearborn	ASME A17.1-2007	2.20.4	Approved as Submitted		04/16/2026
26-04-36(c)	Home 2 Suites	Dearborn	ASME A17.1-2007	2.22.1	Approved as Submitted		04/16/2026
26-04-37	St. Andrews Fire Marshal Report	Ripley	2014 IFC	1030.6	Approved as Submitted		04/16/2026
26-04-38	Boiler Park Tent	Marion	2014 IFC	3103.5	Approved with IDHS Condition(s)	<p>1. The applicant shall comply with all state and manufacturer's requirements for operation of tent.</p> <p>2. The tent shall be inspected weekly for purposes of ensuring its structural stability and identifying any apparent safety hazards. If during an inspection it is found that the tent's structural stability has been compromised or another safety hazard exists, the tent shall not be occupied until the issue has been remedied.</p> <p>3. The tent shall not be occupied in the event of any actual or forecasted accumulating snow or high wind event, which exceeds any manufacturer or installer recommendations or, if neither exist any limit acceptable by the authority having jurisdiction. The tent must be reinspected in the event of any high wind or accumulating snow.</p>	04/16/2026

**IDHS Variance Determinations Report
Determinations Issued Between April 2, 2026, May 5, 2026**

						<p>4. Open flame and heating and cooking sources are not permitted within the tent. 5. This variance shall expire on May 20, 2026.</p>	
26-04-39	Botanical Seasonal Tents	Allen	2014 Fire Cod Ch. 31	3103.5	Approved with IDHS Condition(s)	<p>1. The applicant shall comply with all state and manufacturer's requirements for operation of tent. 2. The tent shall be inspected weekly for purposes of ensuring its structural stability and identifying any apparent safety hazards. If during an inspection it is found that the tent's structural stability has been compromised or another safety hazard exists, the tent shall not be occupied until the issue has been remedied. 3. The tent shall not be occupied in the event of any actual or forecasted accumulating snow or high wind event, which exceeds any manufacturer or installer recommendations or, if neither exist any limit acceptable by the authority having jurisdiction. The tent must be reinspected in the event of any high wind or accumulating snow. 4. Open flame and heating and cooking sources are not permitted within the tent. 5. This structure shall not be erected for more than one hundred and eighty (180) days in a calendar year.</p>	04/16/2026
26-04-40(a)	M93 Elevator Addition	Marion	2014 IBC	716.5, 716.6	Approved as Submitted		04/16/2026
26-04-40(b)	M93 Elevator Addition	Marion	2014 IBC	713.4	Approved with IDHS Condition(s)	<p>Variance (b): Glass enclosures are permitted, provided that each individual pane is laminated and marked in accordance with the</p>	04/16/2026

IDHS Variance Determinations Report
Determinations Issued Between April 2, 2026, May 5, 2026

						applicable standards, ensuring that these markings remain visible after installation.	
26-04-41	The Village at 10 th and College	Monroe	2014 IBC	Table 601	Approved as Submitted		04/20/2026
26-04-42	Charity Cares Early Academy at Sheffield	Marion	IBC 2014	903.2.6	Approved as Submitted		04/21/2026
26-04-43	La Tolteca	Allen	2014 IBC	903.2.1.2	Approved as Submitted		04/21/2026
26-04-44	Lebanon Plant (LMF) Building LW107	Boone	2014 IBC	1008.1.7	Approved as Submitted		04/21/2026
26-04-45	Melao Cuban Café	Johnson	2014 IBC	2902.2 Separate Facil	Approved as Submitted		04/21/2026
26-04-46	Walnut Builders Solar Array Installation	Monroe	1014 IBC	1013.6	Approved as Submitted		04/21/2026
26-04-47	Vigo County YMCA Phase II-A	Vigo	2014 IBC	706.1	Approved as Submitted		04/21/2026
26-04-48	Pfeiffer House	Allen	2014 IBC	2902.2	Approved as Submitted		04/21/2026
26-04-49	Bachelor Creek Church of Christ Sanctuary Renovation	Wabash	12-4-12 Existing Buildings; Additions or Alterations GAR 675 IAC	12-4- 12(f)	Approved as Submitted		04/21/2026
26-04-50	Lick Ice Cream Commercial Kitchen Buildout	Marion	2014 InMC	507.9	Approved as Submitted		04/21/2026
26-04-51	Emanuel Lutheran Church Elevator	Allen	2007 ASME A17.1	2.8.1	Approved as Submitted		04/21/2026
26-04-52	Poly-Wood Building 2 Shipping/Receiving Expansion	Kosciusko	2014 IBC	507.3	Approved as Submitted		04/24/2026
26-04-53	Tractor Supply Tent Sale	Wabash	2014 Fire Cod Ch. 31	3103.5	Approved with IDHS Condition(s)	1. The applicant shall comply with all state and manufacturer's requirements for operation of tent. 2. The tent shall be inspected weekly for purposes of ensuring its structural stability and identifying any apparent safety hazards. If during an inspection it is found that the	04/24/2026

**IDHS Variance Determinations Report
Determinations Issued Between April 2, 2026, May 5, 2026**

						<p>tent's structural stability has been compromised or another safety hazard exists, the tent shall not be occupied until the issue has been remedied.</p> <p>3. The tent shall not be occupied in the event of any actual or forecasted accumulating snow or high wind event, which exceeds any manufacturer or installer recommendations or, if neither exist any limit acceptable by the authority having jurisdiction. The tent must be reinspected in the event of any high wind or accumulating snow.</p> <p>4. Open flame and heating and cooking sources are not permitted within the tent.</p> <p>5. This variance shall expire June 26, 2026.</p>	
26-04-54	GEM Inc Temporary Storage	Allen	2014 Fire Cod Ch. 31	3103.5	Approved with IDHS Condition(s)	<p>1. The applicant shall comply with all state and manufacturer's requirements for operation of tent.</p> <p>2. The tent shall be inspected weekly for purposes of ensuring its structural stability and identifying any apparent safety hazards. If during an inspection it is found that the tent's structural stability has been compromised or another safety hazard exists, the tent shall not be occupied until the issue has been remedied.</p> <p>3. The tent shall not be occupied in the event of any actual or forecasted accumulating snow or high wind event, which exceeds any manufacturer or installer recommendations or, if neither exist any limit acceptable by the authority having jurisdiction. The tent must be reinspected in the event of any</p>	04/24/2026

**IDHS Variance Determinations Report
Determinations Issued Between April 2, 2026, May 5, 2026**

						high wind or accumulating snow. 4. Open flame and heating and cooking sources are not permitted within the tent. 5. This variance shall expire July 31, 2026.	
26-04-55	Lebanon Plant (LMF) Building LW110	Boone	2014 IBC	1008.1.9.9	Approved as Submitted		04/24/2026
26-04-56	Solar Installation for Myers Elementary School	Porter	2009 Indiana Electrical Code (675 IAC 17-1.8)	110.13(A)	Approved as Submitted		04/24/2026
26-04-57	The Cooper House	Allen	12-4-11 Change of Occupancy or Use of Existing Buildings 675 IAC	12-4-11(b)	Approved with IDHS Condition(s)	This variance shall expire on April 30, 2028.	04/28/2026
26-04-58	Sweetwater Training Room	Allen	2014 IBC	508.2.1	Approved as Submitted		04/28/2026
26-04-59	Purdue University Fort Wayne	Allen	2007 ASME A17.1	2.18.5.1	Approved as Submitted		04/28/2026
26-04-60	The Preserve at Gray Eagle	Hamilton	ISPC	Rule 2, Section 17	Approved as Submitted		04/28/2026
26-04-61	Odon Locker	Daviess	2014 IBC	903.2.7	Approved as Submitted		04/28/2026
26-04-62	HUB Bloomington II	Monroe	2010 ISPC	20-2-17(b)(3)	Approved as Submitted		04/28/2026
26-04-63(a)	Trafalgar Senior Apartments	Johnson	2014 IBC	714.4.1.2	Approved as Submitted		04/28/2026
26-04-63(b)	Trafalgar Senior Apartments	Johnson	2014 IMC	1102.2	Approved as Submitted		04/28/2026
26-04-63(c)	Trafalgar Senior Apartments	Johnson	2014 IBC	1018.6	Approved as Submitted		04/28/2026
26-04-63(d)	Trafalgar Senior Apartments	Johnson	2014 IBC	716.5	Approved as Submitted		04/28/2026
26-04-64	Meridian Street United Methodist Church	Marion	2014 InBC	1103.1	Approved as Submitted		04/28/2026
26-04-65(a)	Winterton	Marion	2014 IMC	501.3.1, Item 3	Approved as Submitted		04/28/2026

IDHS Variance Determinations Report
Determinations Issued Between April 2, 2026, May 5, 2026

26-04-65(b)	Winterton	Marion	2014 IMC	1102.2	Approved as Submitted		04/28/2026
26-04-65(c)	Winterton	Marion	ISPC	Rule 2, Sec. 26(f)	Approved as Submitted		04/28/2026
26-04-65(d)	Winterton	Marion	ISPC	Rule 2, Sec. 27(a)	Approved as Submitted		04/28/2026
26-04-65(e)	Winterton	Marion	ISPC	Rule 2, Sec. 26(e)	Approved as Submitted		04/28/2026
26-04-65(f)	Winterton	Marion	2014 IBC	510.2, Condition 1	Approved as Submitted		04/28/2026
26-04-65(g)	Winterton	Marion	2014 IBC	510.2, Condition 7	Approved as Submitted		04/28/2026
26-04-65(h)	Winterton	Marion	2014 IBC	1007.2.1	Approved as Submitted		04/28/2026
26-04-65(i)	Winterton	Marion	2014 IBC	706.5	Approved as Submitted		04/28/2026
26-04-65(j)	Winterton	Marion	2014 IBC	706.5.2	Approved as Submitted		04/28/2026
26-04-65(k)	Winterton	Marion	2014 IBC	705.8	Approved as Submitted		04/28/2026
26-04-65(l)	Winterton	Marion	2014 IBC	3004.1	Approved as Submitted		04/28/2026
26-04-65(m)	Winterton	Marion	2014 IBC	714.4.1.2	Approved as Submitted		04/28/2026
26-04-65(n)	Winterton	Marion	2014 IBC	1209.2	Approved as Submitted		04/28/2026
26-04-65(o)	Winterton	Marion	2014 IMC	918.6, exc. 5.1	Approved as Submitted		04/28/2026
26-04-66	Michigan City Opportunity HUB	Laporte	12-4-11 Change of Occupancy or Use of Existing Buildings GAR	Rule 4, Section 11(b)	Approved as Submitted		04/28/2026
26-04-67(a)	Saica New Origin II	Madison	2014 IBC	904.2	Approved as Submitted		04/28/2026

**IDHS Variance Determinations Report
Determinations Issued Between April 2, 2026, May 5, 2026**

26-04-67(b)	Saica New Origin II	Madison	2014 IBC	1016.2	Approved as Submitted		04/28/2026
26-04-68(a)	Liberty Trailers – Covered Storage Bldg Add	Putnam	2014 InBC	508.2	Not Approved	Applicant has not demonstrated that non-compliance with the rule will not be adverse to the public health, safety, or welfare.	04/28/2026
26-04-68(b)	Liberty Trailers – Covered Storage Bldg Add	Putnam	2014 InBC	507.2	Not Approved	Applicant has not demonstrated that non-compliance with the rule will not be adverse to the public health, safety, or welfare.	04/28/2026
26-04-70	Folktale Greenwood Event Center LLC	Johnson	2014 InBC	903.2.1.2 Group A-2	Approved with IDHS Condition(s)	Signage at the entry door shall state maximum occupant load of 120.	04/30/2026
26-04-71	Jeff's Bagel Run	Hamilton	2014 InBC	2902.2 Exception #2	Approved as Submitted		04/30/2026
26-04-72	Hendricks Community Soccer – New Soccer Fields	Hendricks	2014 IBC	2902.1	No Variance Required	There are no class one structures on the site.	05/04/2026
26-04-73	Munster Cancer Center	Lake	675 IAC 21-3 (ASME A17.1-2007)	8.6.4.8.2	Not Approved	Applicant has not demonstrated that non-compliance with the rule will not be adverse to the public health, safety, or welfare. Elevator control room is for elevator equipment only.	05/04/2026
26-04-74	Plymouth Church Photovoltaic system DC System Size (38.72KW)	Allen	2009 Indiana Electrical Code (675 IAC 17-1.8) 2009 IEC	110.13(A)	Approved as Submitted		05/04/2026
26-04-75	Aviada Apartments	Tippecanoe	2014 IBC	1008.1.5	No Variance Required	Based on the section provided, no variance is required.	05/04/2026
26-04-76	Barlum Remodel	Marion	2020 Indiana Res Code	R311.7.6	Approved as Submitted		05/04/2026
26-04-77	Stony Creek Therapeutic Riding Facility	Hamilton	2014 IBC	503.1	Approved as Submitted		05/04/2026

Please be aware, this report is for informational purposes only. For official records of determinations, please refer to the variance database located here: <https://oas.dhs.in.gov/dfbs/variance/start.do?method=viewApplications>. Determinations contained in this report may not be final and are subject to modification./