


CITY
of
LAFAYETTE
Lafayette, Indiana 47901



FIRE
DEPT.

Indiana Fire Prevention and Building Safety Commission
302 W. Washington Street
Indianapolis, Indiana

Chairman Hawkins,

The Lafayette Fire Department has been made aware of a variance request for U Haul, Inc. 3861 South Street (Application 17465). The fire department does not oppose this variance with the conditions outlined in the application.

The conditions as outlined in the application are as follows:

The current 1 hour fire barrier separating the restaurant occupancy would have fire-stopping installed at the head-of-wall joints.

The existing fire alarm occupant notification shall be maintained in the restaurant space.

This variance would be limited to the duration of the restaurant tenant's lease, which expires July 31, 2019

The Lafayette Fire Department respectfully asks the commission take these items into consideration upon reviewing this variance request.

Respectfully,

Brian Alkire
Assistant Chief of Fire Prevention
Lafayette Fire Department
765-807-1613
blalkire@lafayette.in.gov