



PLAINFIELD FIRE TERRITORY

4010 S. CLARKS CREEK ROAD

PLAINFIELD, IN 46168

OFFICE: (317) 839 - 6939 FAX: (317) 838 - 3716

To: Mark Stuerenberg
From: Alan Trauner
RE: Cambria Suites Plainfield
Date: 4/20/2016

Mark,

This letter is to reiterate the position of the Plainfield Fire Territory on the issue of standpipes in the stairwells of the Cambria Suites at 6014 S Gateway Drive in Plainfield, Indiana.

The Plainfield Fire Territory has taken the position that the standpipes that were not installed during construction should not be required to be installed now based on the ease of access for hoselines and current sprinkler protection. The chance of damaging passive fire protection for the stairwells and other walls is increased if this kind of work is done. Our ability to quickly deploy yard and commercial hose lays into the stairwells will allow us the same capacity to fight fire as if there were standpipes.

Thank you,

Alan R. Trauner,
Investigator/Inspector
Plainfield Fire Territory
Office: 317-839-6939 Ex 18
Cell: 317-979-5820
atrauner@plainfieldfire.com