

INDIANA FIRE PREVENTION AND BUILDING SAFETY COMMISSION

SUMMARY OF PUBLIC COMMENTS RECEIVED AND STAFF RECOMMENDED RESPONSE TO PUBLIC COMMENTS LSA DOCUMENT #26-62 INDIANA ELECTRICAL CODE

Following receipt and review of all timely filed public comments on the proposed rule (LSA Document #26-62) during the second public comment period, staff provides the below summary and response to the public comment.

Summary of Public Comments

1. Oral Comment Made by Armand DeBose

Continued request for the proposed rule to address multimode inverter-based systems.

Response to Public Comment

1. Response to Oral Comments Made by Armand DeBose:

The Commission rejects this proposed change, as the language in the 2026 version of Section 702.4(A) references provisions that are not addressed in the 2023 model NEC. This would create internal inconsistency.