

Regulatory Analysis

TITLE 675 FIRE PREVENTION AND BUILDING SAFETY COMMISSION

LSA Document #XX-XXX

I. Description of Rule

a. History and Background of the Rule

The current Indiana Fire Code ([675 IAC 22-2.5](#)) was adopted in 2014 and is based on the 2012 International Fire Code. These rules establish the regulatory framework which set forth enforceable standards for fire prevention to protect life, health, and safety of building occupants and the public in Indiana.

The Indiana Fire Code Update Committee (Committee), a subcommittee of the Fire Prevention and Building Safety Commission (Commission), was tasked with reviewing the 2024 edition of the International Fire Code. The Committee made recommendations to adopt the 2024 International Fire Code, with certain amendments, as the 2026 Indiana Fire Code. Those recommendations were voted upon and unanimously approved by the Commission.

b. Scope of the Rule

The proposed rule repeals the 2014 Indiana Fire Code and replaces it with the 2026 Indiana Fire Code. Repealing and replacing the entire Indiana Fire Code is necessary due to the size and complexity of the International Fire Code. Amending existing regulations would be impractical and inadequate, as there have been a multitude of changes to the International Fire Code since 2012.

c. Statement of Need

This rule update is necessary to bring Indiana's fire prevention rules up to date with the latest advancements in technology, materials, and methods regarding fire prevention. Additionally, the new code incorporates non-rule policies and interpretations that can reduce administrative burdens and reduce construction costs without an adverse effect upon public safety.

d. Statutory Authority for the Proposed Rule

[IC 22-13-2-2](#) permits the Fire Prevention and Building Safety Commission to adopt rules for a statewide code of fire safety laws.

e. Fees, Fines, and Civil Penalties

The proposed rule does not add or increase any fees, fines, or civil penalties.

II. Fiscal Impact Analysis

a. Anticipated Effective Date of the Rule – **To Be Determined**

b. Estimated Fiscal Impact on State and Local Government – The proposed rule will not have a measurable fiscal impact on State or local government entities.

c. Sources of Expenditures or Revenues Affected by the Rule – The proposed rule will not have a measurable fiscal impact on State or local government entities.

III. Impacted Parties

The proposed rule impacts the safety and well-being of all individuals residing, visiting, or doing business in the Hoosier state. The Indiana Fire Code addresses issues with broad public safety impacts such as fire-resistant construction, fire protection systems, emergency egress, and safe storage of hazardous materials.

IV. Changes in Proposed Rule

New IAC Section	International Fire Code Section	Change
675 IAC 22-2.6-1	N/A	Adopts by reference the International Fire Code, 2024 Edition. This is the model building code being adopted with revisions as set out in this proposed rule.
675 IAC 22-2.6-2	101.1	Deletes the text of this section and inserts as follows: “This rule shall be known as the 2026 Indiana Fire Code. Wherever the term “this code” is used throughout this rule, it shall mean the 2026 Indiana Fire Code.”
	101.5	Deletes the title and text of this section and inserts a new title that reads “Effect of New or Changes Rules” and inserts text regarding construction projects.
	N/A	Adds a new section 101.6 regarding conflict within the rules.
	N/A	Adds a new section 101.7 regarding a savings clause.
	N/A	Adds a new section 101.8 regarding words and phrases not defined.
	N/A	Adds a new section 101.9 that reads as follows: “Interpretation. The State Building Commissioner authorized to issue written interpretations on Rules of the Commission as set out in IC 22-13-5.”
	102.1	Amends this section to add “Class 1” before the term “structures” throughout the section.

	102.2	Amends this section to add section 102.2.1 regarding existing Class 1 structures.
	102.3	Deletes the title and text of this section and inserts a new title “Occupancy of Existing Buildings and Change of Use or Occupancy” and inserts text corresponding with the title.
	102.4	Amends this section to add “Class 1” before “structures” and replace “international” with “Indiana.”
	102.5	Amends this section to replace “international” with “Indiana,” deletes “including, but not limited” and “Where interior or exterior systems or devices are installed, construction permits required by Section 105.6 shall apply” in item #1, and delete item #2.
	102.6	Amends this section to delete “buildings or” and add “Class 1” before “structures.”
	102.8	Amends this section by deleting the text “or by laws” in the second sentence.
	102.9	Deletes the text of this section without substitution.
	102.10	Deletes the text of this section without substitution.
	102.11	Amends this section by inserting “and that is not in conflict or more stringent with the rules of the commission, or other” between “local” and “states.”
	103.1	Deletes the text of this section and replaces it with “Local inspection and enforcement programs of the fire prevention code shall be as set out in IC 36-8-17-8 for the implementation, administration and enforcement of the provisions of this code.”
	103.2	Amends this section by replacing the word “jurisdiction” with “political subdivision.”
	103.3	Deletes the title and text of this section and replaces it with: “Local Ordinance. In accordance with IC 22-13-2 as may be amended from time to time, a city, town or county is permitted to adopt an ordinance which incorporates by reference the rules of the commission.”
	104	Amends this section by deleting the word “fire” without substitution.
	104.1	Amends this section by inserting “State Fire Marshal and their designees, or” between the words “The” and “code.”

	104.2	Amends this section by inserting “State Fire Marshal and their designees, or” between the words “The” and “code.”
	104.2	Amends this section to add items #3 and #4 regarding not creating requirements in conflict with the code and regarding interpretations of the State Building Commissioner.
	104.2.2.2	Amends this section modifying preparer qualifications.
	104.2.3	Deletes the text of this section and replaces it with language regarding this section not authorizing any variances. Also deletes the exception.
	104.2.3.3	Deletes the text of this section and replaces it with language regarding what evidence the code official may accept as evidence of compliance.
	104.2.3.6.2	Amends this section to delete the words “qualified engineer, specialist, laboratory” in the second and third sentences and replace with “registered design professional.”
	104.2.3.7	Deletes this section in its entirety without substitution.
	104.2.4	Deletes this section, and its subsections, and replaces with “Variances to this code may be granted in accordance with IC 22-13-2-11.”
	104.3	Amends this section by deleting “receive application” in the first line and deleting “issue permits for construction regulated by this code” in the second line.
	104.7	Deletes the text of this section and replaces it with language regarding where a local fire prevention ordinance has, or has not, been adopted by the jurisdiction.
	104.7.1	Deletes this section in its entirety and re-numbers the remainder of the sections.
	104.7.4	Amends the title of this section by deleting the phrases “and modified” and “for either” without substitution.
	104.7.6	Deletes this section without substitution.
	104.8	Deletes this section and its subsections without substitution.
	104.9.1	Amends this section to add “by the code official” at the end of the sentence.
	104.10 104.11	Deletes these section and their subsections without substitution.
	105.1	Amends this section to replace “shall be” with “may be.”

	105.1.1	Amends this section to add the following at the end of the section: “from the appropriate code official.”
	105.1.2	Amends this section to delete the text of item #2 and replace it with: “Construction permits shall be obtained from the code official for the political subdivision who is responsible for the issuance of building permits and enforcement of the rule of the commission applicable to construction.”
	105.1.3	Amends this section to insert an exception that reads: “Building permits required to be issued by the code official responsible for the enforcement of the rules of the commission for construction.”
	105.1.4	Amends this section to add the word “by” after “submitted,” delete the word “within,” delete the word “working,” and delete text after the word “official.”
	105.1.5	Amends this section to delete the word “structure” in the 1 st line.
	105.1.6	Deletes this section and its subsection in their entirety without substitution.
	105.2	Amends this section to delete “fire code official” and replacing it with “political subdivision.”
	105.2.1	Delete this section in its entirety without substitution and renumber the remaining subsections.
	105.2.2	Amends this section to renumber it as 105.2.1 and delete the text of the section and replace it with “Before a new operational permit is issued the code official is authorized to inspect the premises, or areas to be used to determine compliance with this code or any operational constraints required.”
	105.2.3	Amends this section to renumber it as 105.2.2 and delete “work or” in the 1 st line without substitution.
	105.2.4	Amends this section by renumbering it as 105.2.3 and replaces the word “shall” with “may” in the 3 rd line.
	105.3	Deletes the text of this section and replaces with language regarding permits.
	105.3.1	Deletes the text of this section and replaces it with language regarding an operational permit.

	105.3.2	Amends this section by deleting the phrase “for periods of not more than 180 days each” without substitution.
	105.3.3 105.3.4	Deletes these sections in their entirety without substitution.
	105.3.6	Deletes the text of this section and replaces it with language regarding compliance with code.
	105.3.7	Deletes the text of this section and replaces it with language regarding information on a permit.
	105.3.8	Deletes the text of this section and replaces it with language regarding the validity of a permit.
	105.4	Amends this section to delete the phrase “or construction documents” without substitution and insert “or any other rule of the commission at the end of item #7.
	105.5.3 105.5.5	Deletes these sections in their entirety without substitution.
	105.5.12	Amends this section by deleting the word “jurisdiction” and replacing it with “political subdivision.”
	105.5.35 105.5.36 105.5.37 105.5.41 105.5.42 105.5.47 106.6	Deletes these sections in their entirety without substitution.
	106.1	Deletes the title and text of the section and replaces it with: “Design Release. This section does not relieve the owner, contractor or Indiana Licensed Design Professional from obtaining a design release as required by IC 22-15-3 and IC 22-15-3.2.”
	106.2	Amends this section to delete the word “shall” and replace it with “may” and delete the word “construction” without substitution.
	106.2.1	Amends this section to delete the word “construction” without substitution throughout the section.
	106.2.2	Amends this section to insert the phrase “applicable standard” between the words “code” and “and” and delete the word “construction.”
	106.2.4	Deletes the title and text of this section and replaces it with a new section regarding documents accepted by the code official.

	106.2.4.1	Deletes this section in its entirety without substitution.
	106.3	Deletes the title and text of this section and replace it with a new section regarding approved documents.
	106.4	Deletes the title and text of this section and replace it with a new section regarding retention of documents.
	107.1	Deletes the text of this section and replaces it with language regarding permits for temporary structures, uses, equipment, or systems.
	107.2	Amends this section to delete the phrase “this code” and replace it with “the rules of the commission.”
	107.3	Deletes this section in its entirety without substitution.
	107.4	Deletes the text of this section and replaces it with language regarding termination of approval.
	108	Deletes this section in its entirety without substitution.
	109.1	Deletes the text of this section and replaces it with language regarding inspection authority.
	109.2	Amends this section to delete the phrase “a responsible officer of such approved agency or by the responsible individual” and replace it with “code official.”
	109.2.1	Renumbers existing section 109.2.1 as section 109.2.2 and renumber existing 109.2.2 as 109.2.3. Insert a new section 109.2.1 regarding inspections.
	109.2.2	Amends section 109.2.2 (formerly 109.2.1) to insert the word “owner” between “the” and “holder” in each instance.
	109.2.3	Amends section 109.2.3 (formerly 109.2.2) by inserting the words “owner or” in the 4th line between the words “the” and “permit” and deleting the words “his or her” between the words “or” and agent” and inserting the words “their duly authorized.”
	109.3	Amends this section by inserting the phrase “owner or” between the words “the” and “permit.”
	110	Deletes the title and text of this section and insert a new section regarding maintenance of existing building and structures.
	111	Deletes the title and text of this section and insert a new section regarding existing

		buildings, additions, alterations, and moved buildings.
	112	Deletes the title and text of this section and inserts a new section regarding variances.
	113.1	Amends this section by inserting “or any other rule of the commission” between the words “code” and “or” and adding “or any other rule of the commission” at the end of the sentence.
	113.3	Amends this section to delete the word “authorized” and replace it with “required” and insert the phrase “as set out in IC 36-7-2-9.5” between the words “violation” and “describing.”
	113.3.3	Deletes the text of this section and replaces it with language regarding prosecution of violations.
	113.4	Deletes the text of this section and replaces it with new language regarding violation penalties.
	114.1	Amends this section to insert “or any other rule of the commission” after “of this code” in each instance.
	114.2	Amends this section to insert the phrase “citing the specific rule of the commission, chapter and section” between the words “order” and “and,” and insert the following after the last sentence: “The stop work order shall cite, by section number, the rule of the commission which was violated.”
	114.3	Amends this section to insert the following after the last sentence: “Written notice shall be provided to the owner, owner’s representative within twenty-four (24) hours of stopping said work.”
	114.4	Amends this section to insert the following after the last sentence: “Written notice shall be provided to persons required to comply with the order within 24 hours of stopping said work and shall comply with IC 4-21.5-4-3.”
	115	Amends the title of this section to read: “Unsafe Buildings and Structures or Equipment.”
	115.1	Deletes the text of this section and insert: “For Unsafe Building or structure or equipment see the political subdivision Code of Ordinances for adoption by reference IC 36-7-9 unsafe structures.”

	115.1.1 115.1.2 115.2 115.3 115.4 115.5 115.6 115.7	Deletes these sections in their entirety without substation.
675 IAC 22-2.6-3	201.3	Deletes the text of this section and inserts: “Where terms are not defined in this code and are defined in the Indiana Building Code (675 IAC 13), Indiana Electrical Code (675 IAC 17), Indiana Fuel Gas Code (675 IAC 25), Indiana Mechanical Code (675 IAC 18), Indiana Energy Conservation Code (675 IAC 19), or Indiana Plumbing Code (675 IAC 16), such terms shall have the meanings ascribed to them as in those codes.”
	202	Amends this section to add, delete, and amend definitions.
	203.11	Deletes the text of this section and inserts language regarding Group U occupancies.
675 IAC 22-2.6-4	301.2	Deletes the text of this section and inserts “See Section 105 of this code.”
	302	Amends this section to add various equestrian-related definitions.
	303.5	Amends this section to add the phrase “dry chemical” between the words “portable” and “fire” in each instance.
	304.1.1	Deletes the text of this section and inserts: “Valet trash collection shall be permitted in accordance with the provisions of Section 304.4 of this code.”
	304.1.3	Amends this section to delete the last sentence in its entirety without substitution.
	304.2	Deletes the text of this section and inserts: “Storage of combustible rubbish shall not produce conditions that will create a hazard to the public health, safety, or welfare.”
	N/A	Adds a new section 304.4 regarding valet trash.
	307.1.1	Deletes the title and text of this section and inserts a new title and text regarding discontinuance of open burning.
	307.2	Deletes the title and text of this section and inserts a new title and text as follows: “Notification. Prior to commencement of open burning, the servicing fire department shall be notified.”

	307.2.1	Deletes the title and text of this section and inserts a new title and text as follows: “Material restrictions. Open burning of rubbish is prohibited.”
	307.3	Deletes this section in its entirety without substitution.
	308.1.3	Amends this section to insert the word “operable” between the words “the” and “water” in the first sentence and insert the following after the last sentence: “Prior to using a torch or flame-producing device to remove paint from a structure, the servicing fire department shall be notified.”
	308.1.5	Amends this section to delete the text after the word “areas” and insert the phrase “except when approved.”
	308.2	Amends this section to delete the phrase “permits required” and insert “notification required” and delete the text “permits shall be obtained from the fire code official in accordance with Section 105.5” and replace with “The servicing fire department shall be notified.”
	311.1.1	Deletes this section in its entirety without substitution.
	311.2.2	Amends this section to insert the following at the end of each exception: “The premises shall be identified in accordance with Section 901.7.2 and 901.7.3.”
	311.5	Deletes the text of this section and insert the following: “Any vacant or abandoned buildings or structures determined to be unsafe shall be marked as required by local ordinance.”
	311.5.1 311.5.2 311.5.3 311.5.4 311.5.5	Deletes these sections in their entirety without substitution.
	314.2	Amends this section to insert “and secured” between the words “arranged” and “so.”
	315.2	Deletes this section in its entirety without substitution.
	316.6.2	Amends this section to delete the text of the exception and insert a new exception regarding combustible storage.
	316.2.2 316.3.1	Deletes these sections in their entirety without substitution.
	319.10	Deletes the text of this section and replaces it with language regarding technical assistance.

	320.4.2.1	Deletes the text of this section and replaces it with the following: “The report shall be submitted by a design profession as defined in 675 IAC 12-6-2(d), to the fire code official, and shall be subject to their approval.”
	N/A	Inserts a new section 323 regarding equestrian facilities.
	N/A	Inserts a new section 324 regarding haunted houses and similar installations.
675 IAC 22-2.6-5	N/A	Adds a new section 403.11.4 regarding overcrowding.
675 IAC 22-2.6-6	503.1.1	Amends this section to delete the existing exceptions and insert the following: “Exception: Buildings protected throughout by a supervised automatic fire sprinkler systems and not used for high-piled combustible storage in excess of twelve thousand (12,000) square feet.”
	N/A	Adds a new section 503.1.4 regarding exterior storage of finished lumber and solid biofuels products.
	503.2.8	Deletes the text of this section and inserts new language regarding angles of approach and departure.
	503.4.1	Deletes the text of this section and inserts the following: “Traffic calming devices installed on fire department access roads shall comply with Section 503.2.”
	505.1	Deletes the title and text of this section and inserts a new section regarding Address identifications where there are local unit of governments requirements.
	505.2	Deletes the title and text of this section and inserts a new section regarding Address identifications where there are no local unit of governments requirements.
	N/A	Adds a new section 505.2.1 regarding address identification.
	N/A	Adds a new table 505.2.1 regarding address identification.
	N/A	Adds a new section 505.2.2 regarding address identification in a complex with multiple Class 1 structures.
	506.1	Amends this section to delete the last sentence and replace with the following: “The key box shall be compatible with the fire department’s key box system and shall contain keys to gain necessary access as required by the fire code official.”

	510.1	Deletes the text of this section, leaving all exceptions remaining, and insert new language regarding emergency responder communications. Inserts and Except #5 that reads as follows: “ERCES equipment within dwelling units of R-2, R-3, and R-4.”
	510.2 510.3	Deletes these sections in their entirety without substitution.
	510.4	Amends this section to insert “and shall be in accordance with 47 CFR 90.219 and the current edition of NFPA 1221 and NFPA 1225” after “510.4.2.8.”
	510.4.1	Deletes the text of this section and inserts: “The building shall be considered to have an acceptable in-building emergency responder communications enhancement system where signal strength measurements in 95 percent of all areas on each floor of the building meet the signal strength requirement in Section 510.1.”
	510.4.1.1	Deletes this section in its entirety without substitution.
	510.4.1.2	Amends this section to renumber it as 510.4.1.1.
	510.4.1.3	Amends this section to renumber it as 510.4.1.2.
675 IAC 22-2.6-7	903.2.8	Amends this section to add an exception that reads: “In a fire or ambulance station, an automatic sprinkler system may be provided throughout the Group R fire area when separated from the remainder of the building in accordance with Section 508.4 and the NS column of Table 508.4.”
	903.3.1.1.1	Amends this section to delete the text of Item #4 and replace it with the following: “Elevator equipment rooms and hoistways used exclusively for the operation of elevators and that are separated from the remainder of the building in accordance with Section 713 of the Indiana Building Code. Penetrations between machine rooms and hoistways necessary for the safe operation of an elevator, and vents required by Section 3004 of this code need not be fire-rated.”
	905.12	Deletes this section in its entirety without substitution.
	906.1	Deletes the text of this section and inserts the following: “Portable fire extinguishers shall be installed where required by Table 906.1.”

	907.2.1.1	Amends this section to add Exception #2 and Exception #3 regarding stadiums, arenas, and grandstands.
	907.2.3	Amends this section to delete “that initiates the occupant notifications signal utilizing an emergency voice/alarm communication system meeting the requirements of Section 907.5.2.2 and installed in accordance with Section 907.6” without substitution.
	907.2.3	Amends this section to delete Exception 4.2.
675 IAC 22-2.6-8	1103	Deletes this section in its entirety without substitution.
675 IAC 22-2.6-9	3206.7.5	Amends this section to delete the text in the Exception and insert the following: “In buildings having ESFR sprinkler systems, a minimum of one (1) access door shall be provided in each two hundred twenty-five (225) lineal feet (sixty-eight thousand five hundred eighty (68,580 mm), or fraction thereof of the exterior walls which face the required fire apparatus access road. Spacing between doors shall not exceed two hundred twenty-five (225) lineal feet.”
	N/A	Adds a new section 3206.9.1 regarding hose connections at access doors.
675 IAC 22-2.6-10	4104.2	Amends this section to delete the word “operated” in the first paragraph and replace it with the word “located” and delete Exception #3 in its entirety without substitution.
675 IAC 22-2.6-11	Chapter 80	Amends this chapter to add reference to appropriate Indiana Administrative Code provisions.
675 IAC 22-2.6-12	Appendices	Amends this chapter to delete Appendix A through Appendix O.
675 IAC 22-2.7	N/A	Repeals the 2014 Indiana Fire Code, 675 IAC 22-2.5.

V. Benefit Analysis

a. Estimate of Primary and Direct Benefits of the Rule

The overarching direct benefit of this rule update is the benefit to public health and safety. This rule update brings Indiana’s fire code up to date with the latest advancements in technology, materials, and methods regarding fire prevention. This will ensure that

regulated structures in Indiana properly address fire prevention to safeguard public health and safety.

Another direct benefit of this rule update is that it eliminates the need for certain variance applications. As the Indiana Fire Code has not been updated since 2014, IDHS regularly receives variance applications seeking to comply with a more recent version of the International Fire Code. If this rule is updated, many of those variances would not be necessary. This reduces compliance costs for consumers by eliminating variance application fees, reducing costs to hire professional code consultants, and eliminating the time necessary for pursuing the unnecessary variances.

Eliminating unnecessary variance applications would also have the direct benefit of reducing IDHS staff time spent processing such applications.

b. Estimate of Secondary or Indirect Benefits of the Rule

As discussed above, this rule update would eliminate unnecessary variance applications that are currently needed to comply with more recent versions of the International Fire Code. The time and resources currently allocated by businesses to pursue these variances could then be used to increase business profitability. Additionally, IDHS staff can allocate time to other agency duties.

c. Estimate of Any Cost Savings to Regulated Industries

As discussed in Section V(a), above, eliminating unnecessary variance applications would save regulated industries the costs of variance applications. These costs are typically at least \$276 per application.

VI. Cost Analysis

a. Estimate of Compliance Costs for Regulated Entities – The Indiana Fire Code is a companion to the Indiana Building Code. The Building Code regulates new construction. The Fire Code regulates some aspects of new construction and regulates the ongoing risk from fire and explosion in existing buildings and sites. Many sections of the two codes overlap. Therefore, cost analysis was conducted in consideration of both codes being adopted together. A detailed evaluation of costs was prepared and shows that the fiscal impact on the regulated community as a whole is an overall reduction in economic cost of \$4,695,636 projected with the adoption of both codes. A detailed cost analysis is attached as a spreadsheet.

b. Estimate of Administrative Expenses Imposed by the Rules – The proposed rule does not impose any additional administrative expenses.

c. The fees, fines, and civil penalties analysis required by IC 4-22-2-19.6 – The proposed rule does not add or increase any fees, fines, or civil penalties.

d. If the implementation costs of the proposed rule are expected to exceed the threshold set in IC 4-22-2-22.7(c)(6) – Implementation and compliance costs of the

proposed rule is less five hundred thousand dollars (\$500,000) for businesses, units, and individuals over any two (2) year period.

VII. Sources of Information

The Indiana Fire Code Update Committee held more than 20 meetings over a multi-year process of developing the costs analysis for the proposed rule. The Committee relied upon several sources of information in developing the analysis, including the following:

- The United States Bureau of Economic Analysis (BEA) data regarding gross domestic product of Indiana by industry. This data can be found on the BEA website at <https://www.bea.gov/data/gdp/gdp-industry>.
- The Association of General Contractors of America (AGC) fact sheet titled “The Economic Impact of Construction in the United States and Indiana.” The fact sheet can be found on the AGC website at https://www.agc.org/sites/default/files/users/user21902/IN-US%20construction%20fact%20sheet_2025_V2.pdf.
- The National Centers for Environmental Information (NOAA) report “U.S. 2024 Billion-Dollar Weather and Climate Disasters. The report can be found on the NOAA website at <https://www.ncei.noaa.gov/access/billions/>.
- The U.S. Chamber of Commerce 2024 Climate Resiliency Report, found on the U.S. Chamber of Commerce website at <https://www.uschamber.com/security/the-preparedness-payoff-the-economic-benefits-of-investing-in-climate-resilience>.
- The National Institute of Standards and Technology (NIST) Technical Note 2214 titled “Economic Analysis of ASCE 7-22 Tornado Load Requirements.” The technical note can be found on the NIST website at <https://nvlpubs.nist.gov/nistpubs/TechnicalNotes/NIST.TN.2214.pdf>.

VIII. Regulatory Analysis

As outlined above, adoption of the proposed rule will have a broad benefit to public health and safety while also reducing economic costs by \$4,695,636 when adopted along with the proposed Indiana Building Code. Accordingly, the Fire Prevention and Building Safety Commission has determined that cost reduction and the benefits of bringing Indiana’s Fire Code up to date with the latest advancements in technology, materials, and methods regarding fire prevention support adoption of the proposed rule.

IX. Contact Information of Staff to Answer Substantive Questions

Trevor Hale – Deputy General Counsel – trhale@dhs.in.gov