

**INDIANA DEPARTMENT OF ADMINISTRATION  
PUBLIC WORKS PROJECT NO. 300DM-07012-34-C1  
STRAHL LAKE DAM REHABILITATION  
BROWN COUNTY STATE PARK**

**Addendum No. 1**

Issue Date: Thursday, April 11, 2024      Quote Date: **April 25, 2024**

---

The purpose of this Addendum is to make changes, additions, deletions, revisions and clarifications to the quote documents for the solicitation referenced above. Bidders shall review the Addendum requirements in detail and incorporate any effects the Addendum may have in their quote price.

**Bidders must acknowledge receipt of any and all Addenda on the Bid Form.** Failure to do so may result in rejection of the Quote. All requirements of the bidding documents remain unchanged except as cited herein.

In response to bidder inquiries, please note the following confirmations and clarifications:

I. Questions and Clarifications

Clarifications regarding the temporary creek crossing and construction access to site:

- Reminder that there will be no excavation for the creek crossing. Specified geotextile to be laid at grade to facilitate restoration work after project completion.
- Pedestrian sidewalk shall be protected from construction traffic and restored to previous condition post construction
- Split rail fence may need taken down to access site and restored post construction
- Construction access to site can be made from SR135 to Horseman Camp Rd
- Pedestrian walkway can be closed off during weekly construction depending on reservations. Coordinate with property manager Scott Crossley for shelter schedule.

Clarifications on the timeline and project:

- All questions need submit by April 18<sup>th</sup>.
- Bid is due on April 25<sup>th</sup>, will be opened via a Teams Call
- Notice to proceed possibly mid-May to beginning of June.
- Substantial completion August 23rd.
- Allowance for remediation of 25k
- Remember the drug free workplace document to submit with the bid.

**Q.** *Does the park want to keep the stone and/or 36" piping from the temporary creek crossing once removed?*

**A.** Contractor has the option of leaving material with the property manager if they do not desire to haul off but it is not required. Coordinate with Scott Crossley on disposal site.

**Q.** *Any weight restrictions on the ACBM's?*

**A.** Keep heavy equipment traffic to below the crest of the dam.

**Q.** *Any operable valve stem on the upstream end of the 12" drawdown pipe?*

**A.** There is a gate valve in the valve chamber but does not need to be touched. Plan is to just grout that all in place.

**Q.** *Is the Davis-Bacon wage rates required for this project?*

**A.** No.

**Q.** *Is there polyurethane grout required for the existing pipe?*

**A.** No, all grout should be cementitious-bentonite mixture as described in the specs.

**Q.** *Does the flexamat need tied into the ACBM's? Is the fill under the flexamat specified out?*

**A.** No. The intention of the regrade and flexamat is mainly for ease of maintenance. Do not alter the existing ACBM's. Yes, the fill material is specified out and consists of INDOT #23 sand, washed pea gravel and topsoil per the plans.

**Q.** *Are all cracks and joints for the principal spillway being sealed?*

**A.** Yes, all cracks and joints.

**Q.** *Topsoil available on site?*

**A.** Currently no topsoil is available for the Stake Park to provide for this project. Please bid assuming you need to haul in topsoil from your own source.

---

This Addendum consists of 3 pages including attachments.

Attachments:

1. Pre-Bid sign-in sheet – 1 page
2. Video footage of 12-inch Ductile pipe segment - .mp4 via Onedrive Link

**THE BIDDER MUST ACKNOWLEDGE RECEIPT OF THIS ADDENDUM NO. 1 BY ACKNOWLEDGEMENT ON THE BID FORM. FAILURE TO DO SO CAN BE CAUSE FOR BID REJECTION.**

**Certified By:**



---

Joseph Miller, P.E.

## Indiana Department of Natural Resources, Division of Engineering

Strahl Lake Dam

Pre-Bid Meeting 300DM-07012-34-35

Thursday, April 11, 2024

**Dam Rehabilitation**

Company Name	Address	Telephone - Office	E-mail Address
<b>Representative</b>			
DNR - Engineering Dave Nance	402 W. Washington St. RM 299 Indianapolis, IN 46204	317-234-1111	<a href="mailto:dnance@dnr.IN.gov">dnance@dnr.IN.gov</a>
DNR - Engineering Jomary Baller	402 W. Washington St. RM 299 Indianapolis, IN 46204	317-234-8731	<a href="mailto:jballer@dnr.IN.gov">jballer@dnr.IN.gov</a>
DNR - Engineering Zach Bell	402 W. Washington St. RM 299 Indianapolis, IN 46204	812-322-1585	<a href="mailto:zabell@dnr.IN.gov">zabell@dnr.IN.gov</a>
DNR - State Parks Scott Crossley	1405 State Road 46 West Nashville, IN 47448	812988-6406	<a href="mailto:SCrossley@dnr.IN.gov">SCrossley@dnr.IN.gov</a>
Banning Engineering Inc. Joe Miller	853 Columbia Rd., Suite 101 Plainfield, IN 46168	317-707-3736	<a href="mailto:jmiller@banning-eng.com">jmiller@banning-eng.com</a>
Banning Engineering Inc. Max Kolb	853 Columbia Rd., Suite 101 Plainfield, IN 46168	317-707-3737	<a href="mailto:mkolb@banning-eng.com">mkolb@banning-eng.com</a>
R.L. Vuckson John Bruce	PO Box 391 Scottsberg, IN 47170	812 525-7185	bruce.jd@icloud.com
R.L. Vuckson RICHARD VUCKSON	PO Box 391 SCOTTSBERG IN 47170	812-525-4265	RLVX@AOL.COM
IDDA PLO Michael Mathias	402 W. Washington St.	812-296-0097	<a href="mailto:mmathias1@idnr.in.gov">mmathias1@idnr.in.gov</a>
Dexter Childress OMni Earth works	82701 W 1100 S Huntingberg, IN 47542	812-683-1518	<a href="mailto:OMni@omniEarthworks.com">OMni@omniEarthworks.com</a>
WILLIAMS CREEK CAROL SCHAMBERG	4620 S. CR 600E PLAINFIELD, IN 46168	317-838-9810	<a href="mailto:CSchaumborg@WilliamsCreekMgt.net">CSchaumborg@WilliamsCreekMgt.net</a>