

**INDIANA DEPARTMENT OF ADMINISTRATION
PUBLIC WORKS PROJECT NO. 300DM-07013-04-C1
CHERRY LAKE DAM REHABILITATION
MORGAN-MONROE STATE FOREST**

Addendum No. 1

Issue Date: Wednesday, October 11th, 2023 Quote Date: **October 18th, 2023**

The purpose of this Addendum is to make changes, additions, deletions, revisions and clarifications to the quote documents for the solicitation referenced above. Bidders shall review the Addendum requirements in detail and incorporate any effects the Addendum may have in their quote price.

Bidders must acknowledge receipt of any and all Addenda on the Bid Form. Failure to do so may result in rejection of the Quote. All requirements of the bidding documents remain unchanged except as cited herein.

In response to bidder inquiries, please note the following confirmations and clarifications:

I. Questions and Clarifications

Q. *Is there a disposal site for woody debris such as tree debris, stumps, etc.?*

A. Yes, disposal site is located southwest of the staging area, down Fire Headquarters Rd. Exhibit is attached to this addendum identifying disposal site. Coordination is required with property management to ensure material is appropriate for disposal.

Q. *What is the surface area of the lake to be used for pump drawdown calculations?*

A. The current surface area of the lake is approximately 2 acres. Lake drawdown must not exceed 1ft/day.

Q. *Question about construction access.*

A. Construction access to the site shall be from the staging area on the right, north side of the embankment, using DNR Fire Headquarters Rd. See attached exhibit.

Q. *Is the Davis-Bacon wage rates required for this project?*

A. No.

This Addendum consists of 2 pages including attachments.

Attachments:

1. Disposal Site and Construction Access Exhibit – 1 page

THE BIDDER MUST ACKNOWLEDGE RECEIPT OF THIS ADDENDUM NO. 1 BY ACKNOWLEDGEMENT ON THE BID FORM. FAILURE TO DO SO CAN BE CAUSE FOR BID REJECTION.

Certified By:



Joseph Miller, P.E.

Find address or place

Map navigation controls: +, -, Home, Refresh, Measure, etc.



Woody Debris Disposal

Fire Headquarters Road

Staging Area

Cherry Lake

Morgan-Monroe State Forest HQ

- Tree debris, stumps etc. disposal will be provided near the site and on property as shown on this map.
- The surface area of the lake at normal pool is approximately 2 acres.
- Construction access to the site shall be from the staging area on the right, north side of the embankment, using DNR Fire Headquarters Road, as shown on this map.