

**ADDENDUM NO. 1
TO
CONSTRUCTION DOCUMENTS**

FOR PROJECT NO. **ENG1902899363**

DESCRIPTION: **Office Remodel**

LOCATION: **Crosley Fish & Wildlife Area**

FOR AGENCY: **Department of Natural Resources**

The information contained in this Addendum shall become a part of the basic plans and specifications the same as if originally incorporated therein. The original plans and specifications shall remain in their entirety, except as modified by this Addendum. The items herein shall supersede information in the specifications and on the plans.

Item No. 1: Electrical Plan Sheet No. E-1

Revise the Lighting Plan on Sheet E-1 to include two additional light fixtures "A" for a total of six (vs. four) in the following rooms:

Foyer (01)

Office (04)

Office (05)

Office (06)

Fixture location shall be "concentric": three fixtures in the long dimension and two fixtures in the short dimension. For example in an 11'x6' room, three fixtures will be located 2'8" from the end walls and 5'4" apart in the 11' length. The two fixtures will be located at 2'9" from the walls and 5'6" apart in the 6' length. Other room fixture locations shall be located in the same fashion. Branch circuitry shall remain the same to include the additional two fixtures.

END OF ADDENDUM