

**DATE: November 8, 2023**

**CLARIFICATION NO. 1**  
**TO**  
**CONSTRUCTION DOCUMENTS**  
**FOR PROJECT NO. E008341**

**DESCRIPTION:**     **AML SITE 2333, BLACKBURN ROAD GROUTING**

**LOCATION:**         **PIKE COUNTY, INDIANA**

**FOR AGENCY:**     **DEPARTMENT OF NATURAL RESOURCES**

The information contained in this Clarification is intended to correct any composition errors and serve to eliminate any misunderstanding of the basic plans and specifications the same as if being originally incorporated therein.

**ITEM NO. 1:**

Grout mix specifications

As detailed in Section 701 General Provisions, subsection 704.04 Grout Mixes, all grout mix designs shall be determined by the Contractor and approved by the Engineer. Each mix should utilize varying proportions of fly ash, sand or pea gravel, cement, and water to obtain the minimum unconfined compressive strength as stated in the mix designs, and the water/cement ratios shall not exceed those of the design mix for each design slump.

**END OF CLARIFICATION**