



Clarification to Questions

ENG2303758614

Miami Boat Ramp Replacement Mississinewa Reservoir

Questions for Miami Boat Ramp

1. Where are you wanting the topsoil placed? Is this for disturbed areas or in a certain location?
 - a. The topsoil should be placed under the Mulched Seeding, Type R. The topsoil should be for the disturbed areas.
2. Can you please clarify the dimensions of the pea gravel area for the pressure relief drains?
 - a. The dimensions of the pea gravel are 6" deep and 6" wide.
3. What are the limits of the longitudinal grooving?
 - a. The limits are for the whole PCCP boat ramp.
4. From a subcontractor: "Per the grooving detail we are not comfortable performing this work as the liability outweighs the opportunity. It is going to be very difficult to accomplish grooving at a 45-degree angle starting at zero and going to an inch deep in 12", along with maintaining 6" off curb at a 45-degree angle. If they would approve of standard grooving practices, we would be happy to provide you with a quotation." – Could we get the 45-degrees to be made shallower (like 15-20 degrees for example) or simply horizontal if the grooves aren't being used for drainage?
 - a. Horizontal grooves are acceptable.