

Date: 02/26/2024

Addendum No. 4

**For Project No. ENG2403729029
INDIANA DUNES STATE PARK – LWCF
DOUBLE VAULT TOILETS
1600 N 25 E, CHESTERTON, IN 46304**

ISSUED FROM: Engineering Division Dept. Natural Resources

ISSUE DATE: February 26, 2024

BID DATE: March 7, 2024

FOR AGENCY: Department of Natural Resources

The information contained in this Addendum shall become a part of the basic plans and specifications the same as if original incorporated therein. The original plans and specifications shall remain in their entirety, except as modified by this Addendum. The items herein shall supersede information in the specifications and on the plans.

ITEM No. 1: GENERAL

- A. Clarifications to additional questions received after the pre-bid meeting have been included as part of this addendum.

ITEM No. 2: CONSTRUCTION DRAWINGS

N/A

ITEM No. 3: SPECIFICATIONS

N/A

END OF ADDENDUM

State Form 21208R4

DAPW-118

CLARIFICATIONS TO QUESTIONS RECEIVED AFTER PRE-BID MEETING:

1. Question – “The concrete spec is calling for 24” turned down edges. Please confirm this applies to the aprons and parking space only and not sidewalks.”
Answer – The 24” turned down edges are required at aprons and new accessible parking slabs. For sidewalks, the 24” turned down edges are only required at site-specific sidewalk locations which transition to asphalt.