Addendum No. 3

For Project No. ENG2403730319 Lincoln Amphitheatre Improvements Lincoln State Park Spencer County

ISSUED FROM: Engineering Division Dept. Natural Resources

ISSUE DATE: April 8, 2024

BID DATE: April 25, 2024

FOR AGENCY: Department of Natural Resources

The information contained in this Addendum shall become a part of the basic plans and specifications the same as if original incorporated therein. The original plans and specifications shall remain in their entirety, except as modified by this Addendum. The items herein shall supersede information in the specifications and on the plans.

ITEM No. 1: GENERAL

A. Change: Notice to Bidders Bid Date from April 11th, 2024 to:

The new bid date and time of 2:31 P.M. (Indianapolis Time) on April 25th, 2024.

- B. Change: DAPW 13 State Form 34894 Page 2 Alternates. Replace with attached revised page 2.
- C. Attached clarifications and additions to the drawings and specifications.

State Form 21208R4

DAPW-118

ALTERNATE BIDS

Add Alternates Are Not to be included as part of the Base Bid Scope of Work.

Deduct Alternates are items of work that Are to be included in the Base Bid Scope of Work, and deducted from the project as described herein.

The work shall be as described in Section, ALTERNATES.

APPLICABLE BOX for each listed alternate.

Bidder shall provide a response to each alternate specified. Response must indicate the amount to be ADDED to the base bid, DEDUCTED from the base bid, or that there is NO CHANGE.

Failure to respond to all alternates may cause the bid to be rejected. BIDDER SHALL CHECK

Alternate No	ADD	DEDUCT	NO CHANGE	AMOUNT \$
Alternate No	ADD	DEDUCT	NO CHANGE	AMOUNT \$
Alternate No	ADD	DEDUCT	NO CHANGE	AMOUNT \$
Alternate No	ADD	DEDUCT	NO CHANGE	AMOUNT \$
Alternate No	ADD	DEDUCT	NO CHANGE	AMOUNT \$
Alternate No	ADD	DEDUCT	NO CHANGE	AMOUNT \$
Alternate No	ADD	DEDUCT	NO CHANGE	AMOUNT \$
Alternate No	ADD	DEDUCT	NO CHANGE	AMOUNT \$
Alternate No	ADD	DEDUCT	NO CHANGE	AMOUNT \$
Alternate No	ADD	DEDUCT	NO CHANGE	AMOUNT \$
Alternate No	ADD	DEDUCT	NO CHANGE	AMOUNT \$
Alternate No	ADD	DEDUCT	NO CHANGE	AMOUNT \$

State Form 34894 Page 2 of 3 DAPW 13 Rev 10/13

Re: Lincoln Amphitheatre

Phase 3&4 - Amphitheatre Improvements

Lincoln City, IN Project #: LA23102

DNR Project #: ENG2403730319

ADDENDUM #3 - REVISED

This addendum is to become a part of the Contract Documents and shall be properly acknowledged and dated on the Bid Form by the Bidding Contractor.

- "E & D Specialty Stands, Inc.". Has been approved for bidding purposes. Final seating structure design approval will be based on pending shop drawings.
- "Southern Bleacher Co". Has been approved for the seating structure bidding purposes. Final seating structure design approval will be based on pending shop drawings.
- "Dant Clayton" Has been approved for the seating structure bidding purposes. Final seating structure design approval will be based on pending shop drawings.
- 4. Rubber base is intended for the alcohol sales areas in building "B". 4" epoxy cove base matching the epoxy floor system is intended for the new restroom additions (building "B" base bid and Alternate #2 of building "D").
- 5. The only ductwork to be routed below ceiling is AHU-1, AHU-3A and AHU-3B main trunks. All branch duct supplied by the system shall be routed above ceiling within the attic space.
- 6. Sheet E1 No disconnect is required for Panelboards C1 or B on Alternate Bid #2.
- Sheet E4 Note 3: Framing is by E.C. If the contractor damages the bird screen they are to replace or repair to match existing. Also, unless noted otherwise, the conduit used for outdoor applications is to match existing.
- 8. Water piping is not restricted to copper only. All acceptable water piping is listed in the Plumbing Specification Section C Note 1 on Sheet P2.
 - a. All water piping by Plumbing Contractor. All water piping underground shall be type "K" copper or PEX. All piping above ground shall be type "L" copper, CPVC (SCHD 40) or PEX. (PEX shall have inside diameter equal to type "L" copper called out on plans). All copper joints shall be made with wrought copper fittings using lead free solder. If CPVC or PEX is used it shall have an inside diameter equal to or greater than that of type "L" copper of the sizes shown on the plans for 1" and larger pipe.

Note: No sheets have been included within this Addendum #3. Also note that all sub contractors (including bleacher seating system supplier/installers) with contract amounts above \$150,000 are also required to be prequalified to work with the Public Works Division in the State of Indiana. See the link below for information and a link within the webpage to apply for contractor prequalification.

https://www.in.gov/idoa/state-property-and-facilities/public-works/certification-board/

Universal Design Associates, Inc.

Jason A. Brown, AIA Project Architect