

**Addendum No. 1**

**For Project No. ENG2403731028  
McCORMICK'S CREEK STATE PARK – LWCF  
DOUBLE VAULT TOILETS  
250 MCCORMICK CREEK PARK RD, SPENCER, INDIANA 47460**

**ISSUED FROM: Engineering Division Dept. Natural Resources**

**ISSUE DATE: February 23, 2024**

**BID DATE: March 14, 2024**

**FOR AGENCY: Department of Natural Resources**

**The information contained in this Addendum shall become a part of the basic plans and specifications the same as if original incorporated therein. The original plans and specifications shall remain in their entirety, except as modified by this Addendum. The items herein shall supersede information in the specifications and on the plans.**

**ITEM No. 1: GENERAL**

- A. Attached, please find a copy of the pre-bid meeting sign-in sheet and pre-bid meeting agenda with a summary of the discussion and clarifications.
- B. SITE PLANS were modified to include additional notes and clarifications with a revision date of 02/23/2024.
- C. SUMMARY OF WORK was modified to clarify project Base Bids and project Alternates.

**ITEM No. 2: CONSTRUCTION DRAWINGS**

- A. **MODIFIED** - SITE PLAN – McCormick's Creek SP – Friendly Shelter Location
  - a. Moved double vault building, apron, and ADA parking more to the South.
  - b. Modified note for ADA accessible parking and signage. Reference attached drawings for additional information.
  - c. Added note, "(2) Accessible parking spaces to remain."
  - d. Modified seed mix information. Reference attached drawings for additional information.
  - e. Added 10' contour lines.

- B. **MODIFIED** - SITE PLAN – McCormick’s Creek SP – Beech Grove Location
  - a. Modified note for ADA accessible parking and signage.
  - b. Modified note for removal of existing vault toilets. Reference attached drawings for additional information.
  - c. Modified seed mix information. Reference attached drawings for additional information.
  - d. Added 10’ contour lines.

### **ITEM No. 3: SPECIFICATIONS**

- A. **MODIFIED** - SECTION 01 11 00 – SUMMARY OF WORK
  - a. On page 2, added clarification for project Base Bids.
  - b. On page 2, added clarification for project Alternates.
- B. **MODIFIED** - SECTION 01 21 00 – ALLOWANCES
  - a. Changed required allowance amount from \$10,000.00 to \$2,500.00. Reference attached SECTION 01 21 00 for additional information.
- C. **MODIFIED** – SECTION 03 45 38 – PRECAST DOUBLE VAULT TOILET:
  - a. On page 6, added specifications for 2' x 2' Orange Polyester Hatch Safety Net. Reference attached SECTION 03 45 38 for additional information.

**END OF ADDENDUM**

**State Form 21208R4**

**DAPW-118**