

Addendum No. 3

**For Project No. ENG2602893355
Shooting Range Improvements
Wilbur Wright FWA**

**ISSUED FROM: Division of Facilities, Fleet, Asset Management, and
Engineering Dept. Natural Resources**

ISSUE DATE: December 1, 2025

BID DATE: December 9, 2025

FOR AGENCY: Department of Natural Resources

The information contained in this Addendum shall become a part of the basic plans and specifications the same as if original incorporated therein. The original plans and specifications shall remain in their entirety, except as modified by this Addendum. The items herein shall supersede information in the specifications and on the plans.

ITEM No. 1: GENERAL

A. Email Question Submissions:

1. Question: Is the soil excavated for footers and piers expected to be screened for lead and treated in addition to the already specified soils?
Answer: No
2. Question: With soil treatment, is there a desired soil pH in the final outcome?
Answer: No
3. Question: Is soil treatment expected to achieve a specific level of heavy metals leachability? I.E. pass a post treatment TCLP test?
Answer: No
4. Question: What are the targeted metals and the targeted leachability values?
Answer: No
5. Question: Is it expected of the remediation contractor to recover lead shot or just pistol/rifle rounds from the 100yd range?

Answer: Per the scope of work: Remove a minimum 90% (weight percent) of lead bullets and fragments greater than ¼” from the soil as measured in samples taken before and after.

6. Question: Is any kind of soil testing prior to lead recovery and treatment required?
Answer: No

7. Question: Do you have a location in mind for the gas tank? My vendor is needing more detail for his quote on how much line will be needed. I know where it sits now roughly, but as far as a spot on the property could you advise on this matter.
Answer: Bid to include the assumption of 100’-0” of line from tank to heater.

8. Question: I wanted to ask about Site Restrictions. Are we to have our own on site portalet? Office Trailer? Dumpster? Connex for storage?
Answer: The property has a portalet on site. If contractor needs are for more than one, this will need to be included in the bid. Office trailer, dumpster, and storage are per contractor needs, not a project requirement. The owner is not responsible for site security.

END OF ADDENDUM

State Form 21208R4

DAPW-118