

Sheet1

	STANDARD	DESCRIPTION	TOT	SER	WIL	REP	OTH
1	1910.1200(e)(1)	HAZCOM - No written HAZCOM program	108	33	0	0	75
2	1910.1200(h)	HAZCOM - Employee information & training	63	34	0	1	28
3	1926.404(f)(6)	Grounding	60	7	0	13	40
4	1926.150(c)(1)(i)	Fire extinguishers not provided	54	3	0	4	47
5	1926.501(b)(1)	No fall protection system when working >6' above lower level	49	42	2	0	5
6	1926.451(e)(1)	Height of mobile scaffold >4 times min. base dimensions	45	30	0	5	10
7	1910.1200(f)(5)(i)	HAZCOM - Chemical containers not marked with identity	44	5	0	3	36
8	1926.21(b)(2)	Failure to instruct employee in recognition of hazards	44	33	0	0	11
9	1910.1200(g)(1)	HAZCOM - No MSDS for each hazardous chemical	43	27	0	1	15
10	1926.100(a)	Hard hats not worn where required	43	33	0	1	9
11	1926.405(g)(2)(iv)	Cord grips - strain relief	42	4	0	2	36
12	1910.1200(f)(5)(ii)	HAZCOM - Chemical containers did not have warning label	37	7	0	3	27
13	1926.150(e)(1)	Fire alarm system not established	36	2	0	1	33
14	1926.652(a)(1)	Inadequate sloping in excavations	36	24	0	5	7
15	1926.20(b)(1)	No safety/health program	35	26	0	0	9
16	IAC 22-8-1-1	"General Duty" clause	32	30	0	0	2
17	1926.25(a)	Debris and scrap lumber not cleared	31	3	2	0	26
18	1926.416(e)(1)	Worn or frayed electric cords in use	31	2	0	2	27
19	1926.451(c)(2)	Guys, ties, and braces not installed properly on scaffolds	31	18	0	1	12
20	1926.451(b)(1)	Space between scaffold planks and/or uprights >1"	30	26	0	1	3
21	1926.403(h)	Panel boxes for circuits not marked or labeled	29	0	0	0	29
22	1926.550(b)(2)	No monthly inspections of critical items on cranes	29	13	0	0	16
23	1910.1200(g)(8)	HAZCOM - Employer did not maintain MSDS sheets	28	5	0	0	23
24	1926.1052(c)(1)	No handrail/stairrail on stairway with 4 or more risers	26	2	0	0	24
25	1926.405(b)(1)	Unused breaker openings not closed	25	3	0	1	21