

SECTION 200 – EARTHWORK

SECTION 201 – CLEARING AND GRUBBING

201.01 Description

This work shall consist of clearing, grubbing, removing, and disposing of all vegetation and debris, except such objects as are designated to remain or are to be removed in accordance with other sections of these specifications, within the construction limits shown on the plans. If no construction limits are shown, the right-of-way and easement areas will be the construction limits. This work shall include the preservation from injury or defacement of all vegetation and objects designated to remain. Disposal of material shall be in accordance with 203.08.

CONSTRUCTION REQUIREMENTS

201.02 General

Right-of-way lines and construction limits will be established. Trees, shrubs, plants, seeded or sodded shoulders, slopes or other things to remain will be designated. All such designated items and vegetation shall be preserved. All areas outside the construction limits shall remain in their original condition. All damage to natural terrain, vegetation, objects designated to remain, or areas outside the construction limits which have subsequently eroded or been damaged, shall be repaired or replaced in accordance with 621.11. Tree wound dressing required for cut or scarred surfaces of trees or shrubs selected for retention shall be in accordance with 914.09(c).

201.03 Clearing and Grubbing

Surface objects, trees, stumps, roots, and other protruding obstructions not designated to remain shall be cleared and grubbed, including mowing as required. Undisturbed sound stumps, roots, and non-perishable solid objects, which are a minimum of 3 ft below the final subgrade or slope of embankments, may be left, provided they are as nearly flush as possible. However, they shall not extend more than 4 in. above the ground line or low water level. Sound stumps may be cut off at ground level outside the construction limits of cut and embankment areas if approved.

Except in areas to be excavated, stump holes and other holes from which obstructions are removed shall be backfilled with suitable material and compacted in accordance with 203.23.

Burning of perishable material shall be done in accordance with applicable laws, ordinances, rules, and regulations. All necessary permit approvals shall be obtained prior to burning.

Unless burned in accordance with the requirements herein, perishable materials and debris shall be removed from the right-of-way and disposed of in accordance with 203.08. If allowed, sod may be disposed of within the right-of-way.

50 All merchantable timber in the clearing area, which has not been removed from the right-of-way prior to the beginning of construction, shall become the property of the Contractor, unless otherwise provided. The value of the timber shall be taken into account when the bid is prepared.

Low hanging branches and unsound or unsightly branches on trees or shrubs designated to remain shall be removed as directed. Branches of trees extending over the roadbed shall be trimmed to give a clear height of 20 ft above the roadbed. All trimming shall be done by skilled workers and in accordance with good tree surgery practices.

201.04 Scalping

60 Areas where excavations are to be made, or embankments are to be placed, shall be scalped to a maximum of 4 in. Scalping shall include the removal of material such as brush, roots, sod, grass, residue of agricultural crops, sawdust, and decayed vegetable matter from the surface of the ground.

201.05 Hedge Removal

Hedges and shrubs shall be pulled or grubbed in such a manner as to ensure complete and permanent removal.

201.06 Method of Measurement

70 When specified as a pay item, measurement of this work will be made by one or more of the following methods.

(a) Area Basis

The work to be measured will be the number of acres and fractions thereof acceptably cleared and grubbed within the limits shown on the plans or staked for clearing and grubbing. Areas not shown on the plans or not staked for clearing and grubbing will not be measured for payment.

(b) Lump Sum Basis

80 If clearing and grubbing is specified as a lump sum pay item, no measurement of area will be made.

(c) Individual Unit Basis

1. The diameter of trees will be measured at a height of 24 in. above the ground. Trees of less than 4 in. in diameter will be classified as brush.

201.07

90

- 2. Stumps will be measured by determining the average diameter at the cutoff location.
- 3. Scalping will be measured by the acre.
- 4. If the Schedule of Pay Items shows measurement to be on an individual unit basis, the units will be designated and measured in accordance with the schedule of sizes as follows:

	Measured Diameter at Height of 24 in.	Pay Diameter
100	4 to 8 in.	6 in.
	Over 8 to 12 in.	10 in.
	Over 12 to 24 in.	18 in.
	Over 24 to 36 in.	30 in.
	Over 36 to 60 in.	48 in.
	Over 60 in.	60 in.

201.07 Basis of Payment

The accepted quantities of clearing and grubbing will be paid for as shown below.

110

(a) Area Basis

The determined quantities will be paid for at the contract unit price per acre respectively for each of the pay items shown in the Schedule of Pay Items.

(b) Lump Sum Basis

120

If the Schedule of Pay Items shows a lump sum pay item, the lump sum price will be paid for all work shown within the construction limits. All clearing the Contractor is directed to perform outside the construction limits, including clearing for utility relocation which is for the benefit of the Department, and not simply for the Contractor's convenience, will be paid for in accordance with 104.03 or 109.03 unless such clearing is shown on the plans, in the Contract Information book, or is for the construction of fence or right-of-way markers.

(c) Individual Unit Basis

If individual unit quantities are shown in the Schedule of Pay Items, the accepted quantities will be paid for at the contract unit prices for the respective pay items.

130

Payment for tree removal sizes as designated in requirement 5 of 201.06(d), which are larger than those sizes shown as pay items, will be made on the basis of the largest size shown in the Schedule of Pay Items except as set out below.

Payment will be made under:

Pay Item	Pay Unit Symbol
Clearing and Grubbing	ACRE LS
Clearing Right-of-Way	LS
140 Scalping	ACRE
_____ , _____, Remove	EACH
name size	

Except as specified in 621, the cost of repair or replacement of terrain, vegetation, objects designated to remain, or areas outside the construction limits which have been damaged by the Contractor or have subsequently eroded, shall be included in the cost of clearing right-of-way.

(d) Clearing Right-of-Way

150 If the Schedule of Pay Items contains a lump sum pay item for clearing right-of-way, such pay item shall include the cost of all work described in this section and all of the work performed in accordance with 202 within the construction limits except for such work set out specifically as pay items or as otherwise provided for herein. All clearing the Contractor is directed to perform outside the construction limits, including clearing for utility relocation which is for the benefit of the Department, and not simply for the Contractor’s convenience, will be paid for in accordance with 104.03 or 109.03 unless such clearing is shown on the plans, in the Contract Information book, or is for the construction of fence or right-of-way markers.

(e) Exclusions

160 If the Schedule of Pay Items does not contain an estimated quantity or a lump sum pay item for work described herein except as set out above, such work will not be paid for directly. The cost thereof shall be included in the cost of other pay items.

SECTION 202 – REMOVAL OF STRUCTURES AND OBSTRUCTIONS

202.01 Description

This work shall consist of the removal, wholly or in part, and satisfactory disposal of all buildings, fences, structures, old pavement, abandoned pipe lines, abandoned tanks, and any other obstructions which are not designated or allowed to remain, except for the obstructions to be removed and disposed of under other items in the contract. It shall include the salvaging of designated materials and backfilling the resulting trenches, basements, holes, and pits.

10

CONSTRUCTION REQUIREMENTS

202.02 General Requirements

All buildings and foundations in accordance with 202.06, structures, fences, tanks, and other obstructions, any portions of which are on the right-of-way shall be razed, removed, and disposed of, except utilities and those features for which other

provisions have been made for removal. Designated salvageable material shall be removed without unnecessary damage in sections or pieces which may be transported readily and shall be stored at specified places within the project limits or as otherwise designated. Except for regulated materials, which shall be disposed of in accordance with 104.06, and bridge painting debris which is subject to 619, non-salvageable material shall be disposed of in accordance with 203.08. Unsuitable material shall be removed from cisterns, septic tanks, other tanks, basements, and cavities. The disposition of this material shall be in accordance with all applicable and current local, State and Federal regulations. Cisterns, septic tanks, other tanks, basements, and cavities shall be backfilled in an approved manner. Those which cannot be backfilled satisfactorily shall be removed. If the backfill is within the limits of construction, it shall be completed in accordance with 203.23, unless otherwise directed. All abandoned wells shall be backfilled in accordance with the Indiana Code. A copy of the driller's license shall be furnished prior to commencement of work.

In accordance with 326 IAC 14-10, the Contractor shall complete and submit a demolition/renovation notification to IDEM when demolition or renovation of buildings, houses, canopies, and bridges are part of the contract. This notification shall be submitted regardless of whether asbestos containing material is present. Fees for this demolition/renovation notification shall be paid to IDEM by the Contractor.

Copies of the demolition/renovation notification form can be obtained from the IDEM's website. Questions concerning the completion of the demolition/renovation notification should be addressed to IDEM's Office of Air Quality.

Initial notification to IDEM shall be by certified mail, return receipt requested, or by hand delivery. Verification of this notification shall be provided to the Engineer. The Contractor shall provide such notification 10 work days prior to the date on which demolition or renovation operations are anticipated to begin. If the Contractor postpones the beginning date of demolition or renovation operations, IDEM shall be provided written notice of the new start date, postmarked at least five work days or delivered at least two work days before these operations begin. Verification of this notification shall also be provided to the Engineer.

Unless otherwise specified, salvageable items removed from the construction site shall become the property of the Contractor and proper allowance for their value shall be taken into account in the bid price of the item involved. Where a house or building has been removed previously and the existing utilities and drains or sewer connections have not been terminated and sealed, this work shall be performed in accordance with 104.03, or as otherwise provided for in the contract.

Unless inspection has previously been conducted by the Department, and the findings are shown in the Proposal book, all facilities to be demolished shall be inspected for the presence of regulated materials as defined in 104.06. Facilities are defined as all institutional, commercial, residential or industrial structures,

installations, buildings, and all bridges. Inspection and testing for asbestos shall be in accordance with 202.07. If inspected by the Department, a copy of the findings will be included in the Contract Information book.

At the direction of the Engineer and in accordance with 104.06(b), appropriate tests shall be made by the Contractor of all potentially regulated materials found. The Contractor shall comply with all applicable environmental regulations.

70

All identified regulated materials shall be reported and removed in accordance with the procedures specified in 104.06 prior to commencing the demolition of the facility. Asbestos removal shall be in accordance with the OSHA Asbestos Standard for Construction Industry, the EPA Asbestos Facts: Demolition and Renovation Regulations, and 202.07.

Except for tank content waste which is classified in 202.08, the Engineer will classify regulated materials as one of the following Department categories for the purpose of disposal requirements and payment.

80

(a) Type Y Waste

All waste material that may be disposed of in a RCRA approved landfill.

(b) Type Z Waste

All waste material that is prohibited from being disposed of in a RCRA approved landfill.

202.03 Removal of Bridges, Culverts, and Other Drainage Structures

Bridges, culverts, and other drainage structures in use by traffic shall not be removed in whole or in part until satisfactory arrangements have been made to accommodate traffic. Any excavation adjacent to the structure or to its approaches shall be shored adequately to avoid damage to them or to traffic.

90

When a reinforced concrete arch bridge is to be removed, either in whole or in part, the work shall include the removal of miscellaneous items within the limits of the structure, which must be removed prior to or in conjunction with the removal of the structure. These miscellaneous items shall include but shall not be limited to: concrete and asphalt pavements; concrete and asphalt sidewalks; and fill within the arches regardless of content.

100

(a) Complete

Unless otherwise directed, the substructures of existing structures shall be removed down to the natural stream bottom and those parts outside of the stream shall be removed down 1 ft below natural ground surface. Where such portions of existing structures lie wholly or in part within the limits of a new structure, they shall be removed as necessary to accommodate the construction of the proposed structure. Portions of pre-existing structures that are not visible and not shown on the plans

202.03

shall be removed as directed. Payment for such removal will be paid as class X excavation in accordance with 206.11.

110

Unless otherwise specified, structural steel and salvageable material shall become the property of the Contractor. It shall be removed from the site before completion of the work and proper allowance for its value shall be taken into account in the bid price of the item involved. If the structure is to remain the property of the Department, steel or wood bridges shall be carefully dismantled without unnecessary damage, steel members shall be match marked, and all salvaged material shall be stored in accordance with 202.02.

120 Blasting or other operations necessary for the removal of an existing structure or obstruction, which may damage new construction, shall be completed prior to placing the new work.

If stated in the special provisions, all concrete which is of suitable size for riprap and not needed for such use on the project shall be stockpiled on the project in an approved manner, for use by the Department.

(b) Portions

130 Portions of the existing structure shall be removed as shown on the plans. Reinforcing bars shall be cut off or allowed to extend into the proposed work as required or as otherwise directed. Explosives shall not be used in the removal of concrete. Where new concrete joins existing concrete masonry, the surface shall be cleaned satisfactorily before new concrete is placed. Adequate safeguards shall be provided to prevent materials from falling below the structure when over or adjacent to traffic; when over bodies of water; as needed to protect life or property; and as needed to comply with laws, regulations, or other contract requirements. A plan shall be submitted for approval showing the proposed method of protection.

140 Pneumatic hammers, up to a maximum of 45 lb may be used for all removal areas to be patched in the deck and all areas within 24 in. of full depth removal lines. Pneumatic hammers up to 69 lb maximum weight may be used for removal of all parapet walls having a construction joint separating the wall from the coping and all partial curb removals. Pneumatic hammers up to 90 lb maximum weight may be used for all other removals outside these limits. Concrete splitters may be used for partial concrete removal subject to satisfactory performance. Deck areas that are to be removed full depth shall be completely separated from adjacent concrete by sawing before hammers heavier than 45 lb may be used.

150 Concrete superstructures or deck removal may be accomplished by pneumatic hammers larger than 90 lb, except directly over structural members that are to remain in place. Partial concrete removal of columns, piers, and abutments may be accomplished with pneumatic hammers larger than 90 lb, provided that the reinforcing bars in the portion to be removed are completely separated from the

concrete that is to remain in place. Alternate methods of removal may be considered if requested in writing.

Hydrodemolition may be allowed for removal of portions of bridge structures as an alternate method to pneumatic hammers. Hydrodemolition for such removals may be accomplished either by use of a machine or a hand held device. Hydrodemolition shall otherwise be in accordance with 722.05(a)2.

160

Any portion of the structure that is removed, but which was not included within the limits of the concrete to be removed as shown on the plans or as directed, shall be replaced with no additional payment. If at any time during the removal process the tools or methods being used appear to cause any damage to concrete that is to remain, the work shall cease immediately and shall not resume until the Engineer is assured the tools or methods used will not cause further damage.

(c) Disposal of Concrete

170 All concrete from complete or partial removals, which is determined to be acceptable for riprap, shall be used on the project as directed. Disposal or placement as riprap will not be paid for directly, but the cost thereof shall be included in the cost of removal.

202.04 Removal of Pipe and Tile Drains

When so provided in the proposal, all pipe and tile drains shall be removed and reasonable precaution taken to avoid breaking or damaging them. The pipe or tile shall be stored neatly on the right-of-way, unless it is to be re-laid as a part of the contract. Otherwise, the conditions in accordance with 104.05 shall apply.

180 Pipes to be re-laid shall be removed and stored so that there is no loss or damage to the pipe. Replacement will be required of sections lost from storage or from damage through negligence or from improper methods in handling. Removal of pipe or drain tile, any necessary cleaning, removal of headwalls, storage of pipe, and disposal of removed headwall material and unsuitable pipe will not be paid for directly, the cost thereof to be included in the various pay items.

190 Sanitary or storm sewers no longer in use shall be removed from under the roadway and shoulders if so specified on the plans or in the proposal or if so directed. No payment will be made for this removal if the removal is shown on the plans and no pay item exists, or if this removal is necessary during the placing of other structures or during other excavation operations. The removal of pipes that are not shown in the contract documents and those that are not being replaced at the same location will be paid for in accordance with 109.05.

202.05 Removal of PCCP, Sidewalks, Curbs, RCBA, and Reinforced Concrete Moment Slabs

All unreinforced PCCP, sidewalks, curbs, gutters, and other unreinforced concrete elements designated for removal shall be:

- 200 (a) broken into pieces and used for riprap on the project; or
- (b) broken into pieces, the maximum weight of which shall be 150 lb, and incorporated into the work as directed; or
- (c) otherwise disposed of in accordance with 202.02.

RCBA, reinforced concrete moment slabs, and reinforced concrete elements designated for removal shall be disposed of in accordance with 202.02.

- 210 Pavement removal shall consist of the removal and satisfactory disposal of RCBA, reinforced concrete moment slabs, reinforced or unreinforced PCCP, PCC resurface with its base, or the total of any combination of HMA base, intermediate, and surface course of any pavement on a PCC, RCBA, or reinforced concrete moment slab base, including the base. Pavement removal shall include only the removal and disposal of existing public road, street, and alley pavement as required for the planned construction. Curb removal shall include curb that is separate from the pavement or removed separately. Integral curb that is removed with the adjacent pavement shall be paid for as pavement removal. Prior to performing the work of pavement removal at locations shown on the plans or where directed, cement
- 220 concrete pavement to be removed shall be cut with a power driven concrete saw along designated lines. Sawing shall be such that any portion of the pavement to remain in place will not be damaged. Any portion that is damaged or removed outside the designated lines shall be replaced with no additional payment. Sawing of pavement to be removed will not be paid for directly, but shall be included in the cost of pavement removal.

202.06 Removal of Houses and Buildings

- This item consists of the satisfactory demolition, removal, backfilling, and disposal of all houses and buildings at locations shown on the plans or where
- 230 directed. The houses and buildings shall be demolished and removed down to a point 1 ft below the original ground level or the subgrade elevation, whichever is lower. All accumulated debris in existing basements shall be removed and disposed of. Prior to starting demolition operations, or when directed, all existing utilities shall be terminated and all floor drains shall be sealed in a satisfactory manner. Temporary fence in accordance with 107.14 may be required where specified or directed. Basements or depressions left by demolition shall be backfilled with B borrow and compacted in accordance with 203.23. No additional payment will be made for temporary fence, the cost thereof to be included in the lump sum price for removal at the location. Temporary fence shall remain the property of the Contractor.

- 240 The removal of houses and buildings shall be arranged and prosecuted such that all Department maintained highways, and all local roads, streets, and alleys within the project limits shall remain open to normal traffic at all times unless otherwise directed.

Demolition and removal of any individual house or building shall not be started without written authorization. Compensation will be paid only for houses and buildings which are actually removed from the right-of-way as authorized. Removed materials shall be disposed of in accordance with 104.05 and 104.06.

250

In the event the houses and buildings listed for removal from a designated parcel are not in existence at the time of submission of the bid, the lump sum bid for that item shall be indicated at zero dollars and cents.

202.07 Inspection and Removal of Asbestos

The Contractor shall comply with all applicable environmental regulations including but not limited to those as follows:

260

(a) In accordance with 202.02 and IAC 14-10, a demolition/renovation notification is to be submitted to IDEM 10 work days prior to the start of demolition or renovation operations. During the 10 day period, the IDEM may make a determination of the existence of asbestos materials. Local governmental agencies may have additional regulations that must be followed. The Contractor shall contact the IDEM's Office of Air Quality to determine what local agencies have regulations.

270

(b) 326 IAC 18-3 which requires the inspector conducting the required inspection to be certified by the IDEM. An accredited asbestos project supervisor shall be required to be present at all asbestos removal projects in accordance with 326 IAC 14-10 and 18-1.

(c) Federal Asbestos National Emission Standard for Hazardous Air Pollutants.

(d) Structurally Unsound and in Danger of Imminent Collapse Building Regulations, in accordance with 326 IAC 14-10-1(b).

202.08 Removal of Underground Storage Tanks Containing Petroleum Products or Other Hazardous Chemicals

280

Removal of underground storage tanks shall consist of the proper excavation; removal of the tank; removal and disposal of liquids, sludges, and other materials in the tanks; backfilling, and permanent closure of underground storage tanks located as shown on the plans or as identified by the Engineer.

This work shall be performed in accordance with the requirements as follows:

290

(a) Technical Standards and Corrective Action Requirements for Owners and Operations of Underground Storage Tanks, UST, Code of Federal Regulations, Title 40, Part 280 (40 CFR 280), Subparts F and G;

202.08

- (b) American Petroleum Institute Recommended Practice 1604, "Removal and Disposal of Used Underground Petroleum Storage Tanks";
- (c) American Petroleum Institute Publication 2015, "Cleaning Petroleum Storage Tanks";
- (d) RCRA and the Indiana Environmental Management Act;
- 300 (e) UST Notification, Reporting and Closure Requirements as prepared by the IDEM Underground Storage Tank Branch;
- (f) safety regulations issued by OSHA;
- (g) Indiana Fire Prevention Code, Flammable and Combustible Liquids, Article 79, 675 IAC 22;
- (h) all applicable Federal and State requirements for certification of underground storage tank removal contractors; and
- 310 (i) local fire codes.

An individual who has been certified for underground storage tank closure or removal, as appropriate, through the State Fire Marshall shall be present at all times for tank closure or removal. Evidence of such certification shall be given to the Engineer prior to starting work.

The removal and disposal of all regulated materials in or around the tanks shall be in accordance with 104.06.

320 The Contractor shall have the responsibilities as follows:

- (a) obtain a review of available tank information from the Engineer;
 - (b) unless the Department has already done so, provide notification of tank removal operations to appropriate authorities. Notification shall be provided as required to the IDEM, Office of the State Fire Marshall and local fire department in accordance with (a) through (i) above. Notification shall be provided to IDEM at least 30 days prior to closure or removal of regulated tanks in the form of the completed Notification for Underground Storage Tanks Form, and at least 14 days prior to removal or closure to the State Fire Marshall and the local fire department. At least 14 days prior notice, by telephone, shall be given to the IDEM Underground Storage Tank Branch of intended closure or removal date. Such forms are available from the Indiana Department of Environmental Management;
- 330

- (c) allow the Engineer to visually inspect tanks after removal;
- 340 (d) allow the Engineer to visually inspect the excavation zone for contaminated soils;
- (e) obtain from the Engineer the limits of excavation for each tank to be removed;
- (f) allow the Engineer to verify all documentation for remediation;
- (g) sample and classify the tank contents, if access is available, or confirm tank contents by sampling and testing;
- 350 (h) submit a site operation plan for the contaminated area to the Engineer for review and approval before beginning removal operations;
- (i) provide and maintain pedestrian safety fencing;
- (j) remove all liquids and sludges from tanks;
- (k) clean tanks and connected piping, including feed lines and drain lines, of contents;
- 360 (l) remove tanks from the ground;
- (m) dispose of all tank content wastes in accordance with the directions provided by the Engineer in 104.06;
- (n) render tanks useless or dismantle tanks and transport to scrap dealer or landfill;
- (o) implement the site operation plan for the contaminated area as directed in accordance with 104.06;
- 370 (p) backfill excavations in an approved manner. Backfill shall be B borrow in accordance with 211;
- (q) maintain accurate records of all operations. Submit reports, including a completed Notification for UST and an UST System Closure Site Assessment Report, to IDEM's UST Branch within 30 days after closure. Two copies of these forms shall be provided to the Engineer with verification that the documents were submitted to IDEM;
- 380 (r) obtain disposal approvals for the hauling and disposal of all tank content waste materials from the site; and

- (s) if the soil or groundwater surrounding the tank shows evidence of contamination, the hole shall be covered to prevent contamination of rainwater until remediation is complete.

The Engineer will classify the tank contents as one of the following liquid wastes for purposes of disposal requirements and payment.

390 **(a) Type A Waste**

Type A waste will consist of direct discharge wastewater which may be discharged to a sanitary sewer system with or without treatment, upon receipt of required permits.

(b) Type B Waste

Type B waste will consist of low flash wastewater which shall be treated off-site at a treatment facility prior to disposal.

(c) Type C Waste

400 Type C waste will consist of petroleum or other chemical liquid and sludge wastes which are regulated materials under current EPA, U.S. Department of Transportation, or IDEM regulations. Such waste shall be disposed of at a RCRA approved facility.

202.09 Remediation of Contaminated Soil and Groundwater

This work shall consist of remediation. All work shall be performed in accordance with all applicable Federal, State, and local requirements, and 104.06.

410 Prior to commencing work, the Contractor shall provide evidence satisfactory to the Engineer that the firm and personnel which are performing the remediation are properly trained or certified as required. The Contractor shall have the equipment for the proper remediation of regulated materials. The Contractor shall be familiar with the required procedures and practices governing such work.

The Contractor shall have the responsibilities as follows:

- (a) notify the appropriate authorities regarding remedial operations and provide verification to the Engineer;
- 420 (b) take samples and conduct tests as approved by the Department to determine extent of the contamination;
- (c) develop a remediation plan and obtain approval for the plan from the Department and the proper authorities;
- (d) remediate the site upon plan approval;
- (e) verify that remediation has been completed by conducting the appropriate sampling or testing;

430

- (f) backfill excavations and restore ground lines as directed, in accordance with 211;
- (g) maintain accurate and complete records of all operations; and
- (h) submit reports to the Engineer and the proper authorities as requested for proper cleanup documentation.

202.10 Remediation of Other Regulated Materials

440 This work shall consist of the remediation of regulated materials not otherwise described herein. This work shall include all necessary excavation, backfilling of resultant excavations, and other handling or storage required.

All work shall otherwise be performed in accordance with all applicable Federal, State, and local requirements, 104.06, and 202.09.

202.11 Transportation and Disposal of Regulated Materials

450 This work shall consist of determining locations for disposal, treatment, or recycling of regulated materials removed from the project site. This work shall also consist of loading regulated materials into a vehicle or transport container and the movement of such material from the project site to a state or EPA permitted disposal site, storage treatment, or recycling facility by appropriately trained and licensed personnel.

The Contractor shall have the responsibilities as follows:

- 460 (a) determine the location for disposal, treatment, or recycling of regulated materials removed from the project site; obtain written approval of the site; arrange with the approved site for the acceptance of the materials; and obtain the Engineer's written approval for the use of the site prior to transporting the materials;
- (b) ensure that all packing containers or tank vehicles are in accordance with the applicable Federal, State, and local requirements;
- (c) prepare a shipping paper or manifest, as required by Federal and State requirements, for signature of the Engineer or designated Contractor representative;
- 470 (d) ensure that the shipping paper or manifest is carried in the vehicle;
- (e) ensure that all required placards are properly displayed on the vehicle;
- (f) ensure prompt movement of the vehicle to the disposal site; and

202.12

- (g) return one copy of the signed shipping or manifest documents to the Engineer.

202.12 Blank

480

202.13 Method of Measurement

If the contract stipulates that payment will be made for removal of obstructions or of houses and buildings, or for clearing right-of-way on a lump sum basis, the pay items for such removals will include all structures and obstructions encountered within the right-of-way in accordance with the requirements herein. No measurement will be made. If it is specified that payment will be made for the removal of specific obstructions on a unit basis, measurement will be made by the unit specified in the Schedule of Pay Items. Material used to backfill excavated areas as directed will be measured by the cubic yard.

490

If the contract stipulates that payment will be made for removal, transportation, or disposal of regulated materials on a unit basis, measurement will be made by the unit stipulated in the Schedule of Pay Items. However, removal of regulated asbestos, if found, will be measured by the square foot.

Underground storage tank removal will be measured per each within the size groupings of under 3,000 gal., from 3,000 through 6,000 gal., over 6,000 through 10,000 gal., or over 10,000 gal. Testing for regulated materials will be measured per each for the type and number of tests required.

500

The length of pipe removed will be measured by the linear foot, computed by multiplying the number of commercial lengths removed by the nominal laying length, or by measuring in place prior to removal, if practicable.

Removal of present structure or portions thereof will not be measured for payment.

Pavement removal will be measured by the square yard of the area removed.

510

202.14 Basis of Payment

The accepted quantities of removal of structures and obstruction within the construction limits will be paid for at a contract lump sum price. All structures or obstructions the Contractor is directed to remove outside the construction limits, including clearing for utility relocation which is for the benefit of the Department, and not simply for the Contractor's convenience, will be paid for in accordance with 104.03 or 109.03 unless such clearing is shown on the plans or in the Contract Information book. Such price shall be full compensation for removing and disposing of obstructions in accordance with requirements herein. Regulated materials shall be subject to 104.06. If no contract price is listed in the Schedule of Pay Items for a pay item set out in this specification, no direct payment will be made for work necessary to comply with the requirements for such pay item, except as set out herein. The cost

520

thereof shall be included in the cost of other pay items. If unknown regulated materials are discovered during the life of the contract, payment for all work relating to removal, testing, transportation, or disposal of such materials will be in accordance with 104.03.

Specific obstructions, including pipe stipulated for removal and disposal, which are shown as pay items, will be paid for at the contract unit price per the unit specified in the Schedule of Pay Items.

530

Removal of houses and buildings will be paid for at the contract lump sum price for houses and buildings, of the parcel number shown in the Schedule of Pay Items, remove.

Testing for regulated materials will be paid for at the contract unit price per each for the type and number of tests required. Testing shall include collecting of samples and all necessary laboratory procedures.

540 Payment for removal of contaminated soils will be based on the actual cubic yards removed, or by the number of 55 gal. drums filled with the contaminated soil.

B borrow required for backfilling basements or depressions left by demolition will not be paid for separately but will be included in the cost of the removal item. B borrow required for backfilling of removed contaminated soils or tank will be paid for in accordance with 211.10.

550 Underground storage tank removal will be paid for at the contract unit price per each tank within the size groupings of under 3,000 gal., from 3,000 through 6,000 gal., over 6,000 through 10,000 gal., or over 10,000 gal. Underground storage tank liquid waste disposal will be paid for based on the type of waste and the actual number of gal. of liquid and sludge removed.

Transportation, disposal, and removal of regulated materials will be paid for based on the type of regulated material and the pay unit shown in the Schedule of Pay Items. If such pay unit is specified as drum, the term drum will mean the contents of a 55 gal. drum.

560 Clearing right-of-way within the construction limits will be paid for in accordance with 201.07 and shall include the cost of all work described herein except for that which is set out specifically as pay items, or work which is described in 104.06, 202.08, 202.09, 202.10, or 202.11. All clearing the Contractor is directed to perform outside the construction limits, including clearing for utility relocation which is for the benefit of the Department, and not simply for the Contractor's convenience, will be paid for in accordance with 104.03 or 109.03 unless such clearing is shown on the plans, in the Contract Information book, or is for the construction of fence or right-of-way markers.

570 Removal of present structure will be paid for at the contract lump sum price for present structure, for the structure number specified, remove. Removal of present structure portions will be paid for at the contract lump sum price for present structure, for the structure number specified, remove portions.

When directed, portions of the present structure contiguous to the areas shown on the plans or non-contiguous portions of the same character as the planned removal shall be removed. Such additional portland cement concrete acceptably removed will be paid for as measured in its original position, at twice the contract unit price per cubic yard for class A concrete in superstructures, class A concrete in substructures, class C concrete in superstructures, or \$652.00 per cubic yard, whichever is lowest.

580 Pavement removal will be paid for at the contract unit price per square yard.

If there is no pay item for pavement removal and such is encountered, payment will be made for each square yard removed. Such pavement removal shall apply only to portland cement concrete pavement or base. A unit price for this work will be established based on thickness, quantity, and removal process. Such unit price will be generated prior to the work being performed. If portland cement concrete pavement has an asphalt overlay, its removal will be considered as incidental, for which no direct payment will be made.

590 Before the Contractor can be paid for any item related to an UST removal in accordance with 202, a detailed explanation of how costs were calculated for those items shown in the Schedule of Pay Items that are related to the UST removal shall be submitted to the Engineer. Such documentation shall include, but is not limited to, a portion of the mobilization and demobilization, a portion of the field office, a portion of the B borrow for backfill of the UST excavation, a portion of the surface removal over the UST, including sawing, and soil borings and laboratory analysis under the testing for waste item. The explanation shall show the type of pavement removed. Contaminated soil removal shall be broken down into equipment cost, labor, and mobilization of equipment used. Transportation of the regulated materials shall be broken down into loading, hauling, and mileage costs.

600

Payment will be made under:

	Pay Item	Pay Unit Symbol
	Contaminated Soil, Remove	CYS
	Houses and Buildings, Parcel No. _____, Remove	LS
	Pavement Removal	SYS
	Present Structure, Str. No. _____, Remove	LS
610	Present Structure, Str. No. _____, Remove Portion	LS
	_____, Remove	EACH
	specific work	LFT
		SYS

	Regulated Asbestos Containing Materials, Remove.....	SFT
	Regulated Materials, Dispose, _____	GAL.
	type	CYS
		TON
		DRUM
		EACH
620	Regulated Materials, Remove, _____	GAL.
	type	CYS
		TON
		DRUM
		EACH
	Regulated Materials, Transport, _____	GAL.
	type	CYS
		TON
		DRUM
		EACH
630	Structures and Obstructions, Remove.....	LS
	Testing for Asbestos	EACH
	Testing for Wastes, _____	EACH
	type	
	Underground Storage Tank, Liquid Waste Disposal, _____	GAL.
	type	
	Underground Storage Tank, Remove and Dispose, Under 3,000 Gallons Capacity.....	EACH
	Underground Storage Tank, Remove and Dispose, 3,000 through 6,000 Gallons Capacity	EACH
640	Underground Storage Tank, Remove and Dispose, 6,000 through 10,000 Gallons Capacity	EACH
	Underground Storage Tank, Remove and Dispose, Over 10,000 Gallons Capacity.....	EACH

650 The cost of removal and disposal of buildings, foundations, debris and unsuitable material, guide posts, delineator posts, temporary road material, existing asphalt patches, the filling of abandoned wells; terminating utilities; sealing floor drains where necessary; breaking basement floors; furnishing and erecting all barricades, fences, and other safety measures necessary for adequate protection of the sites; and backfill of basements or depressions left by demolition shall be included in the cost of the pay items of this section. All fence posts and concrete footings shall be completely removed and the resulting holes backfilled accordingly.

If no contract price is listed in the Schedule of Pay Items for work set out herein, no direct payment will be made for compliance with the requirements for such work, except as set out herein. The cost thereof shall be included in the cost of other pay items.

660 If the houses and buildings listed for removal from a designated parcel are not in existence at the time of the letting, no payment will be made for removal work on such parcel.

670 The cost of removing the tanks and all pipe from the ground, removal and disposal of all miscellaneous parts associated with the tank such as concrete pads or holding devices, filing of all required notifications, preparation and implementation of a site operation plan, excavation of all materials necessary in order to remove the tank, compliance with closure requirements, all necessary pedestrian safety fencing, cleaning and draining of tanks and pipes, dismantling or transport, and all required record keeping or reports shall be included in the cost of underground storage tanks, remove and dispose. However, disposal of waste contents and removal of contaminated soil will be paid for separately. No payment will be made for work not performed in accordance with the specifications or not required by the contract.

The cost of all on-site or off-site storage of the materials shall be included in the cost of transportation.

680 All disposal fees and recycling or treatment costs required for regulated materials found within the project limits shall be included in the cost of regulated materials, dispose. If regulated materials are treated on site and not disposed of at an approved location, payment will be in accordance with 104.03.

The cost of removal of all regulated asbestos-containing materials and all safety procedures shall be included in the cost of regulated asbestos containing materials, remove.

The cost of packaging regulated materials, excavation, restoring ground lines, and maintaining and filing required documents and reports shall be included in the cost of the pay items.

690 The cost of removal of regulated asbestos-containing materials shall include only the removal of material identified in the contract or by the Engineer as regulated asbestos-containing material. Regulated asbestos-containing materials include the following:

- (a) friable asbestos-containing material;
- (b) Category I non-friable asbestos-containing material that has become friable or will be subjected to sanding, grinding, cutting, abrading, or burning;
- 700 (c) transite-like material; and
- (d) other Category II non-friable asbestos-containing material that has a high probability of becoming or has become crumbled, pulverized, or

reduced to powder by the forces expected to act on the material in the course of normal demolition operations.

710 Unless directed by the contract or the Engineer, the cost of asbestos removal shall not include the removal of Category I or II non-friable asbestos-containing material that is not friable or does not have a high probability of becoming friable but which becomes friable because the Contractor uses demolition methods that cause such materials to become regulated. Such cost shall be included in the cost of other pay items.

720 The cost of all labor, equipment, materials, and documentation required for complying with the applicable laws, regulations and procedures, including but not limited to, licenses, permits, other legal fees, or disposal charges shall be included in the cost of the pay items. No payment will be made for work which is not performed in accordance with the specifications or that which is not required by the contract.

The cost of removal of specific work shall include the removal and disposal of such obstructions, the necessary excavation required, salvage of materials removed, their custody, preservation, storage on the right-of-way, and disposal as provided herein. All damage to existing facilities caused by the Contractor's operations or equipment shall be satisfactorily replaced or repaired with no additional payment.

730 If it is necessary to package the contaminated soil in a container, the cost of the container and all cost related to packaging shall be included in the cost of removal. The cost of all excavation pertaining to contaminated soil, removal of all soil within the limits established by the Engineer, restoring ground lines, maintaining required records and filing of reports shall be included in the cost of contaminated soil, remove. No payment will be made for work beyond the limits established by the Engineer, work not performed in accordance with the specifications, or work not required by the contract unless in accordance with 104.03.

The cost of all handling of the product, removal of the product from the tank, disposal, all required packaging, and transportation shall be included in the cost of underground storage tank, liquid waste disposal.

740 All necessary cleanup of spills caused by the Contractor will not be paid for.

SECTION 203 – EXCAVATION AND EMBANKMENT

203.01 Description

This work shall consist of embankment construction and excavation, hauling, and disposal or compaction of all material not being removed under some other item which is encountered within the limits of the work and also from intersecting entrance approaches beyond the right-of-way limits necessary for the construction of the roadway in accordance with 105.03. All excavation will be classified as hereinafter described.

10

203.02 Common Excavation

Common excavation shall consist of all excavation not included as rock excavation or excavation which is otherwise classified and paid for, including asphalt type pavement.

203.03 Rock Excavation

20 Rock excavation shall consist of igneous, metamorphic, and sedimentary rock or other sound mineral matter which cannot be readily excavated by the use of a crawler mounted hydraulic excavator of not less than 40,000 lbs gross operating weight equipped with a general purpose excavator bucket of not less than 1 cu yd capacity, in satisfactory running condition and operated in accordance with the manufacturers recommended operating instructions. Rock excavation shall also include all boulders and other detached stones each having a volume of 1/2 cu yd or more.

203.04 Unclassified Excavation

Unclassified excavation shall consist of the excavation and disposal of all materials of whatever character encountered in the work.

30 **203.05 Peat Excavation**

Peat excavation shall consist of the necessary excavation and satisfactory disposal of peat, muck, marl, or any other similar unsuitable material in peat deposits, together with any overlaying material, except pavement, which is not used in embankment construction, except as otherwise provided in 203.16.

203.06 Waterway Excavation

40 Waterway excavation shall consist of the necessary excavation and satisfactory disposal of all material resulting from excavation for clearing waterways, making channel changes, or both when such are itemized in the Proposal book, but shall not include class Y excavation, or excavation made for a structure in accordance with 206. If not otherwise specified, waterways shall be cleared for the entire distance within the right-of-way lines.

203.07 Class Y Excavation

50 Class Y excavation shall consist of material encountered within the limits of waterway excavation which can be classified as rock in accordance with 203.03, or material which consists of conglomerate, concrete, masonry, or any similar material which is not part of an existing structure shown on the plans. Material as defined in 203.02 will not be considered as class Y excavation.

203.08 Borrow or Disposal

Borrow shall consist of approved material required for the construction of embankments or for other portions of the work and shall be obtained from approved locations and sources outside the right-of-way. Borrow material shall be free of substances that will form deleterious deposits, or produce toxic concentrations or

combinations that may be harmful to human, animal, plant or aquatic life, or otherwise impair the designated uses of a stream or area. Unless otherwise designated in the contract, arrangements shall be made for obtaining borrow. Borrow, as designated herein, shall not include material excavated beyond the right-of-way limits at intersecting public roads, private and commercial drive approaches
60 and material furnished as B borrow.

Disposal of waste material, other than regulated material, from within the right-of-way shall only be allowed at approved locations either within or outside the right-of-way. Disposal of regulated material shall be in accordance with 104.06.

Except where a licensed commercial site or a permitted site is utilized for borrow or disposal, the Contractor shall obtain all permits required by local, State and Federal laws prior to the start of any operations at the site.

70

Licensed commercial sites and permitted sites are defined as follows:

(a) A licensed commercial site is a solid waste facility with a current IDEM operation number.

(b) A permitted site is a location that is operated under permits required by local, State and Federal laws for the activities proposed by the Contractor. A permitted site shall also have documentation that a wetlands delineation and an archaeological survey have been performed
80 by qualified professionals.

80

For proposed borrow or disposal sites other than licensed commercial or permitted sites, an inspection of areas outside the construction limits shall be conducted by a qualified wetland professional approved by the Department to determine if wetlands are present on the site. An approved wetland professional shall be prequalified with the Department to perform environmental services work type 5.4 Ecological Surveys or shall be certified by the Society of Wetland Scientists as a wetland professional-in-training or professional wetland scientist. A list of approved wetland professionals is maintained on the Department's website. The wetlands
90 inspection shall be in accordance with the Federal Manual for Identifying and Delineating Jurisdictional Wetlands. The inspection shall also determine if isolated wetlands as defined by IDEM are present. The Contractor shall demarcate in a method approved by the Engineer the boundary of all wetlands identified within the proposed borrow or disposal site.

90

For proposed borrow or disposal sites other than licensed commercial or permitted sites, a qualified archaeologist shall perform a record check and field survey to determine if any significant archeological sites exist within the proposed site. The Indiana Department of Natural Resources Division of Historic Preservation and Archeology maintains a roster of qualified archeological consultants. If any
100 archaeological sites are identified, the archaeologist shall establish the limits of the

100

site along with a reasonable border. The Contractor shall demarcate in a method approved by the Engineer the border of all archeological sites identified within the proposed borrow or disposal site.

Identified archeological sites shall not be disturbed unless the site is cleared by established procedures and written authorization to enter the site has been obtained by the Contractor.

- 110 Borrow and disposal sites shall be approved by the Engineer prior to the start of any earth disturbing operations at the site. A request for approval of a borrow or disposal site shall be submitted to the Engineer a minimum of 14 days prior to the Contractor's planned start of operations at the site. All requests for approval of a borrow or disposal site shall include a description of the Contractor's planned operations at the site. In the case of disposal sites, the description shall include a listing of the types of material to be disposed of at the site.

A request for approval of a licensed commercial site shall include the following:

- 120
- (a) The name and address of the facility.
 - (b) The IDEM operating number.
 - (c) The expiration date of the IDEM operating permit.

A request for approval of a permitted site shall include the following:

- (a) Name of the site owner.
 - (b) Address of the site.
 - (c) A list of the permits, permit numbers and permit expiration dates for all permits under which the site operates.
- 130
- (d) Documentation that a wetlands delineation and an archaeological survey have been performed by qualified professionals.

A request for approval of a site, other than a licensed commercial or permitted site, shall include the following:

- (a) Name of the property owner.
 - (b) Address or location of the site.
 - (c) A copy of a right-of-entry obtained from the property owner. Rights-of-entry shall include rights for access by Department personnel to the site for the purposes of monitoring, measurement, and sampling.
- 140
- (d) A site plan showing the site location, site dimensions, adjacent property and right-of-way lines, all demarcated jurisdictional wetlands or isolated wetlands, all demarcated archeological sites, existing and proposed finished contours and proposed finished slope grades.
 - (e) A site operations plan detailing the operations proposed for the site, what equipment will be utilized, how the site will be accessed and any other information relevant to the operation of the site.

- 150 (f) A copy of the Rule 5 Notice of Intent, if required in accordance with 327 IAC 15-5.
- (g) An erosion control plan for the site including the types of erosion control measures to be incorporated and the sequencing of the measures with respect to the operations plan for the site.
- (h) Documentation signed by a wetlands professional verifying that the site has been inspected for the presence of both wetlands and isolated wetlands and, if any are present, specifying the area to be demarcated as jurisdictional or isolated wetlands.
- (i) Documentation of the archeological record check and field survey signed by a qualified archeologist including the limits and border of any archeological site discovered.
- 160 (j) Copies of all other permits obtained by the Contractor to perform operations at the site.

The Contractor shall provide the Engineer a minimum of 14 days notice prior to opening borrow areas for the purpose of obtaining original cross section elevations and measurements and to sample the borrow material prior to use.

- 170 The Contractor shall install temporary erosion and sediment control measures at borrow or disposal sites other than licensed commercial and permitted sites prior to the start of any earth disturbing activity. The Contractor shall develop and construct all mitigation measures necessary to fulfill the requirements of all permits obtained by the Contractor for operation of a borrow and disposal site.

No excavation shall occur or no material shall be disposed of within the boundaries of the demarcated wetlands and archeological areas unless the operations are in compliance with all required permits and these specifications.

No extension of completion time will be granted due to any delays by the Contractor in securing approval of borrow and disposal sites.

- 180 Approval of a proposed borrow or disposal site by the Engineer, whether the proposed site is commercial, permitted, or otherwise, shall not relieve the Contractor of its responsibility to utilize an appropriate site and to comply with all applicable local, State and Federal laws and regulations.

Archaeological artifacts encountered during operations shall be addressed in accordance with 107.10.

- 190 Unless written permission is granted, there shall be no excavation in a borrow area below the elevation of the adjacent properties within 150 ft of the nearest right-of-way line of an existing highway, county road, or city street; the nearest right-of-way line of a proposed highway, county road, or city street; or adjacent property lines. If the properties adjacent to the borrow area are privately owned, the setback limit of 150 ft may be lessened if written approval or permission is granted by the

203.08.1

owner of the adjacent property, the excavation is in accordance with local zoning laws and requirements, and if lessening the limit is in the best interest of the State. Such minimum distance shall not be closer than 50 ft to an adjacent property line. All excavated slopes of a borrow area shall not be steeper than 3:1 down to 2 ft below the ground water elevation. All excavated slopes 2 ft below the ground water elevation shall not be steeper than 2:1.

200

Top soil from the borrow or disposal area shall be stockpiled for use in restoring the disturbed area. A minimum encasement of 6 in. shall be placed on the 3:1 or flatter slopes. Final restoration of borrow or waste disposal areas shall include grading, seeding, or other necessary treatments that will blend the area into the surrounding landscape. Restored areas within 150 ft of the nearest right-of-way line shall be well drained. Areas beyond 150 ft shall be drained unless the landowner desires other treatment of the borrow area. Construction of borrow or disposal areas shall be in accordance with existing laws, regulations, and ordinances. Under no conditions shall borrow sites detract from the appearance of the natural topographical features or increase the potential hazard to a vehicle that has inadvertently left the highway.

210

If granulated slag, dunes sand, or other granular material which is not suitable for the growth of vegetation is used, such material shall not be placed within 1 ft of the required finished surfaces of shoulders and fill slopes. Additional material required to complete the embankment, such as sandy loam, sandy clay loam, clay loam, clay, or other materials suitable for the growth of vegetation and free from clods, debris, and stones, shall be furnished at the contract price for borrow.

220

Additional fill material may be secured from within the permanent or temporary right-of-way in lieu of borrow or B borrow either from vertical or horizontal extensions, or both, beyond the lines and elevations of roadway and drainage excavation as shown on the contract plans when authorized in writing. If additional material has been obtained without written approval, the material will be classified either as to source or use, to the best advantage of the Department.

203.08.1 Linear Grading

Linear grading shall consist of:

230

- (a) earth wedging at the outside edge of a shoulder once the pavement has been resurfaced, widened, or replaced;
- (b) earth wedging behind guardrail to obtain the required earth backup for the posts;
- (c) median earth filling required for paving and placement of concrete median barrier.

These types of earthwork will not require benching.

240

CONSTRUCTION REQUIREMENTS

203.09 General Requirements

The excavation and embankments for the roadway, intersections, and entrances shall be finished to reasonably smooth and uniform surfaces. Excavated materials shall not be wasted without permission. Excavation operations shall be conducted so that material outside the limits of slopes will not be disturbed. Prior to beginning excavation, grading, and embankment operations in any area, all necessary clearing and grubbing in that area shall have been performed in accordance with 201. The area of the exposed materials shall be limited by the Contractor's capacity to adequately maintain permanent and temporary erosion and sediment control features.

250

The Engineer will direct the Contractor to stabilize an area if the disturbed ground is anticipated to be left bare and unworked for seven consecutive calendar days. Once directed, the Contractor shall stabilize the area within seven days. The methods shall be installed in accordance with 205 or as otherwise directed.

260

All spongy and yielding material which does not readily compact, and all vegetation, shall be removed from within slope-stake limits and to such depths as directed. Soft or unstable materials which are encountered where the proposed embankment will be placed shall be removed. If groundwater is encountered, backfilling shall be accomplished using B borrow in accordance with 211.02 to an elevation at least 2 ft above the groundwater level. Compaction of the B borrow placed above the free water level shall be accomplished using heavy vibratory equipment. If groundwater is not encountered during the removal operation, the backfill shall be placed in accordance with the following paragraph. None of the removed materials shall be used in embankment, except if approved, they may be used if aerated such that proper compaction can be achieved.

270

Soils containing greater than 7% by dry weight organic material, or soils with a maximum dry density of less than 90 pcf shall not be incorporated in the embankment. Loss on ignition will be determined in accordance with AASHTO T 267, and density will be determined in accordance with AASHTO T 99.

280

After the embankment area has been cleared and before embankment is placed, all pronounced depressions left in the original ground shall be refilled with suitable material and compacted in accordance with 203. The upper 6 in. of the original ground shall be compacted with a roller weighing no less than 10 t, or with other approved compacting equipment. Proofrolling of the natural ground surface shall be performed in accordance with 203.26 within all areas where new fill will be placed.

If the original ground cannot be compacted to the required density because of unstable soils, high water table, or other conditions, the use of stabilizing materials consisting of B borrow in accordance with 211.02, or soils drying with a chemical modifier in accordance with 217 may be used. The materials shall be 1 to 2 ft thick,

203.09

and shall be extended so as to daylight at the toe of slope. B borrow, when exposed, shall be capped with a geotextile and 6 in. of coarse aggregate No. 2 or riprap.

290 Prior to the use of B borrow, granular materials, or soils drying with a chemical modifier, a written approval is required. When preliminary exploration indicates the need to remove more than 4 ft or 250 cu yd of unsuitable material, approval is needed.

Frozen materials, stumps, roots, all or parts of trees, brush, weeds, sod, or other perishable materials shall not be incorporated in the embankment. Rocks greater than 6 in. in any dimension shall not be left within 6 in. of the finished subgrade. The original ground surface, or the surface of any lift in place shall not be frozen and shall be free of snow, ice, or mud.

300 The embankment shall be kept drained at all times by keeping the center higher than the sides and uniformly graded.

Each embankment lift shall extend transversely over the entire area and shall be kept smooth. If a dragline or similar equipment deposits material in large masses onto the embankment, the material shall be spread out in uniform lifts.

The use of hydraulic methods to construct embankments will be allowed only when authorized in writing. Only B borrow shall be placed below the free water level. Backfill at structures shall be in accordance with 211.04.

310

If the same or similar material is being used in the upper lifts of embankment as shall be used in the subbase at that location, these lifts shall be placed in smooth uniform layers for the full width of the embankment.

When grading operations are performed in non-daylight hours, artificial lighting shall be provided and maintained, to enable the construction and inspection of the operations.

320 All slopes which are to be graded and not stabilized with other erosion control measures shall be roughened as described herein, until permanent erosion control measures are placed. Roughening shall take place each day after work is performed on the slopes, or as directed to re-establish the roughening.

The soil slopes shall be roughened to create a series of ridges and depressions parallel to the contour making grooves at least 1 in. deep and not more than 15 in. apart. When directed, slopes shall be stabilized using temporary seeding in accordance to 205.

330 Sufficient quantities of excavated materials suitable for the growth of vegetation shall be preserved from within the planned excavation area and used for the encasement of cut, fill, and shoulder slopes which are deemed not suitable for the

growth of vegetation. The depth of encasement shall be 6 in. or more, as directed, measured perpendicular to the face of the slope. No additional compensation will be allowed for this work except payment will be made for the class of excavation involved for authorizing undercutting of back slopes. Encasement of rock embankment and cut slopes will not be required unless otherwise directed.

340 Material suitable for the growth of vegetation shall be as approved and may consist of sandy loam, sandy clay loam, clay loam, clay, and shall be free from clods, debris, and stones. The material placed on backslopes of cut sections shall be placed in accordance with 203.21.

350 If sufficient excavation materials suitable for the encasement of cut, fill, and shoulder slopes are not available, borrow material shall be furnished. The sources of the borrow material for encasement shall be in accordance with 203.08. Payment for borrow will be made in accordance with 203.28. If the contract does not contain a pay item for borrow, a change order will be executed for payment of borrow. Suitable portions of common excavation may be preserved or borrow material may be furnished for encasement provided all suitable excavation is used constructively.

203.10 Disposal of Excavated Material Except Waterway and Peat Excavation

Excavation material shall be used for the construction of embankments, shoulders, special fill, or other places as may be specified or directed, depending on the nature of the material. Excavated material that is suitable for embankment construction, that is not required for maintenance of traffic, shall be placed in the embankment before placing any borrow material, unless otherwise authorized in writing.

360 If more material is excavated from within required cut slopelines than is needed to construct embankments or special fills, the excess may be used to widen embankments, flatten fill slopes, or be used otherwise as directed. All excess excavated material that cannot be used constructively within the project limits shall be disposed of off the right-of-way in accordance with 203.08.

Excavation obtained from the right-of-way and planned to be used in fills may be wasted and replaced with borrow with no additional payment only after written permission is obtained. All required samples of the borrow or the excavation materials involved shall be furnished with no additional payment.

370

203.11 Disposal of Waterway Excavation

Unless otherwise provided, material resulting from waterway excavation shall be used, if suitable, in embankment, special fill, approach embankments, or any combination of these, as specified or directed.

Any portion of waterway excavation material which is unsuitable for the above uses, any portion which is suitable but is in excess of that required for such uses, or

203.12

when locations for such uses are not available, the material shall be disposed of in accordance with 203.08.

380

203.12 Disposal of Peat

All material removed as peat excavation, removed or displaced by machine operation, or displaced by the advancing backfilling material shall be disposed of in accordance with 203.08.

203.13 Slides

Slides encountered during construction shall be removed as directed and their removal will be paid for as the class or classes of excavation encountered.

390

If the contract involves paving, the omission or delay of paving operations may be required at the location of a slide. If proper treatment of a slide has been obtained prior to completion of the remaining pavement, the gap may be required to be paved, and payment will be at the contract unit price for pavement.

If proper treatment of a slide has not been obtained prior to completion of the remaining pavement, the gap left at the slide location shall become an exception to the contract item for pavement.

203.14 Drainage

400

Ditches shall be interpreted to mean open ditches and channel changes parallel to and adjacent to the roadbed. Channel changes excavated under the classification of waterway excavation are not included in this definition.

Lines, grades, and cross sections of ditches shall be as shown on the plans, unless otherwise established to obtain proper drainage.

Ditches and gutters emptying from cuts onto embankment shall be constructed to avoid eroding the embankment.

410

Exploration of underground drainage and sinkholes may be required, and payment will be hereinafter provided. Should any underground drain be encountered, the location of which is not shown on the plans, notification shall be made at once. Drainage shall be explored as directed and, if deemed necessary, taken care of under applicable provisions of these specifications, or as otherwise directed.

420

If existing surface drains, tile drains, sewers, or other underground drains, or parts thereof, are not to be replaced or are not required by the terms of the contract or directed to be changed, whether such drainage facilities are shown on the plans or not, all such drainage facilities or parts thereof shall be protected, preserved, and satisfactorily continued in use without change. If in the prosecution of the work such existing drainage is changed or interrupted, or through negligence such drainage is interrupted or damaged, satisfactory permanent repairs shall be immediately provided or adequate temporary drainage facilities shall be maintained until

permanent repairs are made. If temporary facilities are provided, before the work is accepted, such damage or interrupted drainage facilities shall be restored to the original condition or to an altered state which is at least equal to their original condition.

430 If slopes or ditches which were graded for a grading contract become eroded or scoured during the paving contract work, the scoured or eroded areas shall be reshaped to the original cross section and reseeded or resodded as shown on the plans, all in accordance with 208 and 621.

When so provided by the plans or special provisions, or when ordered, all tile drains, sewers, or other underground drains encountered in the prosecution of the contract shall be repaired, replaced, extended, reconstructed, connected, or otherwise changed.

440 Unless otherwise provided in the contract, the cost of replacing, restoring, or connecting an underground drain which is substantially in its original location and incidental to roadway and drainage excavation, structures, or other drains will not be paid for directly, but the cost thereof shall be included in the cost of various pay items.

Unless otherwise provided, any necessary drainage change or restoration not shown on the plans and not due to negligence or operations of the Contractor will be paid for at the contract unit price or prices thereof. If there is no such contract unit price or prices, such work shall be done and payment made in accordance with 104.03.

450

203.15 Excavating Rock

If material is encountered during excavation which appears to belong in the classification of rock excavation in accordance with 203.03, notification shall be made in writing. Ample time shall be allowed to make such investigation and measurements that are necessary to determine the class and volume of the material in question.

460 Exploratory cores shall be taken from the top of the rock to approximately subgrade elevation as directed. The cores shall be cut with standard diamond core bits and series X double tube core barrels to obtain 2 1/8 in. diameter samples. All cores shall be suitably marked and identified to show the location of the core by station, offset from centerline, elevation of top of rock, depth below top of rock, and percent recovery within each core. All cores shall be retained. The cores shall be placed in suitable compartmented wooden boxes in the order in which removed from the boring, with dividers between core runs. The top and bottom of each run shall be appropriately marked. The cores shall be transported to a location as directed.

The top of rock elevations shall be determined prior to locating the top of soil cut slopes where finished rock slopes are planned to be 1:1 or steeper.

470

Final breakage of rock excavation shall be in accordance with or closely approximate the slope lines shown on the plans unless different slope lines are fixed, and the Contractor so notified. The final slopes shall be left reasonably smooth and uniform, and all loose and overhanging rock removed. Unless otherwise specified, no rock shall finally project more than 1 ft beyond established slopes. If natural seams intersect an established slope, the excavation may be carried, with permission, along the face of such seams for the distance approved.

480 Rock shall be excavated to the required elevation for the full width of the roadbed as shown on the plans or as directed. Where rock is excavated below the required elevation, the area shall be backfilled to the subgrade elevation with crushed stone, spalls, subbase material, or other approved granular material, which shall be shaped and compacted to the required elevation and cross section.

490 Exploratory drilling, which shall consist of drilling holes for the purpose of determining the existence of cavities affecting underground drainage and possible sinkholes in cut sections, may be required at locations as directed. Unless otherwise directed, the holes shall be drilled on the centerline of the proposed pavement at approximately 100 ft intervals and shall extend for a depth of 7 ft below the proposed grade and have a minimum diameter of 1 1/2 in.

Where cavities are discovered on centerline, additional holes shall be drilled at 25 ft intervals along the edge of the proposed pavement, and unless otherwise directed, extend for a depth of 7 ft below the proposed grade. Where any cavity is discovered or exposed having a minimum cover of less than 5 ft, the cover shall be removed, and the treatment of such areas shall be in accordance with details in the plans or as otherwise directed.

500 The final surface of rock excavation under the roadbed area shall be left so that drainage between the rock surfaces and any material placed thereon will be substantially complete. Where seams of clay or other soft material 1 ft or less in thickness are encountered in rock excavation, the volume of such seams will be considered as rock excavation and paid for as such.

510 Unless otherwise specified or directed, rock shall be pre-split by drilling and the use of explosives in such a manner as results in minimum breakage outside neat lines of the typical cross section and slope stakes as established. Deposits of commercial building stone outside the right-of-way shall not be damaged. Holes for pre-splitting shall be drilled along the established slope stake lines. The holes shall be from 2 to 4 in. in diameter and, unless otherwise directed, be spaced approximately 3 ft apart. Holes shall be drilled approximately 2 ft below the established grade of the cut, or the predetermined bench elevation, or as directed.

The maximum depth of any pre-split lift shall be 30 ft, unless otherwise directed. If more than one lift is required, the first line of drill holes shall be set in

such a manner as to allow for a specified offset for each succeeding lift and an offset of 2 ft from the back of the paved side ditch line. The explosives used and the method of loading depends on the material to be blasted. These explosives may vary from a single strand of detonating cord, for blasting unconsolidated formations, to a solid column of dynamite for massive formations. However, the explosive shall be of a type to accomplish the pre-splitting with a minimum of breakage outside the excavated area. After the charges are placed, the holes shall be filled with sand or other suitable granular material.

Except as indicated below, all pre-splitting charges shall be detonated simultaneously by the use of instantaneous electric blasting caps or by means of a detonating cord trunkline. The line holes shall be fired before the main excavation is blasted. Pre-splitting shall be kept well in advance of regular blasting operations. Primary blasting holes shall be drilled no less than 6 ft from the pre-split face, unless otherwise directed. If additional charges are required, holes shall be placed at 1/2 the distance of a full depth hole to a depth such that the bottom of the hole clears the pre-split face approximately 2 ft. The pre-split face shall deviate no more than 6 in. from the front line of drill holes or more than 12 in. from the back line of drill holes except where the character of the rock will unavoidably result in some irregularities.

The amount of explosives per shot for instantaneous firing or the amount of explosives per delay for delay firing shall not be great enough to damage nearby structures, rock formations, or other property. Where commercial building stone formations are located in the effective vicinity, adequate seismograph readings shall be obtained, with no additional payment, as evidence that blasting operations have not altered existing commercial building stone formations outside the right-of-way limits of the project.

Permission may be granted to use machine methods to establish the finished slopes in those cuts where machine methods are used to remove roadway excavation, provided final machine finished slopes are equal or superior to that which would be obtained by pre-splitting methods.

When or where any direct or indirect damage or injury is done to public or private property by or on account of any act, omission, neglect, or misconduct in the execution of the work or in consequence of the non-execution thereof, such property shall be restored, with no additional payment, to a condition similar or equal to that existing before such damage or injury was done by repairing, rebuilding, or otherwise restoring as directed, or such damage or injury shall be made good in an acceptable manner.

No direct payment will be made for pre-splitting, but the cost thereof shall be included in the pay item of rock excavation or unclassified excavation.

560 **203.16 Peat Deposit Treatment**

If construction is specified at a location where a peat deposit is to be treated, the deposit shall be treated ahead of paving operations to obtain maximum settlement. If settlement has not been obtained when paving operations are at the limits of any peat deposit treatment, a gap in the pavement shall be left as directed. Gaps not constructed as part of the project will become an exception to the contract.

Treatment shall be by the following methods:

(a) Treatment of Existing Fills

570 If the required alignment is on an existing fill over a peat deposit, treatment may be required by any one or any combination of the following methods:

1. removal of the existing fill with or without the removal of the underlying peat and of the material at the sides of the existing fill;
2. blasting the peat under the fill;
3. loading the existing fill with additional fill material, and, if directed, blasting the peat underneath;
- 580 4. leaving the existing fill in place and treating the material at the sides either by removing the peat at the sides and backfilling or by displacement or both;
5. excavating and constructing with lightweight fills.

Determination of the method or methods to be used will be made based on conclusions from test holes which may be required to be drilled at designated locations.

590

(b) Treatment by Removal

This method consists of completely removing the objectionable material either as peat excavation or by machine operation and backfilling to the full toe-width of the proposed embankment or to such other widths, if so directed depending on the condition and depth of the material to be removed.

If water is not present, the space previously occupied by the removed material shall be backfilled with common excavation, borrow, or both, and placed in accordance with 203.

600

If water is present, the backfill shall be with material in accordance with 211.02. Placement of this material shall follow as closely behind the removal of the peat as possible. It shall be carried across the area from one end to the other by end-dumping and finally left at the established grade. This grade shall be such that keeps end-dumping to a minimum, which nominally shall be approximately 2 ft above free

water level. That portion between free water level and this established grade shall be thoroughly watersoaked to secure maximum compaction.

610 If additional fill is needed to bring the embankment to its final required grade, it may be common excavation or borrow. Further placing of the granular material above the end-dumped material may be authorized. This additional fill shall be placed and compacted in accordance with 203 but shall not be placed for at least 14 days after the end-dumped material is placed and compacted. This period may be shortened or lengthened with written approval, depending on the settlement that has been obtained.

(c) Treatment by Displacement

620 When this method is used, the peat at each end of the deposit shall be removed completely by excavation to the full width shown on the plans, or to such other width as may be directed, until a point is reached where the depth of the peat being removed is greater than 10 ft, or to a greater or lesser depth, as directed.

630 If conditions allow, the upper portions of the remaining peat shall be excavated across the remainder of the deposit in the same manner as set out above for the ends. Removal of this upper portion shall begin at one end and proceed to the other end at a sufficient distance ahead of backfilling operations so displacement of the remaining peat will not be retarded. If excavation to the required depth is not maintained for the full width ahead of the backfill or surcharge, additional units shall be used or backfill operations stopped until the two operations are in balance. If conditions allow, draglines shall be operated from mats in front of the advancing excavation. If blasting is required to aid displacement, it shall be completed as extra work in accordance with 104.03.

640 Backfilling shall be in accordance with 203.16(b) for end-dumped material except, when required, a temporary surcharge shall be maintained at the head of the backfilling. The top of the surcharge shall be constructed and maintained to a width equal to the full shoulder width of the proposed embankment, or as approved or directed. The height of the surcharge shall be the same as the depth of the peat being treated, unless otherwise directed. The original ground shall be the reference elevation for measuring peat depths and surcharge heights. The top of the surcharge shall be approximately level and the length on top shall be at least two times the depth of the peat being treated. The surcharge shall be kept built up and pushed forward with a bulldozer or other approved equipment as the displacement progresses. Machine methods shall be used to relieve pressure at the advancing toe and sides of the surcharge. Sufficient hauling units shall be used to maintain the surcharge at the required height, width, and length. The machine operation to augment displacement shall be coordinated with the rate of placing temporary surcharge.

650 After the granular backfill has been completed across the deposit, any remaining fill necessary to bring the embankment up to the required final grade shall be in accordance with 203.16(b) for that portion above the end-dumped material.

203.17 Cased Test Holes

As displacement progresses, cased test holes shall be placed at locations as directed to determine the extent of peat displacement and for use in conjunction with final measurement. These holes shall extend to the bottom of the deposit. The boring shall be conducted in such a manner that accurate information may be obtained as to the nature of the materials through which the test holes are placed. If these test holes
660 indicate that full displacement has not been obtained, the remaining peat shall be blasted or additional treatment shall be performed as required.

Unless otherwise specified in writing, cased test holes shall be placed by hydraulic boring. The external casing shall be a minimum of 2 in. in diameter and of such additional size as to perform the operation satisfactorily. A continuous supply of fresh water shall be jetted through an internal pipe so that the wash water and loosened material is carried to the surface between the jet rod and the external casing. Pumps and other miscellaneous tools and equipment shall be used as required to perform a satisfactory operation.

670

203.18 Embankment Construction

Embankment construction shall consist of constructing roadway embankments, including preparation of the areas upon which they are to be placed; the construction of dikes within or outside the right-of-way; the placing and compacting of approved material within roadway areas where unsuitable material has been removed; and the placing and compacting of embankment material in holes, pits, and other depressions within the roadway area. Only approved materials shall be used in the construction of embankment backfill. Rocks, broken concrete, or other solid materials shall not be placed in embankment areas where piling is to be placed or driven.

680

203.19 Embankment Over and Around Structures

Fill shall not be placed against any new masonry abutment, wingwall, retaining wall, or culvert, or over any culvert, bridge, or arch until approved. Applicable provisions of 702.23 shall be met.

Filling around culverts, bents, and piers, and fill below the natural ground surface at abutments, wings, and retaining walls shall be deposited on both sides to approximately the same elevation at the same time. Piers or bents shall not be displaced and shall be checked for proper location as the work progresses. Corrective
690 measures shall be made if necessary. Filling at arch structures shall be carried up in horizontal layers, symmetrically from haunch to crown, and simultaneously over and against all piers, abutments, and arch rings.

Wedging action of filling material against structures shall be prevented. If directed, back slopes of excavation shall be destroyed by stepping or serrating.

700 The embankments around the end bents shall be constructed to approximate
subgrade elevation for a distance of no less than 75 ft. This work shall be done
before piling in the end bents are driven, and before the end bent or abutment is
constructed. Compaction shall be in accordance with 203.23. After the embankments
710 are completed, the embankments shall be excavated to construct the end bents and
berms. Before driving piles, pilot holes to receive the piling shall be predrilled
through the embankment in accordance with 701.09(a). After the piles have been
driven, the space between the pile and the predrilled hole shall be backfilled with
granular material as directed. If the embankment in the area of the end bents is to
consist of sand, gravel, or other permeable material in which a predrilled hole would
not remain open, the piling shall be driven before the embankment is constructed. No
direct payment will be made for excavation of the embankment at the end bents or
abutments, or for predrilling, backfilling holes, or excavating fill; those costs shall be
710 included in the cost of other pay items.

203.20 Rock and Shale Embankment

Utilization of these materials in embankment construction shall be in accordance
with the following.

(a) Rock Embankment

720 Where rock is used for embankment, no large stones shall be allowed to nest but
shall be distributed over the area to avoid pockets. Voids shall be filled carefully
with small stones. The final 2 ft of the embankment just below the subgrade
elevation shall be composed of suitable material placed in layers not exceeding 8 in.
loose measurement and compacted to the required density. Shale or shale-like
materials shall not be incorporated in the upper 2 ft of the embankment.

730 Where the depth of an embankment exceeds 5 ft and is to consist entirely of
rock, the rock shall be deposited in lifts not to exceed the top size of the material
being placed, but in no event exceeding 4 ft. The rock for any particular lift shall be
deposited on and pushed over the end of the lift being constructed by means of
bulldozers or other approved equipment. Depositing of rock over the end of any lift
from hauling equipment will not be allowed. If the voids of the last lift are not closed
sufficiently, they shall be choked with small broken stone or other suitable material
and compacted as directed. A geotextile in accordance with 918.02 shall be placed
between the rock and the soil.

740 Where the depth of embankment is 5 ft or less, or where the material being
placed does not consist entirely of rock, the material shall be placed in lifts not to
exceed the top size of the rock being placed but not exceeding 2 ft. Each layer shall
be choked thoroughly with broken stone or other suitable material and be compacted
to the required density or as directed. A geotextile in accordance with 918.02 shall be
placed between the rock and the soil.

Where a rock fill is to be placed over a structure, the structure shall first be covered with 2 to 4 ft of earth or other approved material, and properly compacted before the rock is placed. This covering shall be placed in accordance with 203.19.

Shale shall not be incorporated as rock embankment unless written permission is obtained.

(b) Shale, Shale and Soft Rock Mixtures, or Soft Rock

750 When these materials are encountered and are to be used for embankment construction, the compaction shall be accomplished with an approved vibratory tamping-foot roller in conjunction with a static tamping-foot roller. The minimum weight for the static tamping-foot roller shall be 30 t. The minimum total compactive effort for the vibratory tamping-foot roller shall be 27.5 t. Total compactive effort is defined as that portion of the static weight acting upon the unsprung compaction drum added to the centrifugal force provided by that drum. If the manufacturer's charts do not list the static weight acting on the compaction drum, the roller shall be satisfactorily weighed, the weight shall be added to the centrifugal force, and the roller rated in accordance with the Construction Industry Manufacturers Association, CIMA. Each tamping foot on the static roller shall project from the drum a minimum
760 of 6 in. Each tamping-foot on the vibratory tamping-foot roller shall project from the drum a minimum of 4 in. The surface area of the end of each foot on both tamping-foot rollers shall be no less than 5 1/2 sq in.

Shale, shale and soft rock mixtures, or soft rock shall be placed in 8 in. maximum loose lifts. Strength and moisture control for compacted soils shall be in accordance with 203.23 or the density shall be at least 95% of maximum dry density with moisture control in accordance with 203.23. Excavation and blasting procedures shall accommodate the selective placement of these materials and avoid intermixing rock. Rock shall be placed in accordance with 203.20(a).

770

Water shall be applied to the shale in the cut to accelerate the slaking action and again prior to disking and compaction to facilitate the compaction. The water shall be distributed by an approved method which provides uniform application of the required quantity of water. The water shall be uniformly incorporated throughout the entire lift by a multiple gang disk with a minimum disk wheel diameter of 24 in.

Unless otherwise approved in writing, each embankment lift shall receive a minimum of three passes with the static roller and a minimum of two passes with the vibratory roller. The material shall be bladed before using the vibratory tamping-foot roller. A pass shall be in accordance with 402.15. The rollers shall not exceed 3 mph during these passes. The number of passes will be adjusted upward if necessary to meet the requirements of 203.23. No additional compensation will be allowed for additional passes as specified herein, the cost of which shall be included in the cost of the pay items.

780

Water required to facilitate the slaking and compaction of the shale or soft rock will be measured in accordance with 203.27(h) and paid for in accordance with 203.28. No payment will be allowed for any water required for compaction of material furnished as borrow.

790

(c) Shale and Thinly Layered Limestone

In Dearborn, Decatur, Fayette, Franklin, Jefferson, Ohio, Ripley, Rush, Switzerland, Union, and Wayne Counties specifically, or in other areas where relatively thin layered shale and rock are encountered, their use will be allowed in the construction of embankment, if the following provisions, in addition to those stated in 203.20(b), are observed.

800

1. The slopes shall be encased with a minimum of 10 ft of relatively impervious, non-shale, non-erodable material.
2. The maximum size of limestone in the mixture shall be 6 in. in thickness and 1.5 ft in any other dimension.
3. The minimum number of passes with static roller and the vibratory tamping-foot roller shall be six static and two vibratory.

810

If the material is found to be too intermixed with limestone fragments to enable field density tests as required in this section, this requirement may be waived by written permission. As an alternate to this requirement, proofrolling shall be performed after every four lifts, and the moisture content will be controlled on clayey soils in accordance with 203.23.

203.21 Embankment on Hillsides or Slopes

820

Before an embankment is placed on natural soil slopes or existing fill slopes of 4:1 or flatter, the existing ground surfaces shall be plowed or deeply scarified or, if the nature of the ground indicates greater precautions should be taken for integrating the proposed fill materials with the existing slopes, benches shall be cut into the existing slopes before fill placement is started. All such precautionary work shall be done as directed. No direct payment will be made for plowing or scarifying, the cost thereof to be included in the various pay items of the contract. Before an embankment is placed on natural soil slopes or existing fill slopes steeper than 4:1, benches a minimum of 10 ft wide, unless otherwise specified, shall be cut into the slopes prior to the placement of embankment fill. If benches are cut, the excavation involved will be paid for at the contract unit price per cubic yard for the class or classes of excavation encountered.

203.22 Embankment Over Existing Roadbeds

830

If embankment for new pavement is to be placed over an area where a rigid pavement or any pavement having a concrete base is in place, or in other cases when required, the upper surface of which is 1 ft or less below the subgrade elevation of the proposed new pavement, the existing old pavement, including any concrete base,

shall be removed. The method of removal, disposal, and basis of payment shall be in accordance with 202.05 and 202.14.

If embankment for new pavement is to be placed over an area where an existing rigid pavement is in place, the upper surface of which is more than 1 ft but less than 3 ft below the subgrade elevation of the proposed new pavement, or in other cases when required, the existing pavement shall be broken. Pavement shall be broken so the area of any individual unbroken slab does not exceed 1 sq yd.

840

If embankment for new pavement is to be placed over an area where an asphalt filled brick-type or an asphalt-type surface on a concrete base is in place, and such existing surface is more than 1 ft but less than 3 ft below the subgrade elevation of the proposed new pavement, or in other cases when required, the brick and cushion material, or the asphalt courses, shall be removed and the concrete base broken. Removal of the surfacing material, breaking the base, disposal of removed material, and basis of payment shall be in accordance with 202.05 and 202.14.

850 If embankment for new pavement is to be placed over an area where a flexible-type pavement is in place, the top of which is at the approximate elevation of, or is 1 ft or less below the required subgrade elevation of the proposed new pavement, the existing pavement shall be loosened to the depth directed, but no less than 1 ft. This loosened material shall be spread uniformly over the full width of the subgrade plus 1 ft on each side and compacted. No direct payment will be made for this loosening, spreading, and compacting, the cost thereof to be included in the various pay items of the contract.

860 If embankment for new pavement is to be placed over an existing macadam, the surface of which is more than 1 ft but less than 3 ft below the subgrade elevation of the proposed new pavement, the existing macadam shall be loosened to a depth sufficient to prevent possible trapping of water above the existing surface. No direct payment will be made for this loosening, the cost thereof to be included in the various pay items of the contract.

870 Where the existing roadbed is too narrow, except as otherwise herein provided, new pavement shall not be placed partly on old and partly on new embankment. If the fill supporting an existing roadbed is 1 ft or more in depth, and is too narrow to carry the entire width of the proposed new pavement, the existing width of roadbed shall be taken down to include the new roadbed width and rebuilt from the lowest elevation of the disturbed old roadbed to the required new width. This rebuilding shall be in accordance with these specifications for constructing embankment and as directed. For the necessary tearing down of the existing embankment, payment will be made at the contract unit price per cubic yard for the class or classes of excavation encountered.

If an embankment is to be widened, due precautions shall be taken to ensure a firm foundation. After all sod and other perishable material has been removed, the

880 existing shoulders shall be plowed down 2 ft out from the existing pavement. This material shall be used for widening. Benches, a minimum of 4 ft wide, shall be cut into the slope of the old embankment, unless otherwise directed. The materials from plowing down the shoulders and benching the slopes shall be deposited, spread, and compacted as set out herein for embankment, after which any remaining required embankment shall be finished with additional material, deposited and compacted in like manner. No direct payment will be made for benching, plowing, spreading, and compacting, the cost thereof to be included in the various pay items of the contract.

203.23 Embankment other than Rock, with Strength or Density Control

890 The compaction will be determined by dynamic cone penetrometer, DCP, testing in accordance with ITM 509 and the moisture content in accordance with ITM 506. Soil classification will be performed in accordance with the ITM 512 and the following DCP blow counts will be used for compaction control:

Textural Classification	Maximum Dry Density (pcf)	Optimum Moisture Content Range (%)	Acceptable Minimum DCP value for 6 in.	Acceptable Minimum DCP value for 12 in.
CLAY SOILS				
Clay	< 105	19 - 24	6	
Clay	105 - 110	16 - 18	7	
Clay	111 - 114	14 - 15	8	
SILTY SOILS				
Silty	115 - 116	13 - 14		9
Silty	117 - 120			11
SANDY SOILS				
Sandy	121 - 125	8 - 12		12
Sandy	> 125			15
GRANULAR SOILS - STRUCTURE BACKFILL AND A-1, A-2, A-3 SOILS				
No. 30				6
No. 4				7
1/2 in.				11
1 in.				16

Three random test locations will be determined in accordance with ITM 802 for each 2,000 cy yd of compacted soil for each two-lane pavement section.

As an alternate, all embankments shall be compacted to at least 95% of their maximum dry density determined in accordance with AASHTO T 191 and the moisture content as specified.

900

The moisture compaction range for all soil types shall be as follows:

Soil Type	Moisture Compaction Range
Clay (< 105 lb/cu ft)	-2 to +2% of optimum moisture content
Clay (105 - 114 lb/cu ft)	-2 to +1% of optimum moisture content
Silty and Sandy (> 114 lb/cu ft)	-3% to optimum moisture content
Granular	5 to 8%

Moisture tests will be performed every four hours for clayey soils and once a day for silty, sandy, and granular soil types.

If the embankment material is too wet or too dry, either the material shall be aerated to remove excess moisture or watered and disked to increase the moisture content, until in either case the moisture content is within the specified range.

910 Sufficient moisture tests will be made to ensure that this range is maintained throughout the embankment.

The embankment material shall be placed in uniform level layers, left properly shaped as set out above, and compacted with approved compacting equipment. Compacting equipment shall include at least one 3-wheel roller or other approved compacting equipment capable of providing a smooth and even surface on the embankment as directed.

Each lift shall be disked or treated by some other mechanical means which shall

920 ensure the breaking up of any existing lumps and clods.

The loose depth of each lift shall be such that the required compaction can be obtained, but in no case shall it exceed 8 in. Where a tamping roller is used, the loose depth of lift shall not exceed the length of the tamper feet. The surface area of the end of each foot of the tamping roller shall be no less than 5 1/2 sq in.

203.24 Method of Making Strength, Stiffness and Density Tests

The strength of compacted soils will be determined by DCP in accordance with ITM 509 and the stiffness of aggregates will be determined by the Light Weight Deflectometer in accordance with ITM 508. The percent of compaction shall be based on the maximum dry densities unless otherwise specified or directed. Field compaction tests will be performed in accordance with 203.23 and the required compaction obtained before additional material is placed.

930

(a) Laboratory

The DCP criteria will be established on representative soils by performing ASTM D 1140, AASHTO T 88, AASHTO T 89, AASHTO T 90, and AASHTO T 99 using Method A for soils and Method C for granular materials.

940

(b) Field

The soil strength will be determined by the DCP in accordance with ITM 509 and the moisture content will be determined in accordance with ITM 506.

The field density determination shall be made in accordance with AASHTO T 191 or ITM 512 except as follows:

1. If T 191 is used, the sand used for the test shall be silica sand in accordance with the gradation as follows:

950

Passing the No. 20 (850 μ m) sieve - 98 to 100%

Passing the No. 40 (425 μ m) sieve - 0 to 35%

Passing the No. 70 (212 μ m) sieve - 0 to 2%

Sand such as Wedron Silica Sand No. 4075 or Ottawa 2.8 Blasting Sand has been found to be acceptable.

2. If particles larger than those that can pass through a No. 4 (4.75 mm) sieve for soil and a 3/4 in. (19 mm) sieve for granular material are encountered, corrections shall be made so that the density obtained is for the minus No. 4 (4.75 mm) or 3/4 in. (19 mm) only. After the densities are determined, the degree of compaction shall be computed by the following formula:

960

$$\text{Percent Compaction} = \frac{\text{In Place Density, pcf}}{\text{Maximum Density, pcf}} \times 100$$

3. Other approved types of field density tests may be used for control purposes after density values corresponding to those obtained by either of the methods set out above have been established.
4. All references to soils in these methods of tests shall be interpreted to mean either or both soil and granular materials.

970

203.25 Embankment Without Density Control

When aggregate is used for embankment construction and has such a large top size as to make it impractical to perform density tests, and if approved, such material may be compacted with crawler-tread equipment or with approved vibratory equipment, or both. The materials shall be placed in lifts not to exceed 6 in. loose measurements, or as directed, and each lift compacted thoroughly by successive trips back and forth with the tread areas overlapping enough on each trip so that all portions will be compacted uniformly.

980

At locations inaccessible to the above compacting equipment, the required compaction shall be obtained with approved mechanical tamps or vibrators, in which case the depth of lifts, loose measurement, shall not exceed 4 in.

203.26 Proofrolling

When proofrolling is specified, the work shall be performed with a pneumatic tire roller in accordance with 409.03(d)3. Other approved equipment such as a fully legally loaded tri-axle dump truck may be substituted for the pneumatic tire roller. There shall be one or two complete coverages as directed. Roller marks, irregularities, or failures shall be corrected.

990

203.27 Method of Measurement**(a) Contract Quantity**

The quantities of excavation for which payment will be made will be those shown in the Schedule of Pay Items for the pay items, provided the project is constructed to the lines and grades shown on the plans.

Unless otherwise specified, the project limits will be considered as one balance. If earthwork balances are shown on the plans, they are for information only.

1000

When the plans have been altered or when disagreement exists as to the accuracy of the plan quantities in any balance, or the contract quantity, either party shall have the right to request and cause the quantities involved to be measured in accordance with measured quantities. When the quantities are measured for payment, the original plan cross sections plotted on the plans shall be used as original field cross sections. Additional original cross sections may be interpolated at points where necessary to determine the quantities more accurately. If the Contractor has acceptable engineered data that indicates an excavation quantity that is in error by more than 2%, then additional measurements will be performed on the areas in question and payment will be made for actual quantities.

1010

(b) Measured Quantities

When payment is specified on a volume basis, all accepted excavation and borrow will be measured in its original position by cross sectioning the area excavated, which measurements will include over-breakage or slides in common excavation and unclassified excavation, not attributable to carelessness, and authorized excavation of rock, shale, peat, or other unsuitable material. Volumes will be computed from cross section measurements by the average end area method.

1020

Measurement for payment will not include material excavated beyond authorized cross sections. Where material is excavated beyond authorized cross sections and wasted without authority, the material so wasted will be measured and deducted from the excavation quantities. Unless otherwise authorized, the amount of waste to be deducted, when common excavation, rock excavation, unclassified excavation, borrow, or other excavation has been wasted along embankments or elsewhere without authority shall be that portion of the embankment or fill which is outside a 1/4 to 1 slope in excess of that shown on the plans, and all portions outside a line from the shoulder point to a point 4 ft, measured horizontally, outside the

1030 theoretical toe of the slope. In determining waste, no tolerance in widths of shoulders will be allowed unless additional widths are authorized in writing before shoulders are finally constructed.

Measurements will be made for unsuitable materials actually excavated and removed to obtain proper compaction in cut sections and in foundations for fill sections.

1040 Where it is impracticable to measure material by the cross section method due to the erratic location of isolated deposits, acceptable methods involving three-dimensional measurements may be used to measure the material in its original position.

The cubic yards of peat excavated will be determined by cross sections, as described above, with the final cross sections taken after complete excavation and before placing granular backfill, if peat is removed by excavation. When removal by displacement is necessary, final cross sections will be derived from cased test holes through the completed granular treatment in accordance with 203.17. Such test holes shall be located at intervals which clearly define the bottom of the treatment between lateral limits. Pay quantities of peat excavation will be limited to the volume of peat
1050 lying between vertical lines as shown on the plans for lateral limits.

Cased test holes and exploratory drilling will be measured by the linear foot; Borrow by the cubic yard, in accordance with 211.09. However, measurement to neat lines will not apply unless specifically designated. Breaking pavement will be measured by the square yard in place before breaking.

(c) Measurement on a Linear Basis

Linear grading will be measured by the linear foot. Measurement will be made once along each survey centerline for all linear grading completed on the line.
1060 Deductions will be made for bridges. Classes of excavation, except for required borrow, involved in linear grading will not be measured.

(d) Measurement of Excavation Items on a Weight Basis

A pay item for excavation may be specified to be measured and paid for on a weight basis. When a weight basis is specified, the material will be weighed in accordance with 109.01(b).

(e) Measurement of Embankments

1070 When specified, embankments constructed will be measured in accordance with the terms set forth.

When embankment is specified as a separate pay item, the volume so constructed will be measured in place in accordance with 203.27(b). However, no measurement will be made for excavation or borrow, except as noted herein. The volume shall be computed in cubic yards from the dimensions of the embankment

203.27

cross sections and to the depth below completed grade to which this method of construction applies. No shrinkage factor shall be used in computing the embankment volume. Measurements will be made for unsuitable materials actually excavated and removed to obtain proper compaction in cut sections and in foundations of fill sections in accordance with 203.27(b). B borrow from off the right-of-way placed within embankment areas will be measured in accordance with 211.09.

(f) Measurement of Borrow

Borrow will be measured by the cubic yard. Except as otherwise provided herein, borrow will be cross sectioned in its original position before excavation is started, again after it is completed, and the volume computed by the average end area method. No material shall be excavated as borrow until unsuitable material, vegetation, and other perishable matter have been removed and cross sections taken over the cleared area. None of this removed unacceptable material shall be move back into the pit before final sections are taken.

If borrow is obtained from a source where it is impracticable to measure the material in its original position, such material will be measured after being placed in embankment with no allowance made for a compaction factor. The borrow may be measured in truck beds in accordance with 211.09 for contracts having a proposal quantity less than 500 cu yd. If such source is contemplated, approval shall be obtained in writing before this part of the work is started. For quantities less than 5,000 cu yd, the material may be weighed in accordance with 109.01(b) and converted from pounds shown on the weigh tickets to cubic yards using a factor of 3,000 lb/cu yd.

If borrow is specified outside the limits of B borrow and if the requirements of the work do not otherwise prohibit, material in accordance with these specifications for B borrow, may be furnished and placed at the contract unit price for borrow, in which case measurement will be in accordance with 211.09. Measurement of borrow in accordance with 211.09 will be limited to nominal quantities outside the limits of structure backfill. The quantity of borrow measured for payment will not exceed the theoretical quantity of B borrow furnished.

1110

(g) Measurement of Embankment Foundation Soils Treatment

Mechanical treatment of embankment foundation soils will be measured by the square yard. Chemical treatment of embankment foundation soils will be measured in accordance with 217.

(h) Measurement of Water for Shale, Shale and Soft Rock Mixtures, or Soft Rock

When payment for water for shale is specified in the contract, the water for shale used will be measured by the 1,000 gal. by means of calibrated tanks or distributors, or by means of accurate water meters. When water for shale is not specified as a pay

1120

item in the contract, the water for shale that is used will not be measured directly. Such measurement will be included in that required for other pay items.

(i) Lump Sum

If the pay unit for a pay item for excavation is lump sum, no measurement will be made.

(j) Measurement of Exploratory Cores

Exploratory cores will be measured by the linear foot of rock core.

1130

203.28 Basis of Payment

The accepted quantities of excavation and embankment will be paid for at the contract price per unit of measurement for each of the pay items listed below which is included in the Schedule of Pay Items. Common excavation and unclassified excavation will be paid for on the unit basis of contract quantities in accordance with 203.27(a), without any quantity limit, unless otherwise shown in the Schedule of Pay Items. Combined quantities of borrow, common and unclassified excavation not exceeding 15,000 cu yd will be paid for on the basis of contract quantities in accordance with 203.27(a) with no adjustment to plan shrinkage factor. Except as noted above, borrow, as well as all other excavation, will be paid for on the basis of measured quantities in accordance with 203.27(b), unless otherwise shown in the Schedule of Pay Items. Linear grading will be paid for at the contract unit price per linear foot.

1140

If the class of excavation is linear grading, additional borrow and the excavation of and disposal of unsuitable material not included as pay items will be paid for as follows:

If the total quantity exceeds 5,000 cu yd at a given location, it will be paid for at \$8.00 per cu yd. If the total quantity exceeds 1,000 cu yd, but does not exceed 5,000 cu yd at a given location, it will be paid for at \$12.00 per cu yd. If the total quantity does not exceed 1,000 cu yd at a given location, it will be paid for at \$15.00 per cu yd.

1150

Linear grading includes only such grading within the construction limits. All grading the Contractor is directed to perform outside the construction limits, except for the Contractor's convenience, will be paid for in accordance with 104.03 or 109.03 unless such grading is shown on the plans or in the Contract Information book.

1160

Existing concrete building foundations, concrete walls, concrete columns, or concrete steps not visible and not shown on the plans within the limits of the planned excavation will be paid for at 10 times the contract unit price per cubic yard for common or unclassified excavation, whichever is set out as a pay item. Unless a waste area is established within the contract limits, the minimum pay for this work will be \$80.00 per cu yd.

Excavation and disposal of unsuitable material will be paid for at the contract unit price for the class of excavation involved. If no such pay item is included in the contract and embankment is included as a pay item, the excavation and disposal will be paid for at the contract unit price for embankment, unless otherwise directed.

1170

If there is no pay item for rock excavation and such is encountered, it will be paid for at \$125.00 per cu yd for quantities less than or equal to 100 cu yd. For quantities greater than 100 cu yd pay will be determined in accordance with 104.03.

If there is no pay item for common excavation and if such is encountered, it will be paid for at the contract unit price per cubic yard for borrow.

1180

If the contract includes a pay item for waterway excavation, and if class Y excavation is encountered and there is no pay item for such, the class Y excavation will be paid for at 10 times the contract unit price per cubic yard for waterway excavation, or \$100.00 per cu yd, whichever is greater.

If the contract does not include a pay item for waterway excavation and such is encountered, pay will be determined in accordance with 104.03.

1190

If excavation is necessary to investigate or to seal sinkholes, or to explore underground drainage, the accepted quantity involved at each location will be paid for as follows. The first 10 cu yd or fraction thereof will be paid for at 10 times the contract unit price for the class of excavation encountered. The next 40 cu yd or fraction thereof will be paid for at seven times the contract unit price for the class of excavation involved. Additional quantities will be paid for at three times the contract unit price per cubic yard for the class of excavation involved.

1200

Material overlying the peat deposits which is excavated and used in embankment will be considered as common excavation and will be paid for as such. Excavation for standard side ditches or other side ditches which are constructed through peat areas at locations shown on the plans, or where directed, will be paid for at the contract unit price per cubic yard for common excavation.

Mechanical treatment of embankment foundation soils will be paid for by the square yard as embankment foundation soils treatment.

Cased test holes and exploratory drilling will be paid for at the contract unit price per linear foot.

1210

If there is no pay item for borrow, the costs of identifying the borrow areas, the archeological investigation, all required permits, and the opening and closing of the borrow area will be included in a change order developed in accordance with 109.05 and paid for as borrow area.

If the contract documents do not identify excess excavation or require removal of any items from the site, the cost of identifying a disposal area, archeological investigation, all required permits, and the opening and closing of the disposal area will be included in a change order developed in accordance with 109.05 and paid for as disposal area.

1220 If a type of excavation for which no pay item exists is required and the new type of excavation requires the Contractor to use equipment not otherwise being used on the contract, all cost involved in determining the type of equipment necessary to complete the work and making this equipment available for the project will be included in a change order developed in accordance with 109.05 and paid for as additional mobilization and demobilization.

1230 If a type of excavation for which no pay item exists is required and the new type of excavation requires additional traffic control not shown on the plans or results in traffic control being required for an additional period of time, all cost involved in providing the additional traffic control will be included in a change order developed in accordance with 109.05 and paid for as additional maintaining of traffic.

Payment will be made under:

	Pay Item	Pay Unit Symbol
	Borrow.....	CYS
	Breaking Pavement.....	SYS
	Cased Test Holes.....	LFT
	Embankment.....	CYS
1240	Embankment Foundation Soils Treatment.....	SYS
	Excavation, Common.....	CYS
	Excavation, Peat.....	CYS
	Excavation, Rock.....	CYS
	Excavation, Unclassified.....	CYS
	Excavation, Waterway.....	CYS
	Excavation, Y.....	CYS
	Exploratory Cores.....	LFT
	Exploratory Drilling.....	LFT
	Linear Grading.....	LFT
1250	Water for Shale.....	kGAL.

If embankment is specified as a pay item, borrow and common excavation, unless otherwise specified, will not be paid for directly. The costs thereof shall be included in the cost of embankment. Such price shall be full compensation for preparation of the natural ground on which the embankment is to be placed and excavating, hauling, placing, spreading, and compaction of materials in accordance with 203.23. The costs of labor, equipment, tools, and necessary incidentals shall be included in the cost of embankment. The cubic yards of suitable material used in the

203.28

1260 embankment excavated from the right-of-way and paid for under a specific pay item will not be deducted from the embankment quantities. The quantity of material to be paid for as B borrow and placed within the embankment area as specified will be deducted from the quantity of embankment.

The costs of excavating, backfilling, disposal of surplus material, labor, equipment, tools, and necessary incidentals necessary shall be included in the cost of excavation required to seal sinkholes or explore underground damage.

1270 The costs of all excavated or displaced peat, regardless of depth, peat disposal, temporary surcharge, machine operation, and machine availability shall be included in the cost of peat excavation. However, the Department may provide temporary right-of-way for peat disposal when so specified.

Cost for providing additional lighting for grading operations shall be included in the cost of other pay items in this section.

No payment will be made for the construction or restoration of borrow or disposal sites.

1280 No payment will be made for the inspection of disposal and borrow areas for wetland identification, obtaining of permits, the development and construction of all mitigation measures, or the fulfillment of permit requirements.

The cost of boring the holes, casings and fittings, labor, equipment, tools, and all necessary incidentals shall be included in the cost of cased test holes or exploratory drilling.

The cost of reshaping scoured or eroded areas shall be included in the cost of other pay items.

1290 The cost of surface roughening shall be included in the cost of other pay items.

The cost of identification of borrow areas, archeological investigations, and changes to construction operations caused by the identification of an archeological site shall be included in the cost of borrow, unless otherwise agreed to in writing.

The cost of all classes of excavation, except required borrow, within the limits of linear grading shall be included in the cost of linear grading.

The cost of geotextiles shall be included in the cost of other pay items.

1300

SECTION 204 – GEOTECHNICAL INSTRUMENTATION

204.01 Description

This work shall consist of providing, installing and maintaining of geotechnical instrumentation including settlement plates, settlement stakes, lateral stakes and standpipe piezometers as directed and in accordance with 105.03.

MATERIALS

10 204.02 Materials

Materials shall be in accordance with the following:

B Borrow	211.02
Coarse Aggregate, Class D or Higher, Size No. 53.....	904
Ottawa Sand*	AASHTO T 252
Structure Backfill, Size No. 30	904

* Ottawa Sand shall have a minimum permeability of 25 ft/day.

20 Bentonite chips shall consist of commercially processed angular fragments of pure bentonite, without additives.

Bentonite-cement grout shall consist of a mixture with the ratio of 25 lb of bentonite with 94 lb of Portland Cement, type I in accordance with 901.01(b) and a 30 gal. of water.

CONSTRUCTION REQUIREMENTS

204.03 Settlement Plates

30 Settlement plates consist of 1/2 in. by 3 ft by 3 ft steel plate equipped with sections of 3/4 in. pipe and 2 in. galvanized threaded pipe and couplings to act as a cover or guard.

(a) Installation Requirements

40 Each settlement plate shall be placed on a horizontal plane consisting of a compacted leveling layer of B borrow, whose surface is not less than 1 ft below the elevation of the adjacent area. The first section of pipe shall then be installed by welding to the settlement plate. The bottom elevation of the settlement plate will be recorded. The area is backfilled with B borrow and thoroughly compacted. The couplings shall be tack welded and the top elevation of the first pipe section will be recorded before starting the first lift of grading operations.

The pipe sections for the settlement plates shall be 3/4 in. steel pipe, 4 ft long and threaded on both ends with proper fittings so that such pipe sections can be extended vertically from the center of the plates up through the new embankment as it increases in height during grading operations. A cover pipe 2 in. shall be slipped over and centered on the standpipe, and not welded to plates. The 3/4 in. steel and

cover pipes shall extend a minimum of 2 ft or more above the grade of the new embankments at all times during grading operations and monitoring period.

- 50 Settlement stakes and lateral stakes, if required, shall be installed as shown on the plans or as directed by the Engineer. The stakes shall be 3/4 in. by 4 ft steel rods and shall be driven at least 12 in. into the ground. These stakes shall be set firmly in a vertical position and initial readings will be taken.

B borrow shall be used as compaction material around the settlement plates and pipes and shall be placed in accordance with the applicable requirements of 211.

(b) Instrument Readings and Settlement Period

- 60 During the construction of the embankment, elevation readings will be taken on all settlement plate extension pipes and settlement stakes at the end of each seven-day period, or more frequently if required. After the embankment is constructed to subgrade elevation, additional readings will be taken every seven days until the settlement rate per week is 1/4 in. or less for four consecutive weeks. The monitoring period may be reduced as directed by the Department's Geotechnical Section.

If the results of any readings indicate that the new embankment has settlement greater than 1/4 in., the monitoring period will be extended until the settlement requirements are met.

- 70 Settlement stakes will be used to measure the vertical movement, in conjunction with settlement plates if specified. Settlement stakes and settlement plates will be monitored at the same time and interval. Measurements will be made to the nearest 1/4 in. Settlement data will be sent electronically to the Department's Geotechnical Section within one day of the readings for approval.

Lateral stakes will be used to monitor horizontal movement of the ground or new fill. If lateral movement is noticed during the construction of the fill, the work will be suspended and corrective measures taken as directed. Measurements will be made to the nearest 1/4 in.

- 80 Settlement plates, extension pipes, cover pipes, and stakes shall be protected during construction operations and during the monitoring period.

204.04 Standpipe Piezometers

The standpipe piezometers shall be installed by a Department approved Geotechnical Consultant prior to placing the first lift of embankment. Piezometer consists of a 1/2 in. leak proof, flush-coupled Schedule 80 PVC pipe or ABS standpipe extending to the surface of the embankment with an attached polyethylene tip in accordance with AASHTO T 252.

90

(a) Installation Requirements

A separate water-monitoring borehole shall be installed outside the influence of the fill as shown on the plans. This shall be a minimum 2 in. diameter borehole, cased with slotted pipes, drilled to a recommended depth and location or as directed by the Engineer, to establish ground water elevation prior to piezometer installation.

The installation of the standpipe piezometer shall precede placement of any embankment by at least two weeks to allow time for testing of the installation. The piezometer shall be maintained and protected during the embankment construction.

100 The hollow stem auger shall be advanced to an approximate depth of 6 in. below the recommended piezometer tip elevation. Augers shall be cleaned and washed inside for their full length, until the wash water runs clear.

The auger shall be withdrawn 6 in. by means of jacking or other steady pull operations. The hole shall be filled to the bottom with saturated Ottawa sand and tamped with an annular tamping hammer. The elevation shall be measured and provided to the Engineer.

The tip shall be attached to the standpipe and tested for free flow of water. The bottom end of the tip shall be plugged and soaked in water if a porous stone tip is used. The tip and standpipe shall be filled with clean water. The tip shall be lowered into the auger until it rests on the top of the sand placed and the elevation of the tip should be documented. Excess head shall be maintained in the standpipe during lowering to ensure that a small amount of water flows out of the tip.

110

The auger shall then be pulled or jacked a distance equal to the length of the tip in increments of 6 in. The hole shall be filled with water saturated Ottawa sand at each increment. This layer of sand shall not be tamped in order to avoid damage to the tip.

120

The auger shall be raised 12 in. and the hole filled with saturated Ottawa sand in 6 in. increments until the backfilling reaches a minimum of 6 in. below the elevation of the strata change or as directed by the Engineer. In locations where there is no strata change, the Ottawa sand shall be placed a minimum of 12 in. above the top of the tip.

The augers shall then be raised and the hole sealed with bentonite chips in accordance with AASHTO T 252 which shall be placed in 6 in. lifts. The top of the seal shall be a minimum of 6 in. above the strata break. A weighted line shall be used to ensure the bentonite seal is in place. The remainder of the hole shall then be backfilled with bentonite-cement grout as the augers are withdrawn. The riser pipe shall be kept in tension and shall be centered in the auger while backfilling. Depths for various stages shall be recorded on the Engineers' logs.

130

If the piezometer location is not in an area of proposed fill, a protective metal cover, about 3 ft long shall be installed at the top with about 2 ft below the surface

and 12 in. above the surface. A 6 in. circular pad of coarse aggregate; 6 in. thick shall be filled around the cover. A lockable cap shall be securely attached onto the protective metal cover.

140

If the piezometer location is in an area of proposed fill, a PVC casing shall be used around the piezometer standpipe in order to protect the pipes during embankment construction. A borrow shall be placed and compacted around the casing without disturbing the casing.

150

The casing and standpipe shall be extended as the fill is placed, by adding extra lengths not to exceed 5 ft. The top of the standpipe shall be at least 12 in. above the grade of the new fill. Each time the casing and standpipe are extended, the casing shall be filled with structure backfill. The last extension of pipe shall be of such length that it extends 12 in. above grade. It shall be filled with structure backfill to within 9 in. of the top of the casing. A 6 in. circular pad of coarse aggregate, 6 in. thick shall be filled around the pipes. A lockable cap shall be securely attached onto the protective cover.

160

When the standpipe is completed it shall be checked for obstructions by dropping a weighted line through the pipe. The standpipe shall then be filled with water and periodic readings made of the water level until the ground water level is stabilized. Hydrostatic time lag required for equalization will be provided by the Geotechnical report. If required, the standpipe shall be flushed and retested at the direction of the Engineer. Ground water readings shall be provided to the Engineer.

Standpipe piezometers, and cover pipes shall be protected during construction operations and during the monitoring of the fill. In the event of damage, fill construction shall be suspended in this area until the piezometer is restored.

(b) Readings and Maintenance of Piezometer

170

The Engineer will conduct and record all observations and measurements required to determine natural ground water elevations and pore pressures induced by embankment construction. Monitoring intervals will be once every day for the first seven days, once every other day for the next eight, and then, once every three days through the end of construction of the fill. The elevation of the natural ground water existing at the time of installation, prior to placement of any fill, will be used as a reference to determine baseline pore pressures. Ground water and pore pressure test results will be made available to the Contractor.

180

The pore pressure measurement in conjunction with settlement data will be sent electronically to the Department's Geotechnical Section within one day of the readings for approval. If it is determined that pore-water pressures have not sufficiently dissipated, fill placement shall be suspended, and the monitoring period extended as directed.

If monitoring is to be continued after paving in a traffic accessible area, then the pipe shall be cut off 6 in. below the finished grade and a handhole in accordance with 807.09, shall be installed for monitoring access. When the evaluation is completed, the water monitoring borehole and piezometers shall be backfilled with bentonite-cement grout.

204.05 Method of Measurement

190 Settlement plates, settlement stakes, lateral stakes, standpipe piezometers, and water monitoring boreholes will be measured by the number of units installed.

204.06 Basis of Payment

Settlement plates, settlement stakes, lateral stakes, standpipe piezometers, and water monitoring boreholes will be paid for at the contract unit price per each.

Payment will be made under:

	Pay Item	Pay Unit Symbol
200	Settlement Plate	EACH
	Stake, Lateral	EACH
	Stake, Settlement	EACH
	Standpipe Piezometer	EACH
	Water Monitoring Borehole	EACH

The cost of furnishing, installing, and maintaining settlement plates, extension pipes, cover pipes, B borrow, structure backfill, coarse aggregate and all necessary incidentals shall be included in the cost of settlement plates.

210 The cost of backfilling water monitoring boreholes will be included in cost of water monitoring boreholes.

The cost of handholes, protective covers, bentonite chips, bentonite-cement grout, Ottawa sand, tips, casing, drilling, tubing or PVC pipe, backfilling and measurements will be included in the cost of standpipe piezometers.

220 No additional compensation will be made for any costs incurred related to the repair of settlement plates, pipes, settlement stakes, lateral stakes or standpipe piezometers as the result of damage by the Contractor.

SECTION 205 – TEMPORARY EROSION AND SEDIMENT CONTROL**205.01 Description**

This work shall consist of furnishing, installing, maintaining, and removing temporary erosion and sediment control measures in accordance with 105.03.

MATERIALS**205.02 Materials**

10 Materials shall be in accordance with the following:

	Coarse Aggregate, Class F or Higher	904
	Fertilizer	914.03
	Filter Sock	914.09(h)
	Geotextile	918
	Grass Seed, Temporary	914.02
	Manufactured Surface Protection Products	205.04(c)
	Metal End Sections.....	908.06
	Mulch	914.05(a)
20	Pipe Drains	715.02(d)
	Plastic Net	914.09(g)
	Revetment Riprap.....	904
	Stakes	914.09(b)
	Top Soil.....	914.01
	Water	914.09(a)
	Wire Staples	914.09(f)

Straw bales shall not weigh less than 35 lb. Bales shall be bound with wire or nylon twine.

30

CONSTRUCTION REQUIREMENTS**205.03 General Requirements**

The installation of temporary erosion and sediment control measures shall include those necessary or required by permits at off-site locations such as borrow and disposal areas, field office sites, batch plants, locations where the Contractor's vehicles enter and leave public roads, and other locations where work pertaining to the contract is occurring. The Contractor's designated individual in accordance with 108.04 shall be responsible for the installation, inspection, and maintenance of these measures. Temporary erosion control measures shall be placed as soon as practical. Perimeter protection and sediment traps shall be installed prior to beginning earth disturbing activities. Pipe end sections and anchors shall be installed when the structure is installed. If the pipe end sections or anchors cannot be placed at the same time, temporary riprap splashpads shall be placed at the outlets of the pipes until end sections or anchors can be installed.

40

Adjustments of the erosion and sediment control measures shall be subject to the Engineer's approval to satisfy field conditions. These measures shall be constructed as soon as practical and shall be maintained as necessary.

50

The Contractor shall provide a stable construction entrance at the points where construction traffic will enter onto an existing road. Additional stone may be required, as directed by the Engineer. Where there is insufficient space for a stable construction entrance, other measures shall be taken to prevent the tracking of sediment onto the pavement. Temporary entrances utilized by the Contractor for borrow and waste areas will not be paid for directly. These temporary entrances shall be the responsibility of the Contractor to completely install, maintain, and remove.

60 Non-vegetated areas shall be temporary stabilized if the area remains inactive for more than seven days or as directed by the Engineer. The area will be considered inactive when no meaningful work toward accomplishing a pay item has been performed at a site of disturbed soil.

The Contractor shall provide concrete washout facilities of adequate capacity in accordance with project requirements. The concrete washout shall be located as far from surface waters as practical, and shall be able to contain all liquid and solid material from concrete truck or mixer washing operations without contacting or contaminating the ground.

70 The Contractor shall employ dust control measures in accordance with 107.08.

205.04 Temporary Surface Stabilization

(a) Seed

Temporary seeding shall be placed on disturbed areas that are expected to be inactive for more than seven days, or as directed. Seed shall be placed either by drilling in, spraying in a water mixture, or by use of a mechanical method which places the seed in direct contact with the soil. Where inaccessible to mechanical equipment, or where the area to be seeded is small, a hand operated cyclone seeder or other approved equipment may be used. Seed shall not be covered more than 1/2 in. Seed may be distributed by a drill seeder, cyclone seeder, hand or other approved equipment which allows for even distribution of the seed. If as a result of a rain event, the prepared seed bed becomes crusted or eroded, or ruts, or depressions exist, the soil shall be reworked until it is smooth. Reworked areas shall be re-seeded. All seeded areas shall be mulched within 24 h after seeding.

Seed mixture T shall be used for surface stabilization and temporary ground cover. Temporary cover mixtures shall be placed as directed and be subject to seasonal limitations as defined herein. This mixture is not intended to be used as a permanent seed mixture. This mixture shall not be used to satisfy the requirements of the warranty bond.

90

205.04

The mix shall be spray mulched where the slope is steeper than 3:1. From June 16 through August 31, mulching alone shall be used to stabilize the soil.

1. Spring Mix

Spring mix shall be used from January 1 through June 15. This mixture shall be applied at the rate of 150 lb/ac. The mix shall consist of oats.

100

2. Fall Mix

Fall mix shall be used from September 1 through December 31. This mixture shall be applied at the rate of 150 lb/ac. This mix shall consist of winter wheat.

Where directed, fertilizer shall be spread uniformly over the area to be seeded and shall be applied at 1/2 the rate shown in 621.05(a) unless otherwise directed. Fertilizer shall only be applied during the active growing season March through November.

(b) Mulch

110

Mulch shall be applied uniformly in a continuous blanket at the rate of 2.5 t/ac. If seeded, mulch shall be placed within 24 h after seeding. The percent of moisture in the mulch shall be determined in accordance with 621.14(c).

Mulch shall be punched into the soil so that it is partially covered. The punching operation shall be performed longitudinally to the slope. The tools used for punching purposes shall be disks that are notched and have a minimum diameter of 16 in. The disks shall be flat or uncupped. Disks shall be placed a minimum of 8 in. apart. Shaft or axle sections of disks shall not exceed 8 ft in length.

120

The disk for punching shall be constructed so that weight may be added or hydraulic force may be used to push puncher into the ground. An even distribution of mulch shall be incorporated into the soil.

On a slope of 3:1 or steeper but flatter than 2:1, or where specified, temporary mulch stabilization shall also be used. Unless otherwise specified, the following types may be used.

1. Type A

130

The mulch shall be held in place by means of commercially produced water borne mulch binder product. The product shall be manufactured and used in accordance with all applicable State and Federal regulations. Such product shall be applied in accordance with the manufacturer's written instructions. A copy of the written instructions shall be supplied to the Engineer prior to the seeding work. The product shall include a coverage indicator to facilitate visual inspection for evenness of application. If the mulch fails to stay in place, the Contractor shall repair all damaged areas.

2. Type B

140 The mulch shall be held in place with binder twine fastened down with wooden
 140 pegs not less than 6 in. long spaced 4 ft apart. The twine shall be placed parallel to
 and also at 60° to the pavement edge in both directions. The distance between the
 intersections of the diagonal strands measured along the strands shall be 12 ft. The
 strand parallel to the pavement shall cross the diagonal strands at their intersections
 to form equilateral triangles of 12 ft on a side.

3. Type C

150 The mulch shall be held in place with a polymeric plastic net. The plastic net
 shall be unrolled such that it lays out flat, evenly, and smoothly, without stretching
 the material. The plastic net shall be held in place by means of wire staples. The wire
 150 staples shall be driven at a 90° angle to the plane of the soil slope. Staples shall be
 spaced not more than 4 ft apart with rows alternately spaced. The plastic net shall be
 secured along the top and bottom of the soil slope with staples spaced not more than
 1 ft on center. The ends and edges of the plastic net shall be overlapped
 approximately 4 in. and stapled. Overlaps running parallel to the slope shall be
 stapled 1 ft on center and overlaps running perpendicular to the slope shall be stapled
 at least 3 ft on center. The plastic net shall be placed with the length running from
 top of slope to toe of slope, or the plastic net shall be placed with the length running
 horizontally or parallel to the contour.

160 On a slope of 2:1 or steeper, or where specified, a manufactured surface
 protection product shall be used.

(c) Manufactured Surface Protection Products

The following manufactured surface protection products may be used for
 covering an area that has not been seeded. Soil cover shall not be used to cover
 seeded areas. Prior to placing the manufactured surface protection product, the area
 to be covered shall be free of all rocks or clods of over 1 1/2 in. in diameter, and all
 sticks or other foreign material, which prevent the close contact of the blanket with
 the seed bed.

170

After the area has been properly shaped, fertilized, and seeded, the manufactured
 surface protection product shall be laid out flat, evenly, and smoothly, without
 stretching the material.

1. Excelsior Blanket

An excelsior blanket may be used as mulch for seeding where seeding is
 specified or where erosion control blanket is specified. Excelsior blankets shall be
 placed within 24 h after seeding operations have been completed. Excelsior blankets
 shall be installed in accordance with the manufacturer's recommendation.

180

2. Straw Blanket

A straw blanket may be used as mulch for seeding where mulched seeding is
 specified or where erosion control blanket is specified. Straw blankets shall be

placed within 24 h after seeding. The straw blanket shall be unrolled over the designated area so that the plastic mesh is on top and the straw fibers are snugly and uniformly in contact with the soil surface. The rolls shall be butted together and stapled in place. The staples shall be driven through the blanket at a 90° angle to the plane of the ground surface. Each staple shall anchor the plastic mesh. The staples shall be spaced per the manufacturer's recommendation.

190

For placement on a slope, the straw blankets shall be placed with the length running from the top of slope to the toe of slope and shall extend a minimum of 3 ft over the crown of the slope. The blanket shall be stapled in accordance with the manufacturer's recommendation.

For placement in ditch lines, the straw blanket shall be unrolled parallel to the centerline of the ditch. The blanket shall be placed so that there are no longitudinal seams within 24 in. of the bottom centerline of the ditch. In a ditch line, the blanket shall be stapled in accordance with the manufacturer's recommendation with a
200 minimum of six staples across the upstream end of each roll.

3. Rolled Erosion Control Products

Where directed, the Contractor shall install, or with approval of the Engineer, the Contractor may use degradable rolled erosion control products, RECP, including netting, open weave textile, and erosion control blankets.

Unless soil infilling is required, seed shall first be applied in accordance with 621. If soil infilling is required, RECP shall be first installed and then seed applied and brushed or raked 1/4 to 3/4 in. of topsoil into voids in the RECP filling the full
210 product thickness. Staples of at least 6 in. in length shall be used to secure the RECP. The RECP shall be unrolled parallel to the primary direction of flow and placed in direct contact with the soil surface. RECP shall not bridge over surface inconsistencies. Edges of adjacent RECP shall be overlapped by 2 to 4 in. Staples shall be placed to prevent seam separation in accordance with the manufacturer's recommendations.

4. Geotextile

Where directed, disturbed soil shall be covered with geotextile. The covering shall be placed over the exposed soil in a shingle like fashion with a 2 ft minimum
220 overlap covering all loose or disturbed soil. The geotextile, if new, shall be in accordance with 918.02. The geotextile used for soil covering need not be new but shall not have holes or unrepaired rips or tears. All repairs shall be made in accordance with the manufacturer's recommendation.

205.05 Concentrated Flow Protection

(a) Check Dam

Check dams and modified check dams shall be constructed as shown on the plans. Geotextile for check dams shall be in accordance with 616 unless otherwise

230 specified. Revetment riprap shall be in accordance with 616 unless otherwise specified. No. 5 and No. 8 filter stone shall be in accordance with 904.

(b) Check Dam, Traversable

Traversable check dams shall be composed of straw bales, 8 in. minimum diameter fiber rolls, or 8 in. minimum diameter socks filled with straw, ground wood chips, shredded bark, or other approved material for site specific conditions. Rolls and socks may be stacked in a triangle pattern as shown on the plans. Check dams shall be staked as shown on the plans or as directed by the manufacturer. Check dams shall be configured to eliminate gaps between sections. Straw bales shall be
240 placed such that the bindings are parallel to and not in contact with the ground.

(c) Diversion Interceptors

Grading for diversion interceptors shall be in accordance with 203 with the exception that compaction requirements will not apply. The Contractor shall identify, in the SWPPP update, the construction areas which shall utilize diversion type A or B. Revetment riprap stable outlet with geotextile shall be constructed in accordance with 616 unless otherwise specified. Perimeter diversion, type C shall be installed prior to earth moving activities and shall be immediately stabilized. Type A or B shall be stabilized if anticipated to be left in place for more than 15 calendar days.
250 Stabilization methods shall be as shown on the plans or as directed by the Engineer.

(d) Sediment Traps

Revetment riprap and filter stone in accordance with 904 shall be used in construction of sediment traps, unless otherwise specified. Geotextiles shall be in accordance with 918.02.

(e) Sediment Basins

Embankment construction shall be in accordance with 203. Revetment riprap used for overflow protection shall be in accordance with 904, unless otherwise
260 specified. Sediment basins shall be constructed as shown on the plans, or as directed.

(f) Slope Drains

Slope drain pipes shall be lengthened as required due to the construction of the embankment.

(g) Vegetative Filter Strips

Designated vegetative filter strips shall not be disturbed. Small rills that form shall be repaired. Fertilizer shall be applied as directed.

270 **(h) Splashpads**

Splashpads shall be constructed with revetment riprap with geotextile in accordance with 904 and 918, respectively.

205.06

(i) Inlet Protection

All deck and curb drains shall have sediment control measures when the structure or road is to be used for hauling operations or adjacent to disturbed areas. Copies of all current manufacturers' installation manuals shall be provided prior to installation.

280 Inlet protection shall be as shown on the plans.

(j) Retention Ponds

Excavation shall be in accordance with 203. The soil used in the liner shall be in accordance with AASHTO M 145, classification A-6 or A-7.

The sides and bottom of the retention pond shall be lined with a soil liner of 2 ft minimum thickness. The soil in the liner shall be compacted to 95% of the maximum dry density in accordance with 203.23. The Contractor may use an alternate pond lining system. Details of the proposed pond lining system shall be submitted to the
290 Office of Geotechnical Services for approval. The details shall include all necessary information such as liner thickness, smooth versus textured surface, thickness and type of proposed soil cover, joint construction, material used in the liner, and the manufacturer of the liner.

205.06 Perimeter Protection

(a) Silt Fence

Shipping, handling and storage shall be in accordance with the manufacturer's recommendations. The silt fence material shall be in accordance with 918.04. The
300 geotextile will be rejected if it has defects, tears, punctures, flaws, deterioration, or damage incurred during manufacture, transportation, storage, or installation. Each roll shall be labeled or tagged to provide product identification.

Joints shall be made from the ends of each section of fence wrapped around a wood stake and joined together. Copies of all current manufacturer manuals shall be provided prior to installation.

(b) Filter Berm

A filter berm shall be installed as shown on the plans. The filter berm may be
310 constructed of organic mulch, filter sock, or No. 5 and No. 8 filter stone in accordance with 904.

205.07 Maintenance

Temporary erosion and sediment control measures shall be inspected, at a minimum, once every seven days and after a 1/2 in. rain event. Inspections shall be documented and records shall be maintained by the Contractor, to be submitted to the Engineer on the next business day following the inspection. The temporary protection measures shall be returned to working conditions within 48 h after

inspection or as directed. The Contractor shall rebuild or repair damaged temporary
320 erosion and sediment control measures.

(a) Silt Fence

If the fence fabric tears, starts to decompose, or becomes ineffective, the affected portion shall be replaced. Deposited sediment shall be removed once it reaches 1/2 the height of the fence at its lowest point. Once the contributing drainage area has been stabilized, the Contractor shall remove the fence and sediment deposits, grade the site to blend with the surrounding area, and stabilize the graded area.

330 **(b) Sediment Basin**

Sediment shall be removed once it has accumulated to the design volume. The filter stone around the riser pipe shall be replaced if the sediment pool does not drain within 72 h following a stormwater runoff event.

(c) Filter Berm

Accumulated sediment shall be removed once it reaches 1/4 of the height of the filter berm. The filter berm shall be inspected to ensure that it is holding its shape and allowing adequate flow. Eroded and damaged areas shall be repaired.

340 **(d) Inlet Protection**

Accumulated sediment shall be removed once identified and after each storm event. Flushing with water will not be allowed. The sediment shall not be allowed to re-enter the paved area or storm drains. Curb inlet inserts shall be cleaned in accordance with the manufacturer's recommendations.

(e) Sediment Traps

Following each storm event, the Contractor shall repair slope erosion and piping holes as required. Sediment shall be removed once it has accumulated to 1/2 design volume. The Contractor shall replace the coarse aggregate filter stone if the sediment
350 pool does not drain within 72 h following a stormwater runoff event.

(f) Concrete Washout

The containment system shall be inspected for leaks, spills, and tears, and shall be repaired or replaced as necessary. The Contractor shall ensure that each containment system maintains adequate capacity. Solidified waste concrete shall be disposed of in accordance with 202.

(g) Check Dams

Sediment shall be removed once it reaches 1/2 the height of the check dam.
360 Sediment shall be removed and disposed of in accordance with 201.03 and 203.08. The Contractor shall rebuild or repair each damaged check dam to maintain the design height, cross section, and erosion control function.

205.08 Quality Adjustments

If maintenance deficiencies are not remedied within 48 h after identifying them in the inspection or as directed, the Contractor may be assessed damages for failure to maintain the required temporary erosion and sediment control. For each day, during which the following units of temporary erosion and sediment control are in an unsatisfactory condition, a quality adjustment, in accordance with 109, will be assessed as shown for each day, per unsatisfactory unit.

370

If conditions do not allow the Contractor access to the location of the erosion or sediment control features using normal equipment and maintenance has been directed, the Contractor may propose a written alternate schedule, within 48 h, to bring the erosion and sediment control features back into compliance. Damages may be assessed based on compliance with the approved schedule.

380

- (a) Silt Fence: \$100.00 per each contiguous 100 ft section or portion thereof.
- (b) Check Dam: \$100.00 per check dam.
- (c) Sediment Basin: \$100.00 per basin.
- (d) Sediment Trap: \$100.00 per trap.
- (e) Inlet Protection Devices: \$100.00 per unit.
- (f) Failure to inspect site per 327 IAC requirements: \$100.00 per required inspection.
- (g) Failure to temporarily stabilize non-vegetated areas: \$100.00 per acre or portion thereof.
- (h) Failure to correct identified deficiencies not defined above: \$100 per day per measure.

390

Silt fence will be considered unsatisfactory if the fence material has an exposed cut or tear exceeding 1 ft in length, a seam has separated or the retained sediment exceeds 1/2 of the height of the fence.

Check dams, sediment basins and sediment traps will be considered unsatisfactory if they no longer perform their function, or the retained sediment exceeds 1/2 of the effective height.

400

Inlet protection devices will be considered unsatisfactory if they no longer perform their function, or the accumulated sediment exceeds 1/2 of the height of the device.

205.09 Removal

Temporary erosion and sediment control measures shall remain in place until directed to be removed. The Contractor shall remove and dispose of all excess silt accumulations, dress the area, and vegetate all bare areas in accordance with the contract requirements. Use or disposal of temporary erosion and sediment control measures shall be as directed.

410 **205.10 Method of Measurement**

Silt fence and check dams, traversable will be measured by the linear foot. Check dams, traversable will be measured once per dam parallel to the dam and at the widest point. Sediment basins will be measured by the unit installed complete in place. Revetment riprap check dams, sediment traps, and splashpads will be measured by the ton. Temporary filter stone will be measured by the ton. Temporary mulch will be measured by the ton. Temporary mulch stabilization will be measured by the square yard. Temporary seeding will be measured by the pound. Fertilizer will be measured in accordance with 621.13. Temporary geotextile will be measured by the square yard, and only once for the maximum square yardage in place at one time, 420 regardless of the number of times the material is moved. Removal of sediment will be measured by the cubic yard. Revetment riprap will be measured in accordance with 616.12. Slope drains will be measured in accordance with 715.13. Inlet protection will be measured per each unit installed. Filter berm will be measured by the linear foot complete in place. Filter sock will be measured by the linear foot, complete in place. Diversion interceptor type C will be measured by the linear foot. Concrete washouts will not be measured separately. No. 2 stone for stable construction entrances will be measured by the ton in accordance with 109.01(b).

430 Diversion interceptors type A and B, and the off-site locations designated in 205.03 will not be measured for payment.

Excavation for detention and retention ponds will be measured as common excavation in accordance with 203.27. Retention pond liners will not be measured for payment.

205.11 Basis of Payment

The accepted quantities of silt fence will be paid for at the contract unit price per linear foot, complete in place. Temporary mulch will be paid for by the ton. Temporary seeding will be paid for at the contract unit price per pound. Fertilizer 440 will be paid for in accordance with 621.14. Temporary geotextile will be paid for by the square yard. Sediment basins will be paid for at the contract unit price per each unit installed. Temporary check dams, revetment riprap; temporary filter stone; sediment traps; and splashpads will be paid for by the ton. Temporary check dams, traversable will be paid for by the linear foot. Revetment riprap will be paid for in accordance with 616.13. Slope drains will be paid for in accordance with 715.14. Removal of sediment will be paid for at the contract unit price per cubic yard. Inlet protection will be paid for at the contract unit price per each unit installed. Filter berm will be paid for at the contract unit price per linear foot complete in place. Filter sock will be paid for at the contract unit price per linear foot, complete in 450 place. Diversion interceptors, type C will be paid for at the contract unit price per linear foot.

The accepted quantities of excavation for detention or retention ponds will be paid for as common excavation in accordance with 203.28. Retention pond liners will be paid for as a lump sum.

Payment will be made under:

	Pay Item	Pay Unit Symbol
460	Diversion Interceptor Type C	LFT
	Filter Sock	LFT
	Liner for Retention Pond	LS
	Manufactured Surface Protection Product, _____ type	SYS
	No. 2 Stone	TON
	Sediment, Remove	CYS
	Splashpad	TON
	Temporary Check Dam, Revetment Riprap	TON
470	Temporary Check Dam, Traversable	LFT
	Temporary Filter Berm	LFT
	Temporary Filter Stone	TON
	Temporary Geotextile	SYS
	Temporary Inlet Protection	EACH
	Temporary Mulch	TON
	Temporary Mulch Stabilization, _____ type	SYS
	Temporary Sediment Basin	EACH
	Temporary Sediment Trap	TON
480	Temporary Seed Mixture	LBS
	Temporary Silt Fence	LFT
	Temporary Slope Drain	LFT

The costs of geotextile, trenching, backfilling, posts, fencing, and all necessary incidentals shall be included in the cost of temporary silt fence.

The costs for diversion interceptor types A and B shall be included in the cost of other pay items in this section.

490 The costs of stakes, trenching, backfilling, posts, and all necessary incidentals shall be included in the cost of temporary check dams, traversable.

The cost of interceptor ditches shall be included in the cost of other pay items in this section.

The cost of slope drain shall include the standard metal end section, anchors, and all incidentals necessary to perform the work.

500 The cost of materials, installation, inspection, maintenance, and removal of temporary erosion and sediment control measures at off-site locations designated in 205.03 will not be measured for payment.

Except for the removal of sediments, the cost of materials, installation, maintenance, and removal of temporary erosion and sediment control items shall be included in the costs of the respective pay items.

510 The cost of constructing, maintaining, and removal of the construction entrance, other than those constructed by the Contractor for borrow and waste sites, shall be included in the cost of No. 2 stone. No direct payment will be made for construction entrances for borrow and waste sites.

Costs associated with concrete washout will be included in the costs of the concrete pay items.

Costs associated with filter stone replacement due to maintenance and sediment removal shall be included in the cost of sediment removal.

SECTION 206 – STRUCTURE EXCAVATION

206.01 Description

This work shall consist of the excavation and backfill or disposal of all materials required for the construction of foundations for substructures of bridges, culverts, and retaining walls; and for the furnishing and subsequent removal of all necessary materials and equipment for and the construction of cribs, cofferdams, caissons, and similar items, together with their dewatering. The work shall be in accordance with 105.03.

10

All excavation for structures below the designed slope or subgrade line as shown on the plans shall be included under this item.

Unless otherwise specified, structure excavation shall include all pumping, bailing, draining, sheeting, bracing, and incidentals required for proper execution of the work.

206.02 Class X Excavation

20

(a) General Excavation

If one or more of the following materials is encountered within the limits of foundation excavating, such shall be defined as class X excavation.

1. solid rock, hard ledge rock, slate, hard shale, or conglomerate, any of which is actually removed by blasting or use of pneumatic or equivalent tools and which could not reasonably be removed by any other method;
2. loose stones or boulders more than 1/2 cu yd in volume;

30

3. concrete, masonry, or other similar materials which are parts of an old structure not shown on the plans;
4. timber grillages, old foundation piling, buried logs, stumps, or similar materials which extend beyond the limits of excavation so that they must be cut off. Such obstructions shall be removed back to cofferdam limits and the portions so removed within cofferdam limits will be considered as class X.

40 Material commonly known as hardpan will not be considered as class X. If material is encountered during excavation which seems to be in accordance with that defined herein as class X, notification shall be made in writing, and ample time shall be allowed to make necessary investigations and measurements to determine the class and volume of the material in question.

(b) Excavation for Foundation of Traffic Support Structures

50 If class X material as defined in 206.02(a) is encountered within the limits of foundation excavation for traffic support structures, overhead sign structure foundations, strain pole, or high mast lighting foundations, the foundation shall be located as directed.

If class X material in accordance with 206.02(a)1 is encountered, the material shall be excavated to allow the foundation to be embedded a distance that is equal to 1/2 of the remaining depth of the foundation before the material was encountered, except for overhead sign structures, strain poles, and high mast lighting foundations.

Overhead sign structure foundations, strain poles, and high mast lighting foundations shall be excavated to allow the foundation to be embedded as shown on the plans or as directed.

60

If class X material in accordance with 206.02(a)2, 206.02(a)3, or 206.02(a)4 is encountered, the material shall be removed to the total depth of the foundation as shown on the plans.

206.03 Wet Excavation

70 Wet excavation shall be defined as that portion of foundation excavation, except class X, which is below a horizontal plane designated on the plans as the upper limit of wet excavation and above the bottom of the footing as shown on the plans. If wet excavation is a pay quantity and the elevation of the upper limit of wet excavation is not shown on the plans, an elevation of 1 ft above the elevation of low water level as shown on the plans shall be used as such limit.

206.04 Dry Excavation

Dry excavation shall be defined as that portion of foundation excavation, except class X, which is above the upper limit of wet excavation.

206.05 Foundation Excavation, Unclassified

If the Schedule of Pay Items provides a pay quantity of foundation excavation, unclassified, and none for wet excavation or dry excavation, then foundation excavation, unclassified shall include all work described as wet excavation and dry excavation, regardless of whether or not water is encountered, but shall not include class X. Even though designated herein as foundation excavation, unclassified, it shall be regarded in these specifications as a class of excavation.

If no upper limit of foundation excavation, unclassified is shown on the plans, it shall be at the original ground except where waterway excavation, common excavation, or other classified excavation overlaps the area of foundation excavation and is a pay item. The upper limit of foundation excavation, unclassified shall be the lower limit of the overlapping classified material.

CONSTRUCTION REQUIREMENTS

206.06 General Requirements

The drainage requirements of 203.14 shall apply to excavation for structures and, in addition, adequate outlets shall be provided as shown on the plans or as directed, if within the limits of the excavation.

All excavation shall be adequately shored to avoid damage to the structure, its approaches, adjacent roadway, embankments, tracks, buildings, or other property.

Footing excavation shall, in general, conform with the outlines of footings as shown on the plans, or as revised, and shall be of sufficient size to enable construction of the footings to their full required dimensions. If an existing structure is being extended, the old footings shall be adequately protected. Boulders, logs, or other unforeseen obstacles encountered shall be removed.

The elevations of bottoms of footings as shown on the plans shall be considered approximate. The final elevations shall depend on conditions encountered during excavation, at which time other elevations may be ordered in writing if necessary to secure satisfactory foundations.

Where existing foundation material would not support the contemplated load safely, the plans may require, or it may be directed that foundation piles be driven in the footing area. This piling shall be furnished, driven, and paid for in accordance with 701.

206.07 Disposal of Excavated Material

Except as otherwise herein provided, material excavated for a structure or its approaches, including any material excavated beyond the pay limits of foundation excavation or its specified or approved extensions, shall, if suitable, be used for filling around the new structure, for spandrel filling, approach embankment, regular embankment, or for any combination of these, all as specified or directed.

If excavated material is in accordance with 211.02 and if material of this nature is required at the structure or in its approaches, then this material shall be used as special fill and placed in accordance with applicable provisions of 211.

130 Surplus or unsuitable material shall not be disposed of in any manner that would obstruct or pollute the stream or otherwise impair the efficiency or appearance of the structure. If there are piers in the water, permission may be granted to waste excavated material adjacent to these piers provided such waste does not obstruct the waterway. If usable excavated material is wasted without authority, the quantity so wasted will be deducted from the quantities of common excavation, borrow, or B borrow, depending on the nature of the waste and its use.

Disposal of surplus or unsuitable material, including class X excavation, outside the right-of-way shall be in accordance with 201.03 and 203.08.

206.08 Preparation of Foundation Surfaces

140 Excavation for foundations on rock without piles shall extend a minimum of 2 ft into solid rock. All rock or other hard material, if to be left in place as a foundation surface, shall be freed of loose material, cleaned, and cut to a firm surface. The final surface shall be level, stepped, or serrated as directed. Seams shall be cleaned and filled with concrete, cement mortar, or grout. These conditions shall prevail when the foundation masonry is placed.

150 Where the masonry is to rest on a foundation surface other than those described above, the approximate bottom of the excavation shall not be disturbed. The final removal of material to the required grade shall be done carefully just prior to placing the foundation masonry. The final surface shall be left smooth and, unless otherwise designated, be level.

Notification shall be given after final excavation of each foundation is completed. No masonry shall be placed until the depth of the excavation and the character of the foundation material have been approved.

160 Before foundations that do not require piling are poured, sufficient test borings shall be made to determine the character of the underlying material for a depth of at least 5 ft below the bottom of the footing. Also, before pilings are driven in foundations requiring piling, sufficient soundings shall be made to determine the character of the underlying material for a depth of 10 ft below the bottom of the footing.

Rock at the bottom of spread footings shall be proof tested. Exploratory holes of 2 in. diameter shall be drilled into the foundation base. Holes shall be drilled into sound rock to a depth of 5 ft or as directed. Three holes shall be drilled into each foundation base. Observations shall be made at each hole as follows:

- 170
1. speed of drilling
 2. drill pressure
 3. dropping or clogging of drill bit
 4. loss of drill water, if used
 5. probing of the sides of the holes with a right angled chisel point. The chisel shall be formed from a rod of 3/8 or 1/2 in. diameter
- 180
6. continuity of bearing material.

A professional engineer shall supervise the proof testing work. A report for each hole shall be prepared and submitted for review and approval.

206.09 Cofferdams and Temporary Construction Dikes

Working drawings shall be submitted in accordance with 105.02. They shall show the proposed method of cofferdam construction and other details left open to choice or not fully shown on the plans.

- 190
- Working drawings for dikes to be used in lieu of cofferdams or to be used for access to the work shall be submitted in accordance with 105.02, if such dikes are to be constructed within the waterway. Approval of such drawings will only be given if the probability of stream pollution and stream flow restriction is minimal.

- 200
- Cofferdams shall be constructed for all abutments and piers where water or unstable soil is encountered or where the soil may become unstable; excessive stream pollution or stream flow restriction might occur with other construction procedures; or if necessary to support the sides of excavated areas, embankment, adjacent buildings, tracks, or other premises. In general, they shall be carried down well below bottoms of footings, shall be well braced, and as nearly watertight as practicable. The interior dimensions shall be sufficient to provide ample clearance to enable pile driving, the construction of forms, and clearance for pumping equipment outside the forms. Cofferdams shall be constructed to protect plastic concrete against damage from a sudden rising of the stream and to prevent damage to the foundation by erosion.

No timber or bracing that would extend into substructure masonry shall be left in cofferdams except with written permission.

- 210
- Cofferdams which become tilted or moved laterally during the process of sinking shall be righted or enlarged to provide ample clearance. Any necessary correction shall be made with no additional payment.

206.10

Except as otherwise provided herein, cofferdams shall be dewatered and sediment controlled in accordance with 108.04. Pumping will not be allowed for 24 h after concrete placement, unless otherwise approved.

220 When conditions are encountered under which it is established that no reasonable pumping will dewater the cofferdam when every practicable effort has been made to reduce the inflow of water, or other conditions are such that a foundation seal is necessary, the construction of a concrete foundation seal may be required of such dimensions as necessary. This seal shall be constructed in accordance with 702.20(f).

Unless otherwise specified, all cofferdam bracing shall be removed and all sheeting removed or cut off at least 2 ft below the finished ground line, except within the low-water channel it may either be removed or cut off even with the stream bed. Removal shall be such that the finished masonry will not be marred or disturbed.

230 **206.10 Method of Measurement**

Structure excavation, except wet excavation, will be measured in cubic yards in its original position below the limits of roadway excavation. Wet excavation will be the theoretical quantity in accordance with 206.11(b). When structures are to be placed in embankment sections, the natural ground line, as cross sectioned, will be the uppermost level of computation unless otherwise specified or shown on the plans.

240 Class X material encountered and removed during the excavation of foundations for traffic support structures will be measured to the foundation neat lines as shown on the plans below the surface of class X material.

If the pay unit for any item of excavation in the Schedule of Pay Items is lump sum, no measurement will be made.

Extended excavation for footings will be measured to include the entire depth needed for the deeper footing and the entire width needed to comply with OSHA or IOSHA requirements.

250 Additional excavation required for a culvert when the culvert is placed at an elevation that is a least 1 ft below the elevation shown on the plans shall be measured to include the entire width needed to comply with OSHA or IOSHA requirements.

206.11 Basis of Payment

The accepted quantities of structure excavation will be paid for at the contract unit price per cubic yard or lump sum.

Unless otherwise provided, excavation for bridges will be paid for at the contract unit price or prices per cubic yard for the respective class or classes involved.

260

If cofferdams are specified as a pay item, they will be paid for at the contract lump sum price for cofferdams.

If a foundation seal is constructed, it will be paid for in accordance with 702.28.

270

The quantity of class X excavation to be paid for will be the cubic yards of such material actually removed from within vertical planes defining the neat lines of the footings, except where material classified as class X excavation overlays other material which shall be excavated to cofferdam limits. Such overlying strata will be paid for to the limits of the material excavated beneath it. Unless otherwise provided, no additional payment will be made for such excavation made outside these limits.

If class X excavation is encountered at locations other than sign foundations, traffic signal foundations, and highway illumination foundations, and there is no contract unit price for class X excavation, payment will be made at a unit price per cubic yard as follows:

280

1. \$1,000.00 per cu yd if the quantity of class X excavation is less than or equal to 1 cubic yard per foundation.
2. When the quantity of class X excavation is greater than 1 cubic yard per foundation, payment will be made at the lesser of four times the contract unit price for wet excavation or 10 times the contract unit price for dry excavation.

If class X excavation is encountered at locations for sign foundations, traffic signal foundations, and highway illumination foundations and there is no contract unit price for class X excavation, payment will be made as follows:

290

1. \$500.00 if the quantity of class X excavation is less than or equal to 1 cubic yard per foundation.
2. \$500.00 per cu yd for all quantities over 1 cubic yard.

300

In addition to the payment for class X excavation at sign foundations, traffic signal foundations, and highway illumination foundations when there is no contract unit price for class X excavation, a mobilization and demobilization payment for class X excavation will be paid in the amount of \$1,500.00 per occurrence. Multiple mobilization and demobilization payments will be paid if all project foundation locations are not made available in a reasonable time frame while the equipment is on the project. The cost of this work will be included in a change order developed in accordance with 109.05 and paid as class X excavation and a mobilization and demobilization for class X excavation.

If class X excavation is encountered in foundation excavation unclassified and there is no pay item shown in the Schedule of Pay Items, payment will be made at eight times the contract unit price per cubic yard for foundation excavation unclassified.

310 Except as otherwise provided, the quantity of dry excavation to be paid for will be the amount of such excavation actually removed from its original position within vertical planes which are 18 in. outside the neat lines of the footings and parallel thereto. Regardless of the quantity actually removed, the quantity of wet excavation to be paid for will be the theoretical volume bounded by the bottom of the footings, the upper limit of wet excavation, and vertical planes which are 18 in. outside the neat lines of footings and parallel thereto. Additional payment will not be made for such excavation outside these limits.

320 Where it is necessary to carry a footing or a portion of a footing deeper than its elevation shown on the plans, such additional excavation, except a portion thereof classified as class X which is carried down to a plane which is 4 ft below the bottom of footing as shown on the plans, will be paid for as extended dry excavation, extended wet excavation, or extended foundation excavation unclassified, at a price to be determined by multiplying the contract unit price for dry excavation, wet excavation, or foundation excavation, unclassified, respectively by the factors shown below.

1. For footings or portions thereof lowered not more than 1 ft, the factor will be 2.0.
- 330 2. For footings or portions thereof lowered more than 1 ft and not more than 2 ft, the factor will be 2.5.
3. For footings or portions thereof lowered more than 2 ft and not more than 3 ft, the factor will be 3.5.
4. For footings or portions thereof lowered more than 3 ft and not more than 4 ft, the factor will be 5.0.

340 For a footing lowered more than 4 ft below its elevation shown on the plans, all such extended excavation below the bottom of footing elevation shown on the plans to the revised bottom of footing shall be done as extra work in accordance with 104.03. Payment will be made in accordance with 109.05.

All backfill material or sub-footing material required whose source is other than structure excavation will be paid for at the contract unit price for the material being used or as extra work if no unit price has been established. A change order will be prepared in accordance with 109.05.

350 The cost of furnishing all materials and labor associated with proof testing of rock shall be included in the cost of other pay items.

If a borrow area is required and borrow is not specified as a pay item, payment will be made in accordance with 203.28.

If a waste area is required and the contract documents do not identify excess excavation or require removal of any items, payment will be made in accordance with 203.28.

360 Except for sign foundations, traffic signal foundations, and highway illumination foundations, if a type of excavation for which no pay item exists is required and the new type of excavation requires the Contractor to use equipment not otherwise being used on the contract, payment will be in accordance with 203.28.

If a type of excavation for which no pay item exists is required and the new type of excavation requires additional traffic control not shown on the plans or results in traffic control being required for an additional period of time, payment will be made in accordance with 203.28.

370 Payment will be made under:

Pay Item	Pay Unit Symbol
Cofferdam.....	LS
Excavation, Dry.....	CYS
Excavation, Foundation, Unclassified.....	CYS
Excavation, Wet.....	CYS
Excavation, X.....	CYS

380 The cost of placing and compacting of all backfill when the materials used are obtained from excavation, clearing and grubbing required and not paid for under another pay item, formation of embankments made with material from structure excavation, and disposal of all surplus or unsuitable excavation, unless otherwise specified shall be included in the cost of the pay items.

The cost for disposing of surplus or unsuitable excavated materials outside the right-of-way shall be included in the various pay items in this section.

(a) Culverts

390 This requirement will not include pipe culverts. Except as otherwise provided herein, excavation for culverts will not be paid for directly. The cost thereof shall be included in the cost of the class of concrete used therein. The cost of all necessary removal and satisfactory disposal of all or part of the existing old structure unless its removal is otherwise provided for, cleaning out an old channel or constructing a new channel within the right-of-way limits and widening it to the grade of the existing or

proposed new stream bed as shown on the plans or as directed, construction of all necessary curbs and cofferdams and their subsequent removal, subsoil borings or soundings below bottom of footings, dewatering, disposal of excavated materials, and all labor, equipment, tools, and necessary incidentals shall be included in the cost of this work.

400

If a culvert is lowered, relocated, or material of such nature is encountered that additional excavation is necessary over and above that required at the originally planned location, the additional excavation will not be paid for if it is 10 cu yd or less. Additional excavation in excess of 10 cu yd will be paid for at three times the contract unit price for the class of excavation involved. However, if the culvert is placed at a depth that is equal to or greater than 1 ft deeper than the elevation shown on the plans, the additional excavation in excess of 10 cu yd will be paid at five times the contract unit price for the class of excavation involved.

410

(b) Bridges

The cost of clearing right-of-way within the project limits; constructing, dewatering, and removal of cofferdams, if not a pay item; subsoil borings or soundings below bottoms of footings; final preparation of foundation surfaces; disposal of excavated material; and all labor, equipment, tools, and incidentals necessary to the satisfactory completion of the excavation shall be included in the cost of this work.

The cost of all required working drawings; furnishing, hauling, and placing necessary materials; construction; maintenance; dewatering; removal of bracing; removal of or cutting off the sheeting; and labor, equipment, tools, and necessary incidentals shall be included in the cost of cofferdams.

420

If cofferdams are not specified as a pay item, and if cofferdams are necessary, their cost shall be included in the cost of excavation or the concrete requiring their use.

If there is no pay item for dry excavation, the cost of this part of the work shall be included in the cost of the foundation concrete or for other concrete requiring such excavation. However, where waterway excavation, common excavation, or other classified excavation overlaps the area of dry foundation excavation, no deduction will be made in the pay volume of such overlapping classified material. This exception will apply only if dry excavation is not a pay item.

430

Except as otherwise provided in 206.05, the cost of foundation excavation unclassified shall include all work and elements of volume, and excavation described above for wet excavation and dry excavation, regardless of whether or not water is encountered. The cost of foundation excavation unclassified shall not include the cost of class X excavation.

440

The classifications for necessary excavation for a cantilevered wing outside the limits of foundation excavation shall be the same as those governing the excavation inside such limits. The quantity to be paid for will be that actually removed from its original position within vertical planes 18 in. outside the neat lines shown on the plans and parallel thereto and above a plane 1 ft below and parallel to the bottom surface of the wing.

450 The classifications for necessary excavation for arch superstructures outside the limits of foundation excavation or waterway excavation shall be those governing the excavation inside the limits of foundation excavation or waterway excavation, depending on the location of the excavation for the arch superstructure. Such excavation shall be bounded by vertical planes which are 1 ft outside the outside faces of the arch ring and parallel thereto, by a vertical plane passing through the intersection of the intrados of the arch ring and the original ground line and parallel to the face of the abutment, and the vertical plane bounding the foundation excavation on the side adjacent to the arch ring. The lower limit shall be a sloping plane which is 1 ft below a plane connecting the intersection of the intrados of the arch ring and the original ground, and the intersection of the intrados of the arch ring with the vertical plane bounding the foundation excavation.

460

For U-abutments, the limits of dry excavation to be paid for will be extended to include all material removed from between the limits of the wing excavation and above the elevation of the bottom of the lowest tie beam. If the bottom of the lowest tie beam is below the upper limits of wet excavation, the limits of wet excavation and dry excavation to be paid for will be extended to include material actually and necessarily removed from between the limits of the wing excavation.

470 Where it is necessary to excavate outside the foundation excavation limits for superstructure or extensions other than those described above, the pay limits will be extended to include all such excavation, as determined necessary.

If a suitable sump is constructed outside the pay limits as described above, such limits will be extended to include the actual lines of the sump. The additional pay limits added for the sump will not exceed 4% of the area of the footing involved.

(c) Traffic Structure Supports

The cost of excavation for traffic structure supports, except for class X material in accordance with 206.02(a)1, shall be included in the cost of the foundation material.

SECTION 207 – SUBGRADE

207.01 Description

This work shall consist of the construction of the subgrade in accordance with 105.03.

MATERIALS

207.02 Materials

10 Materials shall be in accordance with the following.

Chemical Modifiers	
Fly Ash	901.02
Lime.....	913.04(b)
Portland Cement, Type I.....	901.01(b)
Coarse Aggregate, Class D or Higher, Size No. 11, 12, 53, or 73.....	904
Geogrid, Type IB.....	918.05(a)
Water	913.01

20 Recycled concrete pavement meeting the requirements of coarse aggregate size No. 53 may be used when crushed stone size No. 53 is specified.

CONSTRUCTION REQUIREMENTS

207.03 General Requirements

The subgrade shall be constructed uniformly transversely across the width of the pavement including shoulders or curbs unless shown otherwise on the plans, by one of the following methods:

- 30
- (a) chemical modification in accordance with 215;
 - (b) aggregate No. 53 in accordance with 301;
 - (c) geogrid in accordance with 214 placed under aggregate No. 53 in accordance with 301, or
 - (d) soil compaction to 100% of maximum dry density.

40 Longitudinally, the treatment may vary depending on the method of construction.

Soils containing greater than 3% by dry weight organic material, or with a maximum dry density of less than 100 pcf, or with liquid limit of greater than 50, or with a soluble sulfate content greater than 1,000 ppm, will not be allowed within the specified thickness of the subgrade treatment in cut sections and will not be allowed

50 within 24 in. of the finished subgrade elevation in fill sections. Density will be determined in accordance with AASHTO T 99 or ITM 512 and loss on ignition will be determined in accordance with AASHTO T 267. Liquid limits will be determined in accordance with AASHTO T 89. Sulfate content will be determined in accordance with ITM 510.

Coal within the specified thickness of the subgrade shall be excavated if directed, and disposed of in accordance with 202.05. Coal or coal blossoms that are allowed to remain shall be mixed thoroughly with subgrade soils and compacted in accordance with 207.04.

60 All rock greater than 6 in. shall be removed or broken off at least 6 in. below the specified subgrade surface. Holes or depressions resulting from the removal of unsuitable material shall be filled with an acceptable material and compacted to conform with the surrounding subgrade.

During subgrade preparation, adequate drainage shall be provided at all times to prevent water from standing on the subgrade.

70 Even though the subgrade has been previously accepted, the condition of the subgrade shall be in accordance with 105.03 and 207.04 at the time paving material is placed. Just prior to placing the base course on the subgrade, proofrolling in accordance with 203.26 shall be completed. Undue distortion of the subgrade shall be avoided. If limits of the work make mechanical preparation of the subgrade impractical, appropriate hand methods may be used.

The grade and cross section of the subgrade shall be finished within a tolerance of 1/2 in. from the true subgrade. Finishing within this tolerance by blading or other mechanical means without the use of side forms will be allowed. If these methods do not finish within this tolerance, side forms shall be used.

207.04 Subgrade Treatments

80 The subgrade treatment type shall be as specified on the contract plans. If required, the subgrade foundation shall be corrected as directed by the Engineer prior to subgrade treatment.

Type I	24 in. of soil compacted to density and moisture requirements.
Type IA	[blank]
Type IB	14 in. chemical soil modification.
Type IC	12 in. of the subgrade excavated and replaced with coarse aggregate No. 53.

90

207.04

- Type II 6 in. of the subgrade excavated and replaced with coarse aggregate No. 53.
- Type IIA 8 in. chemical soil modification.
- Type III 6 in. of soil compacted to the density and moisture requirements.
- 100 Type IV 12 in. of the subgrade excavated and replaced with coarse aggregate No. 53 on type IB geogrid.
- Type V 3 in. of subgrade excavated and replaced with 3 in. coarse aggregate No. 53.

In areas where shallow utilities are encountered or chemical modification is not allowed, the Contractor may submit a request to the Engineer to substitute Type IC for Type IB.

110 Where the density and moisture control option is used, compaction of embankment areas shall be in accordance with 203.23. In cut and transition areas, the top lifts shall be removed, and the bottom 6 in. compacted in-place to comply with the specified density and moisture requirements. The excavated material shall then be replaced and compacted in 6 in. lifts to comply with the specified density and moisture requirements. Removal of the lifts may be waived and only the upper 6 in. treated in accordance with 207.03 when it is determined, through testing in accordance with 203.24, that the lower lifts comply with the specified density and moisture requirements.

120 In sections where shale or shale and rock mixtures are encountered, these materials shall be undercut 12 in. below the subgrade elevation and replaced with coarse aggregate No. 53 or No. 73 and compacted in accordance with 301.06. All irregularities and holes shall be graded to provide positive drainage. Where necessary, finishing to subgrade elevation shall be accomplished using No. 11 or No. 12 crushed stone.

130 The existing railroad ballast and railroad bed material shall be excavated to the depth specified for subgrade treatment, Type V and graded as shown on the plans, or as directed by the Engineer, in order to provide the subgrade width required for the proposed pavement section, including side slopes. Excavation and grading of the ballast and bed material shall include any cuts and fills necessary to account for erosion or degradation of the ballast in localized areas. Cuts and fills shall be balanced within sections approximately 300 ft in length along the profile of the pavement. The graded ballast and bed material shall be compacted in accordance with the applicable provisions of 203 prior to placement of the coarse aggregate No. 53. The 3 in. compacted aggregate as part of the subgrade treatment Type V shall be compacted to 100% prior to the placement of the pavement.

140 When conditions are encountered below the specified subgrade treatment depth that prevent achieving the specified subgrade compaction, such conditions shall be corrected as directed.

207.05 Method of Measurement

Subgrade treatment will be measured in both cut and fill areas by the square yard per type. Chemicals for modification, excavation, aggregates, and geogrid materials will not be measured.

150 The undercutting of rock, where encountered, will be measured in accordance with 203.27(b).

207.06 Basis of Payment

The accepted quantities of subgrade treatment will be paid for at the contract unit price per square yard per type, complete in place. In areas where shallow utilities are encountered or the Contractor elects to use Type IC for Type IB, payment will be made at the price of Type IB.

The undercutting of rock, where encountered, will be measured in accordance with 203.27.

160 Payment will be made under:

Pay Item	Pay Unit Symbol
Subgrade Treatment, Type _____	SYS

The cost of subgrade treatments including testing, sampling, aggregates for cut or at-grade areas, chemicals for modification, geogrid, water, and the excavation required for the methods chosen by the Contractor shall be included in the cost of the pay item for subgrade treatment, type.

170 The cost of excavation and grading of existing railroad ballast and railroad bed material shall be included in the cost of subgrade treatment, Type V.

Where conditions exist below the specified subgrade compaction depth that prevent achieving the specified compaction, payment for correcting such conditions will be made based on the directed method of treatment.

SECTION 208 – FINISHING SHOULDERS, DITCHES, AND SLOPES

208.01 Description

This work shall consist of the final shaping and dressing of shoulders, ditches, and slopes by hand or machine methods, or both, to the required smoothness in accordance with these specifications and in reasonably close conformance with the elevations and cross sections shown on the plans or as directed.

- 10 Where divided pavement is constructed, each roadway with its shoulders, ditches, and slopes will be considered a separate roadway.

CONSTRUCTION REQUIREMENTS

208.02 Finishing Shoulders

- 20 Unless otherwise provided, shoulders shall be constructed of earth or other approved material which contains no sod, weeds, sticks, roots, or other perishable matter. The inside edges shall be built up slightly above the finished surface of the adjoining pavement and compacted thoroughly with a roller weighing no less than 5 t and with the roller wheel slightly overlapping the pavement. Rolling shall continue until there is no break between the pavement and shoulders, and until the required cross section is obtained.

If rolling is not practicable on shoulders for approach pavement or other miscellaneous areas, compaction shall be obtained with mechanical tamps, vibrators, or other satisfactory means.

Except where permission has been granted to widen shoulders to dispose of surplus excavation, the outside edges shall be parallel to the pavement edges.

- 30 Where cuts are widened beyond the typical cross sections shown on the plans in order to obtain additional material for constructing shoulder widths required or where fills are widened to dispose of excess excavated material, the shoulders shall be finished to the widths as finally constructed.

It may be necessary to finish shoulders after the pavement is opened to traffic. As a matter of safety to traffic, the pavement shall be kept as free as possible from shoulder material and equipment. The adjacent pavement over which traffic is being routed shall be cleaned at the close of each work day.

- 40 **208.03 Finishing Ditches**

Ditches shall be finished to the lines and grades shown on the plans or as otherwise laid out. The edges shall be parallel to the pavement unless it is necessary to have the gradients different from that of the pavement in order to obtain proper drainage, in which case the edges shall be as determined.

208.04 Finishing Slopes

50 All cut and fill slopes shall be constructed to the cross sections shown on the plans or to revised sections where cuts are widened to obtain additional material or fills widened to utilize excess. Cut and fill slopes shall be finished to the degree ordinarily obtained by a blade grader, scraper, or hand shovel.

208.05 Blank**208.06 Finishing at Contract Drainage Structures**

If the contract work is for bridges or culverts or for extensions thereof, the requirements of this specification shall apply to the right-of-way within the contract structure limits, unless otherwise specified.

208.07 Method of Measurement

60 Finishing will not be measured for payment unless otherwise provided.

208.08 Basis of Payment

Finishing shoulders, ditches, and slopes will not be paid for directly. The cost thereof shall be included in the cost of other pay items.

SECTION 209 – FINISHING EARTH GRADED ROADS**209.01 Description**

This work shall consist of leveling, shaping, and otherwise completing an earth graded road ready for acceptance when the contract is for grading or for grading and structures, but not when the contract includes paving or surfacing.

209.02 Construction Requirements

10 After all grading is substantially complete and structures, if any, are finished, the roadbed and cut and fill slopes shall be shaped properly and, where necessary, compacted.

Shaping and compacting shall be with approved equipment supplemented with hand methods if necessary. Reasonably smooth surfaces shall be obtained and finished at least to within ± 0.1 ft of the required profile and cross sections shown on the plans or as directed.

20 All rock greater than 6 in. encountered shall be removed or broken off at least 6 in. below the subgrade surface. Holes or depressions resulting from the removal of unsuitable material shall be filled with an acceptable material and compacted to conform with the surrounding subgrade.

Final trimming and cleaning shall be in accordance with 210.

209.03

209.03 Method of Measurement

Finishing earth graded roads will not be measured for payment unless otherwise provided.

209.04 Basis of Payment

30 Finishing earth graded roads will not be paid for directly. The cost thereof shall be included in the cost of other pay items.

SECTION 210 – FINAL TRIMMING AND CLEANING

210.01 Description

This work shall consist of trimming and cleaning the otherwise completed highway between right-of-way lines for its entire contract length.

210.02 Construction Requirements

10 At the time of acceptance, the following conditions shall prevail for the entire contract length and also for the full right-of-way width except as hereinafter provided.

Debris and rubbish shall be removed and disposed of in accordance with 201.03.

Remaining loose stones and broken masonry meeting the aggregate requirements for hand laid or grouted riprap shall be stored in neat piles on the right-of-way as directed.

Weeds, brush, and stumps shall be cut close to the ground. Disposal shall be in accordance with 201.03 and 203.08.

20 Cut and fill slopes made or disturbed shall be left reasonably smooth and uniform. Loose and overhanging rock shall be removed.

Floors, roadways, railings, bottom chords, shoes, and seats of bridges shall be cleaned of rubbish, sand, stone, gravel, and dirt. Waterways shall be left unobstructed. Culverts and other drainage structures shall be left clean for their entire length.

30 If the contract is for construction of a new pavement or for grading and structures only on a right-of-way acquired for divided highway construction, one roadway of which has been constructed and on which the Department has assumed normal maintenance, the provisions of this specification shall not apply to the maintained portion except to those areas of such which are disturbed by the operations.

If the contract is for construction of a portion of a divided highway on a right-of-way on which no previous construction has been done or on a divided highway right-of-way on which a previous grading-only contract has been completed, then the

40 provisions of this specification shall apply to the entire right-of-way for the full contract length.

Unless otherwise set out in the special provisions for a contract which includes work for patching, widening, resurfacing, surface treating, undersealing, or for a combination of these, or for a contract through which traffic is being maintained during construction, these requirements will apply only to that portion of the right-of-way disturbed by the operations.

210.03 Method of Measurement

50 Final trimming and cleaning will not be measured for payment unless otherwise provided.

210.04 Basis of Payment

Final trimming and cleaning will not be paid for directly. The cost thereof shall be included in the cost of other pay items.

SECTION 211 – B BORROW AND STRUCTURE BACKFILL

211.01 Description

This work shall consist of backfilling excavated or displaced peat deposits; filling up to designated elevations of spaces excavated for structures and not occupied by permanent work; constructing bridge approach embankment; and filling over structures and over arches between spandrel walls, all with special material.

MATERIALS

10

211.02 Materials

Materials shall be in accordance with the following:

B Borrow	As Defined*
Flowable Backfill	213
Geotextile	918.02
Structure Backfill	904

20 * The material used for special filling shall be of acceptable quality, free from large or frozen lumps, wood, or other extraneous matter and shall be known as B borrow. It shall consist of suitable sand, gravel, crushed stone, ACBF, GBF, or other approved material. The material shall contain no more than 10% passing the No. 200 (75 µm) sieve and shall be otherwise suitably graded. The use of an essentially one-size material will not be allowed unless approved.

Aggregate for end bent backfill shall be No. 8 or No. 9 crushed stone or ACBF, class D or higher.

30 The Contractor has the option of either providing B borrow or structure backfill from an established CAPP source, or supplying the material from another source.

211.03

The Contractor has the following options for supplying B borrow or structure backfill from a local site:

- (a) the establishment of a CAPP Producer Yard at the local site in accordance with 917; or
- (b) use a CAPP Certified Aggregate Technician or a consultant on the Department's list of approved Geotechnical Consultants For Gradation Control Testing.

40

For material excavated within the project limits, gradation control testing will be performed by the Department if the Contractor is directed to use the material as B borrow or as structure backfill.

The frequency of gradation control testing shall be one test per 2,000 t based on production samples into a stockpile or by over the scales measurement, with a minimum of two tests per contract, one in the beginning and one near the mid-point. The sampling and testing of these materials shall be in accordance with applicable requirements of 904 for fine and coarse aggregates. The Contractor shall advise the

50

Engineer in writing of the plan to measure the material.

CONSTRUCTION REQUIREMENTS

211.03 General Requirements

If B borrow or structure backfill is obtained from borrow areas, the items of obtaining the areas, their locations, depths, drainage, and final finish shall be in accordance with 203.

60 Unless otherwise specified, if excavated material complies with 211.02 and if B borrow or structure backfill is required for special filling, the excavated material shall be used as such. If there is a surplus of this material, such surplus shall be used in embankment. The provisions of 203.19 shall apply to placing this material at structures. All surplus in excess of the directed or specified use on the right-of-way shall be disposed of in accordance with 201.03.

If fill or backfill as described in this specification is within embankment limits, and if it is not required that the entire fill or backfill be of B borrow and placed as such, then that portion above the free-water level shall be placed in accordance with applicable provisions of 203 and compacted to the required density.

70

If borrow is required outside the specified limits of B borrow, material in accordance with the specifications for B borrow may be furnished at the contract unit price for borrow; however, the quantity of borrow measured for payment outside the limits of structure backfill will not exceed the theoretical quantity of B borrow furnished.

Unless otherwise specified, all spaces excavated for and not occupied by bridge abutments and piers, if within embankment limits, shall be backfilled to the original ground line with B borrow, and placed in accordance with 211.04.

80

Where B borrow or structure backfill is required as backfill at culverts, retaining walls, sewers, manholes, catch basins, and other miscellaneous structures, it shall be compacted in accordance with 211.04.

Where specified, aggregate for end bent backfill shall be placed behind end bents and compacted in accordance with 211.04. Prior to placing the aggregate, a geotextile shall be installed in accordance with 616.11.

211.03.1 Structure Backfill Types

90

The structure backfill type shall be as specified.

Within each of the following structure backfill types, the Contractor shall choose from the listed options for each type:

(a) Type 1

1. Structure backfill in accordance with 904.05.
2. Non-removable or removable flowable backfill in accordance with 213.

100

(b) Type 2

1. Crushed stone aggregate or ACBF structure backfill in accordance with 904.05, except No. 30, No. 4, and 2 in. nominal size aggregate shall not be used.
2. Non-removable or removable flowable backfill in accordance with 213.

110

(c) Type 3

Structure backfill in accordance with 904.05, except only nominal size aggregates 1 in., 1/2 in., No. 4 or No. 30, and coarse aggregate No. 5, No. 8, No. 9, No. 11, or No. 12 shall be stone. ACBF meeting the size requirements for coarse aggregate No. 5 or No. 8 may also be used.

A type A certification in accordance with 916 for the additional structure-backfill testing described below shall be furnished to the Engineer prior to use. An approved geotechnical laboratory shall be used to perform the tests.

120

Structure backfill for all retaining walls shall be in accordance with the following criteria:

PROPERTY	CRITERIA	TEST METHOD
pH	5 < pH < 10	AASHTO T 289
Organic Content	1% max.	AASHTO T 267
Permeability, min.	30 ft/day	AASHTO T 215

The gradation shall be run on the material used in the permeability test. Testing for permeability shall be performed on the sample of the material compacted to 95% in accordance with AASHTO T 99, Method C or D. All of the tests listed above shall be run a minimum of once every 12 months per source. The Office of Materials Management will evaluate the material from each source and determine the appropriate tests to be performed.

In addition to the criteria above, structure backfill for retaining wall systems containing metal components in contact with structure backfill shall also be in accordance with the following criteria:

PROPERTY	CRITERIA	TEST METHOD
Chlorides	< 100 ppm	AASHTO T 291
Sulfates	< 200 ppm	AASHTO T 290
Resistivity, min.	3,000 Ω -cm	AASHTO T 288
Internal friction angle, ϕ , min.	34°	AASHTO T 236* or T 297*

* under consolidated drained conditions

If the minimum resistivity exceeds 5,000 Ω -cm, the requirement for the testing of chlorides and sulfates will be waived. The resistivity shall be tested at 100% saturation. All of the tests listed above shall be run a minimum of once every 12 months per source. The Office of Materials Management will evaluate the material from each source and determine the appropriate tests to be performed.

Testing for ϕ shall be performed using a sample of the material compacted to 95% in accordance with AASHTO T 99, Method C or D. Testing for ϕ will not be required when using coarse aggregate No. 5, No. 8, or No. 9.

(d) Type 4

Removable flowable backfill in accordance with 213.

(e) Type 5

Non-removable flowable backfill in accordance with 213.

211.04 Compaction

B borrow and structure backfill types 1, 2, and 3 shall be compacted with mechanical tamps or vibrators in accordance with the applicable provisions of 203.23 except as otherwise set out herein.

160 Aggregate for end bent backfill and coarse aggregate used for structure backfill shall be deposited in layers not to exceed 12 in. loose measurement. Each layer shall be mechanically compacted with a compactor having a plate width of 17 in. or larger that delivers 3,000 to 9,000 lb per blow. Each lift shall be compacted with two passes of the compactor.

211.05 Embankment for Bridges

170 When special filling is required, the embankment for bridges shall be constructed using B borrow within the specified limits shown on the plans. All embankment construction details specifically set out in this specification for embankment for bridges shall be considered in accordance with the applicable requirements of 203.

180 At the time B borrow is being placed for approach embankment, a well compacted watertight dam shall be constructed in level lifts, the details of which are shown on the plans. Except as hereinafter specified for material to be used in constructing the enclosing dam, and for growing vegetation, and unless otherwise provided, the material for constructing bridge approach embankment shall be B borrow compacted by mechanical methods. If approach embankment or shoulders are constructed of material not suitable for growing seed or sod, and if one or both of these is required, then such areas shall, unless otherwise specified, be covered with a layer of clay, loam, or other approved material. This layer shall be approximately 1 ft thick after being compacted into place.

211.06 B Borrow Around Bents

190 When specified, B borrow shall be placed around all bents falling within the limits of the approach grade as shown on the plans. Before placing, the surface of the ground on which it is to be placed shall be scarified or plowed as directed. The embankment slope shall be 2:1 on the sides and beneath the structure, and shall be 6:1 from the end of the bridge down to the average ground line, or it may be required to complete the approaches back to the existing grade. An enclosing dam and provisions for growing vegetation shall be constructed in accordance with 211.05.

211.07 Blank

211.08 Spandrel Filling

Unless otherwise specified, spandrel fills for arch structures shall be composed of B borrow. The fill shall be carried up symmetrically in lifts from haunch to crown and simultaneously over all piers, abutments, and arch rings. Compaction shall be in accordance with 211.04.

200 211.09 Method of Measurement

B borrow, structure backfill types 1, 2, or 3, and aggregate for end bent backfill will be measured by the cubic yard as computed from the neat line limits shown on the plans. If cubic yards are set out as the pay item for B borrow or structure backfill in the Schedule of Pay Items and if neat line limits are not specified for measurement

211.10

of volume for the material, measurement will be made by the cubic yard at the loading point in truck beds which have been measured, stenciled, and approved. The B borrow may be weighed and converted to cubic yards by assuming the weight per cubic foot to be 90% of the maximum wet density in accordance with AASHTO T 99. The material may be cross sectioned in its original position and again after excavation is complete, and the volume computed by the average end area method. If B borrow is used for backfill in areas where unsuitable material is present or peat excavation has been performed, unless otherwise directed, the B borrow will be cross sectioned, and the volume will be computed by the average end area method.

Structure backfill types 4 or 5 will be measured by the cubic yard as computed from the neat line limits shown on the plans. If neat line limits are not shown on the plans, the volume in cubic yards of flowable backfill furnished and placed as structure backfill type 4 or 5 will be computed from the nominal volume of each batch and a count of the batches. Unused and wasted flowable backfill will be estimated and deducted.

If the material is to be paid for by the ton, it shall be weighed in accordance with 109.01(b).

If the material comes from a wet source such as below water or a washing plant, and weighing is involved in the method of measurement, there shall be a 12 h drainage period prior to the weighing.

Geotextile will be measured in accordance with 616.12.

211.10 Basis of Payment

The accepted quantities of B borrow will be paid for at the contract unit price per cubic yard or per ton as specified, complete in place.

Structure backfill will be paid for at the contract unit price per cubic yard of the type specified, provided the material comes from outside the permanent right-of-way.

B borrow material placed outside the neat lines will be paid for as borrow when such B borrow eliminates required borrow material. Otherwise, no payment will be made for backfill material placed outside the neat lines.

Aggregate for end bent backfill will be paid for at the contract unit price per cubic yard, based on the neat line limits shown on the plans.

Geotextile will be paid for in accordance with 616.13.

If topsoil, loam, or other suitable material in accordance with 211.05 is used for expediting the growth of seed or sod, it will be paid for at the contract unit price per cubic yard for borrow, unless otherwise provided.

Payment will be made under the following:

Pay Item	Pay Unit Symbol
Aggregate For End Bent Backfill	CYS
B Borrow	CYS
	TON
Structure Backfill, Type _____	CYS

260

No payment will be made under this section for material obtained within the excavation limits of the project if the Contractor is directed to use the material as B borrow or structure backfill in a pipe trench, culvert, construction of an embankment or fill, or if the Contractor uses the material for its own convenience. Material obtained from within the excavation limits of the project and which the Contractor is directed to use as B borrow or structure backfill for other purposes including replacement of undercut areas, support for a retaining wall system, and end bent fill will be paid for at the contract unit price of \$5.00 per cubic yard for B borrow/structure backfill handling.

270

The cost of disposal of excavated material shall be included in the cost of the pay items in this section.

SECTION 212 – STOCKPILED SELECTED MATERIALS

212.01 Description

This work shall consist of excavating selected road material from within the construction limits and stockpiling it on the right-of-way at designated locations. It also includes any subsequent removal of the material from the stockpile, if to be used in the work.

212.02 Materials

10 Any material to be excavated and stockpiled will be specifically named and described in the special provisions and may include rock, top soil, material in accordance with 211.02, or any other material selected, any of which may be excavated as common excavation.

After the selected material is stockpiled it shall be known as stockpiled selected material and if any of this material is required to be removed from the stockpile and used in the work, its removal and its incorporation into the work shall be known as salvaged stockpiled selected material.

20 212.03 Construction Requirements

Selected material shall be excavated from specified areas and stockpiled on the right-of-way at designated locations. The depth of excavation shall be as directed.

212.04

If the material is required to be taken from the stockpile and utilized in the work, the material so utilized shall be placed in accordance with these specifications as they apply to the nature of the material and the use to which it is put.

212.04 Method of Measurement

30 Stockpiled selected material will be measured in the stockpiles by means of cross sections by the cubic yard, computed by the average end area method. The volume measured as salvaged stockpiled selected material will be the difference in cubic yards between that of the existing stockpile and that remaining after the material has been removed from the stockpile and used. Both stockpiles will be measured by means of cross sections. The volume will be computed by the average end area method.

If stockpiled selected material is obtained from within the excavation pay limits of new construction, the volume of the material will be deducted from the pay quantities for excavation as shown on the original cross sections.

40

212.05 Basis of Payment

The accepted quantities of stockpiled selected material and salvaged stockpiled selected material will be paid for at the contract unit price per cubic yard, complete in place.

Payment will be made under:

	Pay Item	Pay Unit Symbol
50	Stockpiled Selected Material	CYS
	Stockpiled Selected Material, Salvaged	CYS

The cost of excavation, hauling, removing material from the stockpile, placing materials, and necessary incidentals shall be included in the cost of the pay items.

SECTION 213 – FLOWABLE BACKFILL

213.01 Description

This work shall consist of placing flowable backfill in trenches for pipe structures, culverts, utility cuts, other work extending under pavement locations, cavities beneath sloped walls and other locations in accordance with 105.03.

Flowable backfill will be classified as either removable or non-removable.

10

MATERIALS

213.02 Materials

Materials shall be in accordance with the following:

Concrete Admixtures*	912.03
Fine Aggregate	904.02(a)
Fly Ash	901.02
Portland Cement	901.01(b)
Water	913.01

- 20 * Other admixtures that increase flowability may be used as approved by the Engineer.

The supplier may elect to use nominal size No. 23 and No. 24 gradations in accordance with 904.02(h) or may propose the use of alternate gradations. The alternate gradation and proposed tolerances of material passing each sieve shall be included in the flowable backfill mix design.

213.03 Flowable Backfill Mix Design

- 30 The Contractor shall submit a flowable backfill mix design, FBMD, to the DTE a minimum of seven days prior to the trial batch. The FBMD will be accepted in accordance with 213.04. The FBMD shall be submitted in a format acceptable to the DTE and shall include the following:

- (a) a list of all ingredients
- (b) the source of all materials
- (c) the gradation of the aggregates
- (d) the batch weight (mass) with the aggregates at the SSD condition
- (e) the names of all admixtures
- (f) the admixture dosage rates and manufacturer's recommended range.

40

A FBMD in accordance with these specifications, which has been approved for use on a previous contract, may be submitted to the DTE for approval. The submittal shall include copies of test results in accordance with 213.04 and 213.05.

Changes in the FBMD will not be allowed except for adjustments to compensate for routine moisture fluctuations or a change in sand source in accordance with 213.05 based on the dry flow determined from the trial batch testing. All other changes will require a new FBMD.

50 213.04 Flowable Backfill Mix Criteria

The FBMD shall produce a workable mixture with the following properties:

(a) Flow Consistency

Flow consistency will be measured in accordance with ASTM D 6103. The diameter of the spread shall be at least 8 in.

(b) Lightweight Dynamic Cone Penetration Blow Count Number

- 60 A lightweight dynamic cone penetration test will be performed in accordance with ITM 216 after the flowable backfill mix has cured for three days. The average penetration resistance blow count number for removable flowable backfill shall not

213.05

be less than 12 or greater than 30. Non-removable flowable backfill mixes shall have an average penetration resistance blow count greater than 30.

(c) Removability Modulus

The removability modulus, RM, will be determined for the FBMD by the formula as follows:

$$RM = 0.000104 (U_w)^{1.5} \sqrt{1.72N_{14} - 15.64}$$

70 where:

N_{14} = average lightweight dynamic cone penetration blow count after 14 days in accordance with ITM 216.

U_w = dry unit weight, lb/cu ft, of flowable backfill after 14 days in accordance with ITM 218.

The RM shall be 1.0 or less for removable flowable backfill.

80 After all test results have been reviewed for compliance with the specifications, a mixture number will be assigned by the DTE.

213.05 Flowable Backfill Trial Batch

A trial batch shall be produced by the Contractor and will be tested by the Department to verify that the FBMD meets the flowable backfill mix criteria. The Department will verify the classification of the mix as either removable or non-removable from the results of the trial batch. The flowable backfill shall be batched within the proportioning tolerances of 508.02(b). The Department will determine the test results and provide them to the Contractor. The trial batch shall be
90 of sufficient quantity to allow the Department to perform all required tests from the same batch.

The Department will obtain a sample of the fine aggregate and fly ash described in the FBMD. The Department will test the dry flow in accordance with ITM 217 and record the results on the FBMD.

If the Contractor requests to change the source of the fine aggregate identified in an approved FBMD the Contractor shall submit a revised FBMD to the DTE. The Department will obtain a sample of the new fine aggregate and, if applicable, a
100 sample of the fly ash as identified in the approved FBMD. Dry flow will be tested in accordance with ITM 217. If the test result is within ± 2.0 s of the value shown on the approved FBMD, the revised FBMD will be approved and a new trial batch will not be required. Failure to meet the dry flow test requirement will require the Contractor to submit a new FBMD and perform a new trial batch for approval of the proposed new fine aggregate.

213.06 Mixing Equipment

The mixing equipment shall be in accordance with the applicable requirements of 702 or 722.

110

CONSTRUCTION REQUIREMENTS**213.07 Placement**

The flowable backfill shall not be placed on frozen ground. Flowable backfill shall be protected from freezing for 72 hr. Flowable backfill shall not be placed into or through standing water unless approved by the Engineer in writing.

The diameter of the flowable backfill spread shall be at least 8 in. at time of placement. Water may be adjusted from the FBMD to meet the minimum spread requirement if the initial measured spread is between 7 and 8 in.

120

If using mixing equipment in accordance with 722, the yield will be checked using the 1/4 cu yd box method as follows:

- (a) The chute shall be cleaned and the box shall be positioned on a level surface to receive the discharged flowable backfill.
- (b) The mixer shall be operated until the cement or fly ash counter indicates that 1/4 cu yd of flowable backfill has been yielded.
- (c) The contents of the box will be consolidated and struck off. If the box is not full, the gates shall be adjusted and the procedure shall be repeated until the actual and calculated volumes of flowable backfill agree.
- (d) Yield will be checked on the first load of each truck and every third load per truck thereafter. Additional yield tests will be required after making any adjustments.

130

The flowable backfill shall be brought up uniformly to the fill line as shown on the plans or as directed. When used as structure backfill, flowable backfill shall be placed uniformly so as not to induce unbalanced loading on any part of a structure.

140

The flowable backfill shall not be subjected to load or disturbed by construction activities until a lightweight dynamic cone penetration test has produced a minimum blow count. The minimum blow count shall be as follows:

Construction Activities with Vibratory Compaction after Backfill12
Construction Activities without Vibratory Compaction after Backfill7

150

213.08 Method of Measurement

Flowable backfill will be measured by the cubic yard of the type specified as computed from the neat line limits shown on the plans. If neat line limits are not

213.09

shown on the plans, the volume in cubic yards of flowable backfill furnished and placed will be computed from the nominal volume of each batch and a count of the batches. Unused and wasted flowable backfill will be estimated and deducted. Drilled holes will be measured by the number of holes drilled.

213.09 Basis of Payment

160 The accepted quantities of flowable backfill will be paid for at the contract unit price per cubic yard for the type specified, furnished and placed. Holes drilled in the pavement will be paid for at the contract unit price per each.

Payment will be made under:

Pay Item	Pay Unit Symbol
Drilled Hole for Flowable Backfill.....	EACH
Flowable Backfill, Non-Removable	CYS
Flowable Backfill, Removable	CYS

170

SECTION 214 – GEOGRID

214.01 Description

This work shall consist of furnishing and installing geogrid as shown on the plans or as directed by the Engineer and in accordance with 105.03.

MATERIALS

214.02 Materials

10 Materials shall be in accordance with 918.05.

CONSTRUCTION REQUIREMENTS

214.03 Foundation Preparation

20 The embankment foundation shall be cleared and grubbed in accordance with 201 and excavated using lightweight equipment to minimize disturbance of the embankment foundation surface soils. Construction activities using equipment which cause pumping and rutting of the embankment foundation soils shall be prevented where possible and shall otherwise be minimized. Fine grading may be waived where impractical. However, when very soft soil is encountered, the embankment foundation shall be cleared of all trash and rubbish materials without disturbing the vegetation cover or root mat. The embankment foundation shall be subject to approval prior to placement of geogrid. Proofrolling of the embankment foundation will not be required when geogrid is used in construction of embankment foundation treatment.

214.04 Geogrid Placement

30 The geogrid shall be installed in accordance with the Engineer's designs or the manufacturer's recommendations. The geogrid shall be kept taut during placement of the initial lift of backfill. Installation shall require the use of stakes, staples, sandbags, pile of granular fill, or other approved means to hold the geogrid in place during fill placement operations. Type IA geogrid shall be used for embankment foundation treatment. Type IB geogrid shall be used for subgrade treatment, type IV. When placing type IA geogrid, any rutting in the granular material shall not exceed 3 in. The Engineer may increase the lift thickness to obtain stability of the granular material.

40 If required by the Engineer, the geogrid material supplier shall provide a qualified manufacturer's representative on the contract site at the start of the work to assist the Contractor. The representative shall also be available during the construction when required by the Engineer or the Contractor.

When type IB geogrid is used, proofrolling shall be performed prior to placing the type IB geogrid. The first 6 in. of coarse aggregate No. 53 shall be spread and compacted with a 10 t roller in static mode. The spreading and compaction of the aggregate shall be performed so that adequate interlocking of the aggregate and geogrid is obtained. The second 6 in. of coarse aggregate No. 53 shall be constructed in accordance with 301.

50 The geogrid shall be overlapped a minimum of 2 ft side to side and end to end for type IB. The type IA geogrids shall be overlapped 3 ft in areas where foundation conditions cannot support foot traffic or where 2 ft is found to be inadequate during fill placement. Overlaps shall be oriented in the direction of fill placement, or shingled, to prevent advancing fill from lifting any geogrid roll edges. Overlaps shall be further secured to prevent separation during fill placement. Damaged geogrid shall be patched. Patching shall include placement of a minimum of 3 ft of overlapped geogrid beyond the damaged area. If the damaged portion extends for more than 50% of the roll in the width direction, the entire width shall be replaced.

60 Geogrid shall be covered with fill within three calendar days after placement. Only that amount of geogrid required for pending work shall be placed to minimize exposure of the geogrid.

214.05 Fill Placement

Construction vehicles shall not be on the geogrid. The placement of the fill shall proceed forward along the roadway centerline and outward to the embankment edges and compacted in accordance with 203.23. The Engineer may waive density requirements for the first lift of embankment foundation treatment if the fill is determined to be too weak to support compaction equipment.

70

density shall be determined in accordance with AASHTO T 99, the loss on ignition shall be determined in accordance with AASHTO T 267, the calcium/magnesium carbonate shall be determined in accordance with ITM 507, and the sulfate content shall be determined in accordance with ITM 510.

CONSTRUCTION REQUIREMENTS

30 **215.03 Testing and Mix Design**

The Contractor shall be responsible for all tests required to determine the chemical modifier type and optimum chemical modifier content for modification of the soils. The modifier selection, laboratory testing, and mix design shall be performed by an approved geotechnical consultant in accordance with the Department's Design Procedures for Soil Modification or Stabilization.

40 The quantities for hydrated lime, quicklime, or portland cement shall be based on 4.0% of the maximum dry density of the soils. The quantities for lime by-products shall be based on 5.0% of the maximum dry density of the soils. The quantities for fly ash class C shall be based on 12.0% of the maximum dry density of the soils. Class F fly ash shall not be used except in combination with lime or cement.

50 If hydrated lime, quick lime, lime by-products or portland cement are used, test results and the geotechnical consultant recommendations shall be submitted to the Engineer prior to use. If fly ash or any combination of chemical modifiers are used, the test results and the geotechnical consultant recommendations shall be submitted to the Engineer and to the Office of Geotechnical Services for approval at least five business days prior to use. If the modifier as bid is not appropriate for the soils encountered, portland cement shall be used. Portland cement, fly ash, lime, and lime by-products shall be from the Department's list of approved sources.

The quantity of chemical modifier may be adjusted for different soil types. However, the source or type of chemical modifier shall not be changed during the progress of the work without approval. A change in source or type shall require a new mix design.

60 **215.04 Storage and Handling**

The chemical modifier shall be stored and handled in accordance with the manufacturer's recommendations.

60 **215.05 Weather Limitations**

The chemical soil modification shall be performed when the soil has a minimum temperature of 45°F, measured 4 in. below the surface, and with the air temperature rising. The chemical modifier shall not be mixed with frozen soils or with soil containing frost. Chemical soil modification shall only be performed in areas which are going to be paved during the same construction season.

215.06

215.06 Preparation of Soils

70 The soils shall be prepared in accordance with 207.03. All aggregates which are larger than approximately 3 in. encountered before or after mixing the soils and chemical modifiers shall be removed.

215.07 Spreading of Chemical Modifiers

Where type A-6 or A-7 soils are used or encountered, the surface shall be scarified to the specified depth prior to distribution of the chemical modifier. If a combination of modifiers is used, the modifiers shall be mixed mechanically prior to being incorporated. The chemical modifier shall be distributed uniformly by a cyclone, screw-type, or pressure manifold type distributor. If a slurry is used, the surface shall be scarified prior to the distribution of the slurry. The chemical modifier shall not be applied when wind conditions create problems in adjacent areas or create a hazard to traffic on any adjacent roadway. The spreading of the chemical modifier shall be limited to an amount which can be incorporated into the soil within the same work day. If weather causes stoppage of work or exposes the chemical modifier to washing or blowing, additional chemical modifier may be spread when the work resumes.

80

215.08 Mixing

The chemical modifier, soil, and water when necessary, shall be thoroughly mixed by rotary speed mixers or a disc harrow. The mixing shall continue until a homogenous layer of the required thickness has been obtained. One hundred percent of the material, exclusive of rock particles, shall pass a 1 in. (25 mm) sieve and at least 60% shall pass a No. 4 (4.75 mm) sieve. The mixing depth shall be 14 in.

90

215.09 Compaction

Compaction of the mixture shall begin as soon as practicable after mixing and shall be in accordance with 203 or 207.03 as applicable. Compaction after mixing shall be as follows:

- 100
- (a) For portland cement modified soils, mixing shall be completed within 1 h of portland cement placement and grading and final compaction shall be completed within 3 h after mixing.
 - (b) Fly ash modified soils shall be compacted within 4 h.
 - (c) Lime modified soils shall be compacted within 24 h.

Acceptance of chemically modified soils will be determined by measuring the compaction with a Dynamic Cone Penetrometer, DCP, in accordance with ITM 509. Testing of the chemically modified soils will begin 24 hours after compaction.

110

Three random test locations will be determined in accordance with ITM 802 for each 1,500 lft of chemically modified soil for each 2-lane pavement section. The average of the blow counts obtained at the three random locations will be the DCP blow count representing the 1,500 lft section. Blow counts of 15 and above will be

120 used to determine the average for the top 6 in. of a 14 in. lift. Blow counts of 14 and above will be used to determine the average for the bottom 8 in. of a 14 in. lift. Blow counts of 18 and above will be used to determine the average for the 8 in. lift. Locations with test results less than the specified minimum blow counts will be retested and shall be reworked if the minimum blow count is not obtained.

The chemically modified soil lift shall meet the following requirements for compaction:

- 130
- (a) The average DCP blow count shall not be less than 17 for the top 6 in. of a 14 in. lift.
 - (b) The average DCP blow count shall not be less than 16 for the bottom 8 in. of a 14 in. lift.
 - (c) The average DCP blow count shall not be less than 20 for an 8 in. lift.

Moisture tests for chemically modified soils mixture will be performed every 4 h during chemical and soils mixing. One gradation test in accordance with 215.08 will be performed for each 2,500 lft of chemically modified soil for each 2-lane pavement section.

140 Construction traffic or equipment will not be allowed on the treated soils until the soil meets the DCP test requirements.

215.10 Curing

The moisture content of the mixture shall be at the optimum moisture content or above the optimum moisture content as determined by the mix design in accordance with 215.03. Moisture content will be determined in accordance with ITM 506. Moisture content shall be maintained above the optimum moisture content for the first 48 h after mixing with quicklime or hydrated lime.

215.11 Method of Measurement

150 The accepted quantity of chemically modified soils will be measured by the square yard, complete in place. All removal and replacement required to modify the soils below the specified depth will be measured in accordance with 203.27(b).

215.12 Basis of Payment

The accepted quantity of chemically modified soils will be paid for by the square yard, complete in place. All removal and replacement required to modify the soils below the specified depth will be paid for in accordance with 203.28.

160 Adjustment of materials for chemical modification that exceeds the limits of 215.03 will be included in a change order for materials only and paid for as chemical modifier adjustments. If mix design test results show that the chemical modifier as bid by the Contractor is not appropriate and the strength of the modified soil can not

216.01

be achieved, a price adjustment will be made for the use of portland cement. The price adjustment will be calculated at a cost equal to the difference in the invoice cost of the chemical modifier found to be appropriate for use and the invoice or quoted delivered cost of the chemical modifier as bid by the Contractor. This adjustment will be included in a change order and will be paid for as chemical modifier adjustments. Payment for chemical modifier adjustments will be made for direct delivered material costs incurred by the Contractor and shall not include any other markups.

170

Payment will be made under:

Pay Item	Pay Unit Symbol
Chemical Modification, Soils	SYS

180

The cost of performing the laboratory tests, providing an approved geotechnical consultant, scarification of the subgrade, spreading and mixing of the chemical modifier and soil, compaction of the resultant mixture, shaping the subgrade, work required due to adjustments of modifier proportioning, additional modification required due to weather conditions, correction of deficient areas, water required for the modification process, modified subgrade trimming, and all operations needed to meet the requirements of this specification shall be included in the cost of the pay items of this section.

SECTION 216 – CELLULAR CONCRETE FILL, CCF

216.01 Description

This work shall consist of furnishing and placing a lightweight, low absorbability cellular concrete fill in accordance with 105.03.

MATERIALS

216.02 Materials

10

Materials shall be in accordance with the following:

Cement	901.01(b)
Fly Ash	901.02
Water	913.01

An admixture in accordance with 912.03 may be used as recommended by the CCF manufacturer.

20

A foam liquid concentrate in accordance with ASTM C 796 shall be used to produce the CCF properties in accordance with 216.04. The foam liquid concentrate shall be chosen from those shown on the Department’s list of approved CCF Manufacturers/Installers.

CONSTRUCTION REQUIREMENTS

216.03 Mix Design

A mix design prepared in accordance with the geotechnical report shall be submitted to the Engineer for approval at least five work days before the CCF operations begin. A cellular concrete manufacturer shall be chosen from those shown on the Department's list of approved CCF Manufacturers/Installers.

216.04 Properties and Tests

The CCF shall be in accordance with the manufacturer's recommendations and the minimum physical properties as follows:

PROPERTIES	CLASS II	CLASS III	CLASS IV
Cast Density Mix	810 lb/cu yd	972 lb/cu yd	1,134 lb/cu yd
Minimum Compressive Strength, ASTM C 495*	40 psi	80 psi	120 psi
Freeze-thaw Resistance minimum at relative E = 70%, ASTM C 666, modified		80 cycles	300 cycles
Water Absorption, max.**	20%	16%	14%
Shear Modulus, G, ASTM D 4015	25,000 psi	34,000 psi	
Young Modulus, E, ASTM D 4015	67,000 psi	102,000 psi	
* Specimens shall not be oven dried for the compressive strength test. ** Percentage after 120 days. Long term total immersion as a percent of cast density in accordance with ASTM C 796.			

(a) CCF Cast Density

The density shall be monitored at the point of placement at hourly intervals during placement. Adjustments shall be made as necessary to maintain the specified cast density, $\pm 10\%$. If two consecutive test results are failing, operations shall cease and corrective action taken before placement of the CCF resumes.

(b) Foam Density

Foam density shall be tested twice during each 24 h period for each mixer. The foam density shall be within 10% of the target provided in the approved mix design.

216.05 Storage and Handling

Protection of the material during and after placement shall be in accordance with the manufacturer's recommendations.

216.06 Weather Limitations

CCF shall be placed when the ambient temperature is 32°F or above. CCF shall not be placed on frozen subsoil. The installation procedure shall not begin if a

216.07

temperature of less than 32°F is expected within a 10 h period from the completion of the CCF placement, unless recommended by the manufacturer.

216.07 Preparation of Subgrade

The subgrade shall be prepared in accordance with 207. All standing water shall be removed prior to placement of CCF.

60

216.08 Installation

CCF shall be proportioned, mixed, and placed in lifts as recommended by the manufacturer. Transit mixers will not be acceptable for mixing the CCF. The CCF shall not be subjected to load or disturbed by construction activities until a minimum compressive strength of 25 psi has been achieved.

The final surface finish shall be within ± 0.1 ft of the plan elevation.

216.09 Lots

70 Lots will be defined as 300 cu yd of CCF placed. A partial lot equal to or less than 60 cu yd shall be included in the previous lot. A partial lot greater than 60 cu yd but less than 300 cu yd will be considered a full lot.

216.10 Testing

80 Acceptance of the work will be based on successful test results for compressive strength. The Contractor shall cast four specimens for each lot. Testing of the specimens will be in accordance with ASTM C 495, except test specimens shall be covered immediately after casting. The specimens shall be moist cured for 26 days and then air cured for two days prior to the compressive strength testing. The specimens shall not be oven dried. Test specimens will become the property of the Department after curing and will be tested at 28 days.

216.11 Method of Measurement

CCF will be measured by the cubic yard for each class as computed from the neat lines shown on the plans.

216.12 Basis of Payment

CCF will be paid for at the contract unit price per cubic yard of the class specified.

90

Payment will be made under:

Pay Item	Pay Unit Symbol
Cellular Concrete Fill, _____ class	CY

Water, curing, molds, equipment, materials, and other incidentals necessary for finishing CCF specimens shall be included in the cost of CCF.

100

No payment will be made for replacement of damaged CCF.

SECTION 217 - SOILS DRYING WITH CHEMICAL MODIFIERS

217.01 Description

This work shall consist of drying soils by uniformly mixing fly ash or lime with soil to aid in achieving the workability of soils having moisture over 2 % above optimum moisture content.

MATERIALS

10

217.02 Materials

Materials shall be in accordance with the following:

Fly ash	901.02
Lime	913.04(b)
Water	913.01

20

Soils containing greater than 6% by dry weight calcium, magnesium carbonate or organic material, or having a maximum dry density of less than 95 pcf, or with soluble sulfate content greater than 1,000 ppm shall not be used. The density shall be determined in accordance with AASHTO T 99, the loss on ignition shall be determined in accordance with AASHTO T 267, calcium carbonate/magnesium carbonate content shall be determined in accordance with ITM 507, and the sulfate content shall be determined in accordance with ITM 510.

CONSTRUCTION REQUIREMENTS

217.03 Testing and Mix Design

30

The Contractor shall be responsible for all tests required to determine the chemical modifier type and the relationship between the soils, chemical modifier, and moisture content. The modifier selection, laboratory testing, and mix design shall be performed by an approved geotechnical consultant in accordance with the Department's Design Procedures for Soil Modification or Stabilization.

Chemical modifier, mix design, test results, and the geotechnical consultant recommendations shall be submitted to the Engineer and to the Office of Geotechnical Services for approval at least five business days prior to use. Fly ash and lime shall be from the Department's list of approved sources.

40

The quantity of chemical modifier may be adjusted for different soil types and moisture content.

217.04 Storage and Handling

The chemical modifier shall be stored and handled in accordance with 215.04.

217.05 Weather Limitations

50 The chemical soil modification shall be performed when the soil has a minimum temperature of 35°F, measured 4 in. below the surface, and with the air temperature rising. The chemical modifier shall not be mixed with frozen soils or with soil containing frost. When the soil temperature is expected to fall below 35°F prior to the next lift being placed, chemically treated soils shall be protected from freezing by placing a minimum of 12 in. thick soil.

217.06 Preparation of Soils

The preparation of the soil shall be in accordance with 215.06. The maximum loose lift shall be no more than 12 in.

217.07 Spreading of Chemical Modifiers

60 The specified quantity of chemical modifier shall be spread on the surface. The chemical modifier shall be distributed uniformly by a cyclone, screw-type, or pressure manifold type distributor. Where type A-7 soils are encountered, the soil shall be scarified prior to spreading the chemical modifier. The chemical modifier shall not be applied when wind conditions create problems in adjacent areas or create a hazard to traffic on any adjacent roadway. The spreading of the chemical modifier shall be limited to an amount which can be incorporated into the soil within the same work day. The chemical modifier spreading rate shall be adjusted to the current soil moisture content. If weather causes stoppage of work or exposes the chemical modifier to washing or blowing, additional chemical modifier may be spread when the work resumes. Any materials wasted or disturbed by the Contractor's actions shall be repaired or replaced at no additional cost.

70

217.08 Mixing

The chemical modifier, soil, and water when necessary, shall be thoroughly mixed by rotary speed mixers. The mixing shall continue until a homogenous layer of the required thickness has been obtained. One hundred percent of the material, exclusive of rock particles, shall pass a 1 in. (25 mm) sieve and at least 60% shall pass a No. 4 (4.75 mm) sieve. The mixing depth shall not exceed 12 inches.

217.09 Compaction

80 The moisture content of the mixture shall be at the optimum moisture content or above the optimum moisture content as determined by the mix design in accordance with 215.03. Moisture content will be determined in accordance with ITM 506. Aeration or drying by further mixing may be done to obtain the required moisture content. Compaction of the mixture shall begin as soon as practical. The Contractor shall perform moisture tests during the day to verify the spread rate application. Compaction shall be in accordance with 203 or 207.03, as applicable.

Acceptance of chemically modified soils will be performed on the finished grade with a Dynamic Cone Penetrometer, DCP, in accordance with ITM 509. The chemically modified soil lift shall meet the following requirements for compaction:

90

(a) A minimum DCP blow count of 20 for 12 in. of in place modification. A minimum DCP blow count of 8 for the top 6 in. is required.

(b) A minimum of one passing DCP test for each 1,000 lft of chemically modified soil for each 2-lane pavement section.

(c) A minimum of one gradation test will be performed every 2,500 lft for each 2-lane pavement section.

100

(d) A minimum of one moisture test will be performed for every 4 h of lime soils mixing.

Construction traffic or equipment will be allowed after the minimum DCP blow count is obtained. Construction traffic or equipment shall be routed in one direction so that the chemically modified soil does not pump or rut.

217.10 Method of Measurement

110

The accepted quantity for drying soils will be measured by the ton of chemical modifier complete in place. Soils required to construct the fill will be measured in accordance with 203.

217.11 Basis of Payment

The accepted quantity of chemically modified soils will be paid for by the ton of chemical modifier used for drying. Soils required to construct the fill will be paid for in accordance with 203.

Payment will be made under:

120

Pay Item	Pay Unit Symbol
Drying Soils for Embankment.....	TON

The cost of performing the laboratory tests, providing an approved geotechnical consultant, scarification of in-situ soil, spreading, pulverization, mixing of the chemical modifier and soil, moisture compaction of the resultant mixture, shaping the grade, work required due to adjustments of modifier proportioning, correction of deficient areas, water required for the modification process, and all operations needed to meet the requirements of this specification shall be included in the cost of the pay item of this section.