

PROFILE WALL POLYVINYL CHLORIDE PIPE HEIGHT OF COVER LIMITS (m)		
DIAMETER (mm)	MINIMUM (m)	MAXIMUM (m)
300	0.61	10.8
375	0.61	10.4
450	0.61	10.4
525	0.61	10.1
600	0.61	9.4
675	0.61	9.1
750	0.61	8.8
900	0.61	8.2

SMOOTH WALL POLYVINYL CHLORIDE PIPE HEIGHT OF COVER LIMITS (m)			
PAY ITEM DIAMETER (mm)	NOMINAL DIAMETER (mm)	MINIMUM (m)	MAXIMUM (m)
300	300	0.61	19.5
375	375	0.61	19.5
450	475	0.61	18.6
525	560	0.61	18.6
600	630	0.61	18.6
675	710	0.61	18.6

**NOTE:**

- The tabulated cover depths shall be measured from the bottom of the concrete or asphalt pavement to the top of the pipe.
- The pay item diameter reflects the minimum required inside diameter.

All dimensions are in mm unless otherwise specified.
INDIANA DEPARTMENT OF TRANSPORTATION

PIPE HEIGHT OF  
COVER LIMITS  
MAY 1999

STANDARD DRAWING NO. 715-PHCL-19

L. URENOVICH  
No. 18095  
STATE OF INDIANA  
PROFESSIONAL ENGINEER

/s/ Anthony L. Urenovich  
DESIGN STANDARDS ENGINEER  
DATE 5-09-99

/s/ Donald W. Lucas  
CHIEF HIGHWAY ENGINEER  
DATE 5-09-99

DESIGN STANDARDS ENGINEER

Source Sheet:
NONE