

**PROFILE WALL POLYVINYL CHLORIDE PIPE  
HEIGHT OF COVER LIMITS (m)**

DIAMETER (mm)	MINIMUM (m)	MAXIMUM (m)
300	0.61	10.8
375	0.61	10.4
450	0.61	10.4
525	0.61	10.1
600	0.61	9.4
675	0.61	9.1
750	0.61	8.8
900	0.61	8.2

**SMOOTH WALL POLYVINYL CHLORIDE PIPE  
HEIGHT OF COVER LIMITS (m)**

PAY ITEM DIAMETER (mm)	NOMINAL DIAMETER (mm)	MINIMUM (m)	MAXIMUM (m)
300	300	0.61	19.5
375	375	0.61	19.5
450	475	0.61	18.6
525	560	0.61	18.6
600	630	0.61	18.6
675	710	0.61	18.6

**NOTE:**

1. The tabulated cover depths shall be measured from the bottom of the concrete or asphalt pavement to the top of the pipe.
2. The pay item diameter reflects the minimum required inside diameter.


All dimensions are in mm unless otherwise specified.

INDIANA DEPARTMENT OF TRANSPORTATION

**PIPE HEIGHT OF  
COVER LIMITS**

MAY 1999

STANDARD DRAWING NO. 715-PHCL-19



/s/ Anthony L. Uremovich 5-03-99  
DESIGN STANDARDS ENGINEER DATE

/s/ Donald W. Lucas 5-03-99  
CHIEF HIGHWAY ENGINEER DATE

Source Sheet: NONE

DESIGN STANDARDS ENGINEER