


**$2\frac{2}{3}$ " x $\frac{1}{2}$ " CORRUGATED STEEL PIPE-ARCH (RIVETED OR LOCK SEAM)
HEIGHT OF COVER LIMITS (ft.)**

Rc (in.)	SPAN (in.)	RISE (in.)	AREA (sft)	THICKNESS (in.)									
				0.064		0.079		0.109		0.138		0.168	
				MIN.	MAX.	MIN.	MAX.	MIN.	MAX.	MIN.	MAX.	MIN.	MAX.
3/3 $\frac{1}{2}$	17	13	1.1	1.5	13.7	1.5	13.7	1.5	13.7				
3/4 $\frac{1}{8}$	21	15	1.6	1.6	13.0	1.6	13.0	1.6	13.0				
3/4 $\frac{1}{4}$	24	18	2.2	1.5	13.5	1.5	13.5	1.5	13.5				
3/5 $\frac{1}{2}$	28	20	2.9	1.6	13.0	1.6	13.0	1.6	13.0				
3/6 $\frac{1}{8}$	35	24	4.5	1.6	13.0	1.6	13.0	1.6	13.0	1.6	13.0		
3 $\frac{1}{2}$ /8 $\frac{1}{4}$	42	29	6.5	1.6	13.0	1.6	13.0	1.6	13.0	1.6	13.0	1.6	13.0
4/9 $\frac{1}{8}$	49	33	8.9			1.6	13.0	1.6	13.0	1.6	13.0	1.6	13.0
5/11	57	38	11.6					1.6	12.8	1.6	12.8	1.6	12.8
6/12 $\frac{3}{8}$	64	43	14.7					1.6	12.8	1.6	12.8	1.6	12.8
7/13 $\frac{3}{4}$	71	47	18.1							1.6	12.9	1.6	12.9
8/15 $\frac{1}{8}$	77	52	21.9									1.6	13.0
9/16 $\frac{1}{2}$	83	57	26.0									1.5	13.2

NOTE:

1. The tabulated cover depths shall be measured from the bottom of the asphalt or concrete pavement to the top of the pipe.
2. Dual entries in the "Corner Radius" column, such as 3/3 $\frac{1}{2}$, represent the following:
 - 3 - minimum corner radius allowed by AASHTO M 36.
 - 3 $\frac{1}{2}$ - corner radius typically available.
3. The tabulated cover heights reflect pipe-arches with typically available corner radii. If a pipe-arch with corner radii other than what is typically available is to be used, a specific design shall be performed to verify structural adequacy.

INDIANA DEPARTMENT OF TRANSPORTATION	
PIPE HEIGHT OF COVER LIMITS	
JANUARY 1998	
STANDARD DRAWING NO. E 715-PHCL-11	
DETAILS PLACED IN THIS FORMAT 11-15-99	
	/s/ Anthony L. Uremovich 11-15-99 <small>DESIGN STANDARDS ENGINEER DATE</small>
/s/ Firooz Zandi <small>DESIGN STANDARDS ENGINEER</small>	/s/ Firooz Zandi 11-15-99 <small>CHIEF HIGHWAY ENGINEER DATE</small> ORIGINALLY APPROVED 1-02-98