

620-R-483 SOUND BARRIER SYSTEMS

(Revised 01-20-11)

The Standard Specifications are revised as follows:

SECTION 620, BEGIN LINE 1, DELETE AND INSERT AS FOLLOWS:

SECTION 620 – ~~BLANK~~ SOUND BARRIER SYSTEMS

620.01 Description

This work shall consist of furnishing materials and placement of a sound barrier system and a coping in accordance with 105.03.

620.02 General Design Requirements

10 *The sound barrier system shall be either wall mounted, bridge mounted or ground mounted, and shall consist of wall attachments or post foundations, vertical support posts, and sound barrier panels. For the purposes of this section, “panel” is defined as the reflective or absorptive component mounted between the posts, piers or columns.*

All appurtenances behind, in front of, under, over, mounted upon, or passing through the wall, including drainage structures, fire hydrant access openings, highway signage, emergency access openings, utilities or other appurtenances shown on the plans, shall be accounted for in the design of the sound barrier system.

20 *If the sound barrier manufacturer needs additional information to complete the design, the Contractor shall be responsible for obtaining such information. The Contractor shall be responsible for field verifying wall locations in areas of all existing traffic poles, utility poles, roadway lighting poles, drainage pipes, underdrain outlets, and bridge expansion joints and all other locations where the sound barrier system may conflict with existing conditions. The wall shall be realigned and designed to box out openings where conflicts occur with existing light poles and traffic control devices. The Contractor shall establish and account for the existing locations of all underdrain outlets, drainage pipes, and bridge expansion joints in the final wall plans. If the Contractor discovers that overhead utilities will be within 6 ft (1.8 m) of the sound barrier, the Contractor shall notify the Engineer in accordance with 104.02 and 105.16.*

30 *The sound barrier wall design shall follow the general dimensions of the wall envelope as shown on the plans. The top of the sound barrier shall be at or above the acoustical profile line shown, unless noted. Changes in elevation shall be accomplished by stepping the sound barrier sections at the vertical support posts. Steps shall not exceed 3 ft (0.9 m) vertically unless otherwise specified in the plans. Barrier heights shall be selected in groups of no fewer than 3 successive panels, except where barriers are to be stepped down for barrier termination. The ends of the sound barrier shall be tapered or stepped down to a height of 8 ft (2.4 m) within the sound barrier end transitions or as shown on the plans. The bottom of ground mounted sound barrier shall be embedded a*
 40 *minimum of 6 in. (150 mm) into the ground. The bottom of wall mounted or bridge mounted sound barrier shall follow within 3 in. (75 mm) a profile 6 in. (150 mm) below the top of the existing concrete barrier railing or wall.*

50 *Caisson footings, vertical support posts, and connections for ground mounted sound barrier shall be designed as specified by the manufacturer, with minimum post spacing of 15 ft (4.5 m). Exceptions will be allowed due to site-specific conditions such as access doors, drainage requirements or utility accommodations. These shall be reviewed and approved through the working drawing process. The foundation design shall use the COM 624P or LPILE Program. The foundation design shall be based on the soil model shown on the plans based on cyclic loading and shall consider the effects of a sloping ground surface. The post deflection shall be limited to $L/100$, measured from the top of the caisson to the top of the wall. The foundation depth shall not be less than 7.5 ft (2.3 m) and shall not exceed the depth of the soil model except where the Contractor elects to drill deeper borings to extend the model. The foundation diameter shall not be less than 18 in. (450 mm) and shall not be less than 6 in. (150 mm) larger than the diagonal dimension of the post being used. The foundation shall be designed by the sound barrier manufacturer. Vertical support posts shall be attached to caisson footings by means of anchor bolts, or embedded wide flange steel posts.*

60 *A sound barrier system shall be selected for the type specified from those which are on the Department's list of approved Sound Barrier Systems. The materials used in the fabrication of the sound barrier system shall be the same as those used for approval of the sound barrier system.*

The structural design of the sound barrier system shall be in accordance with the AASHTO Guide Specifications for Structural Design of Sound Barriers, except as otherwise directed. The sound barrier system shall be designed to withstand wind pressure as shown on the plans, as applied perpendicular to the barrier, in each direction.

70 *The post spacing for sound barriers mounted on any structure or safety barrier shall be limited to a distance that does not overstress the existing structure or safety barrier. The spacing shall also be limited to a distance that allows the sound barrier to conform to the existing horizontal and vertical alignments. The allowable loads on a structure or barrier will be shown on the plans. If no allowable loads are shown, the Contractor shall contact the project designer for this information.*

80 *When sound barriers are to be installed on a bridge structure, design calculations shall be submitted to the Engineer that demonstrate structure loading limits, as shown on the plans, will not be exceeded.*

All materials shall have a minimum predicted maintenance free structural and acoustical lifespan of 20 years. All colorings and coatings shall have a minimum predicted maintenance free lifespan of 10 years.

The types of acoustic sound barrier systems that are accepted are as follows:

90 *Type 1, single sided absorptive, sound barrier systems and their components shall be designed to achieve a sound transmission loss equal to or greater than 20 decibels at all frequencies when tested in accordance with ASTM E 90. Type 1 sound barrier systems shall be designed to have a minimum noise reduction coefficient of 0.70 on the roadway*

side. Type 1 sound barrier systems shall be tested in accordance with ASTM C 423. Material samples for this test shall be provided with the coating applied, so as to determine that the color coating does not inhibit the acoustic performance. The sample shall be mounted in accordance with ASTM E 795, type A.

100 Type 2, double-sided absorptive, sound barrier systems and their components shall be designed to achieve a sound transmission loss equal to or greater than 20 decibels at all frequencies when tested in accordance with ASTM E 90. Type 2 sound barrier systems shall be designed to have a minimum noise reduction coefficient of 0.70 on the roadway and non-roadway sides. Type 2 sound barrier systems shall be tested in accordance with ASTM C 423. To determine that the color coating does not inhibit the acoustic performance, material samples for this test shall be provided with the coating applied. The sample shall be mounted in accordance with ASTM E 795, type A.

Type 3, reflective, sound barrier systems and their components shall be designed to achieve a sound transmission loss equal to or greater than 20 decibels at all frequencies when tested in accordance with ASTM E 90.

110 A type 2 barrier system may be substituted for a type 1 barrier system at the Contractor's discretion. A type 1 or a type 2 barrier system may be substituted, with written approval, for a type 3 barrier system.

All molded finishes shall have a 1 in. (25 mm) minimum relief. All rolled finishes shall have a minimum 3/4 in. (19 mm) relief. Relief is defined by material that is provided in excess of the minimum wall thickness required to meet the Noise Reduction Coefficient required for the absorptive surfaces. Fluted finishes shall be coped at each end to avoid cracking.

120 Corrugations, ribs, or battens on sound barrier panels shall be oriented vertically when erected. The sound barrier shall be designed to prevent entrapment and ponding of water. The sound barrier shall not be designed with openings promoting the perching or nesting of birds, or the collection of dirt, debris, or water. The sound barrier shall not be designed with hand holds or grips promoting scaling or climbing of the system.

Fire hydrant access points shall be designed with additional reinforcement or bracing and protective coating around the opening as necessary to maintain structural integrity.

130 Closure plates shall be provided where new sound barrier is constructed adjacent to existing sound barrier. Where bridge mounted walls cross over expansion joints, expansion closure plates shall be used. The wall manufacturer shall provide expansion closure plates for each expansion joint unless directed otherwise. The minimum thickness of closure plates shall be 3/16 in. (4.5 mm).

The calculations for sound barriers which also retain earth must show that the walls are adequate for earth retention. The earth retention areas shall be shown on the plans. The exposed face of the sound barrier earth retaining panel will match the adjacent panel's color and texture.

140 **(a) Precast Panel Design Criteria**

Base-plated or embedded reinforced precast concrete posts may be substituted for wide flanged steel posts with the approval of the Department. Proposed substitutions for wide flanged steel posts shall be shown on working drawings submitted for approval.

Support posts must match the adjoining wall in color unless directed by the Engineer. Embedded reinforced precast concrete posts must also match the adjoining wall in texture. Sound barrier systems utilizing stacked panels shall have ship-lapped or tongue and groove horizontal joints or other approved design which blocks the passage of light.

150

(b) Masonry Design Criteria

Reinforced masonry vertical support posts shall be faced to match the adjoining wall in color and texture unless directed by the Engineer.

Steel support posts shall match the adjoining wall in color unless directed by the Engineer.

620.03 Submittals

160 *The Contractor shall submit a minimum of 3 alternative textured finishes for the wall to the Engineer. These shall include the following colors:*

- (a) light gray (federal standard 595, color number 36492),*
- (b) light brown (federal standard 595, color number 30450),*
- (c) light tan (federal standard 595, color number 37769).*

The colors will be presented to the public for their input in accordance with 620.05. The final wall pattern and color will be approved before production of the wall panels may begin.

170

The Contractor shall submit design calculations in accordance with 105.02. Calculations for sound barriers on bridge structures shall include an analysis of the bridge structure that demonstrates the additional loads imposed by the sound barrier, including dead load and wind load, will not exceed the structural capacity of the bridge. The Contractor shall submit working drawings in accordance with 105.02 after design calculations are approved and before beginning wall construction operations. Design calculations and working drawings shall meet the following minimum requirements:

180

- (a) Design calculations shall include all structural design calculations and vertical support post design calculations.*
- (b) Design calculations for bridge mounted installations shall include the design unit weight and mass of the sound barrier and support systems.*
- (c) Design calculations for bridge mounted installations shall demonstrate that the structural loading limits of the structure, as shown on the plans, will not be exceeded.*

190

(d) Working drawings shall include all details, dimensions, quantities, and cross sections necessary to construct the sound barrier systems and shall include but not be limited to the following:

200

1. A plan and elevation sheet or sheets for each sound barrier systems location.
2. An elevation view of the sound barrier systems which shall include the elevation at the top of the wall at all horizontal and vertical break points at least every 50 ft (15 m) along the face of the wall.
3. A plan view of the wall that indicates the offsets from the construction centerline to the face of the wall at all changes in horizontal alignment. A plan view and elevation view which detail the placing position.
4. A typical cross section or cross sections showing elevation relationship between ground conditions and the sound barrier systems locations.
5. All general notes required for constructing the wall.
6. Each sheet shall show the complete project identification number.
7. All horizontal and vertical curve data affecting the wall.
8. A listing of the summary of quantities on the elevation sheet for each wall.
9. A list of manufacturer's recommendations with respect to maintenance, including repair of graffiti and other damages.
10. Typical sections and elevation views for bridge mounted installations.

210

220

(e) Working drawings shall include a detailed plan of aesthetic treatment for the entire sound barrier system, manufacturer- recommended installation requirements and sequence of construction, manufacturer-recommended repair requirements for damage caused by vandalism or graffiti prior to final acceptance, and a detailed bill of materials.

MATERIALS

230

620.04 Materials

Materials shall be in accordance with the following:

Cast-in-Place Portland Cement Concrete, Class A702
Coarse Aggregate, Class A or Higher, Size No. 91904

	Coarse Aggregate, Class D or Higher, Size No. 5.....	904
	Coarse Aggregate, Class D or Higher, Size No. 8.....	904
	Concrete Masonry Units	905.06
	Fine Aggregate, Size No. 23.....	904
240	Joint Mortar	901.08, 907.12
	Paint	909.02
	Portland Cement	901.01(b)
	Precast Concrete.....	707
	Reinforcing Bars	910.01
	Structural Aluminum Posts	910.14(d)
	Structural Steel.....	910
	Water	913.01

250 *Steel structural components shall be in accordance with ASTM A 36. Structural steel components shall be hot dipped galvanized in accordance with ASTM A 123, coating grade 100 or painted in accordance with 619.11 and 619.12. Exposed surfaces of galvanized components shall be coated in accordance with 619.09(b). The galvanized surfaces shall be prepared using a light brush-off blast cleaning in accordance with SSPC-SP 16. The surface profile shall be 15 to 30 microns in accordance with ASTM D 4417, prior to painting.*

260 *All structural steel hardware shall be in accordance with ASTM A 325 and shall be hot dipped galvanized in accordance with ASTM A 153 or shall be made of nonferrous material or stainless steel. All other non-structural fastening devices shall be made of nonferrous metal or stainless steel. Plastic members shall be connected with either screws or bolts. Aluminum members shall be connected with stainless steel fasteners. Anchor bolts shall be of the size shown with a minimum of 10 in. (250 mm) of 7NC threads on the upper end. Anchor bolts shall be in accordance with ASTM F 1554. The threads, nuts, and washers shall be galvanized in accordance with ASTM A 153 or be mechanically galvanized and conform to the coating thickness, adherence, and quality requirements of ASTM A 153, where required.*

270 *Solid portland cement concrete or composite concrete shall be coated or contain an integral pigment, as specified by the manufacturer, and shall meet the specified color requirements. Integral pigment shall be certified to be in accordance with ASTM C 979. The coating shall be tested for accelerated weathering in accordance with ASTM D 6695. The test panel substrate shall be of the same portland cement concrete or composite concrete material used in the sound barrier system component. Cured coating or integral pigment shall not contain heavy metals that exceed the requirements of 40 CFR 261.24.*

Concrete class A for the coping shall be in accordance with the applicable requirements of 702, except the coarse aggregate for pre-cast units may be size No. 91 in accordance with 904. Reinforcing steel in the coping shall be in accordance with the applicable requirements of 703. The coping may be precast or cast-in-place.

280 *Masonry block shall be tested in accordance with ASTM C 90 and as follows:*

(a) *The average compressive strength of 3 units shall be a minimum of 3,000 psi (21 MPa) with no single unit being less than 2,700 psi (19 MPa).*

(b) *The units shall be tested for water absorption in accordance with ASTM C 140. The maximum absorption shall be 7%.*

(c) *Joint reinforcement for masonry block systems shall be in accordance with ASTM A 951.*

290

(d) *Mortar for masonry block systems shall be in accordance with ASTM C 270; type S, Table 1 proportion requirements.*

(e) *Portland cement-lime or mortar cement may be used. Masonry cement shall not be used. Grout for masonry shall be in accordance with ASTM C 476.*

(f) *Aggregate for masonry grout shall be in accordance with ASTM C 404.*

300

Masonry blocks shall be coated or contain an integral pigment, as specified by the manufacturer, and shall meet the specified color requirements. The integral pigment shall be certified to be in accordance with ASTM C 979. The coating shall be tested for Accelerated Weathering in accordance with ASTM D 6695. The test panel substrate shall be of the same masonry blocks used in the sound barrier system component. Cured coating or integral pigment shall not contain heavy metals that exceed the requirements of 40 CFR 261.24.

310

Certifications shall be provided for each of the materials to be supplied for the sound barrier system. Certifications shall be in accordance with a type C in accordance with 916, unless noted otherwise. A type A certification in accordance with 916 shall be provided for compressive strength and absorption test values for masonry block, sampled and tested in accordance with ASTM C 140. All test reports required to substantiate compliance shall be in accordance with the test method/material requirements cited herein. A Department approved laboratory shall conduct the testing.

CONSTRUCTION

620.05 Information for Public Input

320

Colored flyers with appropriate graphics shall be developed by the Contractor and furnished to the Department.

Wall color photos shall be provided for each color in accordance with 620.03 along with photos of each available texture alternative. A minimum of 3 wall samples of the non-roadway side textures shall be provided. All samples of the wall textures shall be a minimum of 3 sq ft (0.27 m²) in area, with a distinguishable pattern.

Based on comments received, the Department will select the final finishes and colors for each wall. Each wall shall have the selected color used throughout the entire

330 wall on the roadway and the non-roadway sides. The Contractor shall coordinate all sound barrier wall issues with the Engineer prior to ordering any materials.

620.06 Construction Requirements

Sound barrier components shall not be stored on the right-of-way unless written permission is given by the Department. Requests for permission to store materials on the right-of-way will not be accepted until after the contract has been awarded.

340 The sound barrier supplier shall provide technical instruction, guidance in preconstruction activities including the preconstruction conference, and on-site technical assistance during construction. The Contractor is responsible for following installing instructions from the supplier unless otherwise directed in writing by the Engineer.

Clearing and grading shall be in accordance with 201 and 202 as required.

The foundations for ground mounted sound barrier systems shall be constructed as shown on the working drawings. Holes for footings shall be drained of free water prior to installing any components. Placing concrete shall be in accordance with 702.

350 The integrity of the sound barrier system continuity shall be such that no light will be visible through any vertical joint between sound barrier panel and vertical support post, through any horizontal joint between sound barrier panels, between the bottom of any ground mounted sound barrier and the adjacent ground, or between the bottom of any wall mounted sound barrier and the top of the adjacent wall. Exceptions may be allowed as necessary for drainage as indicated on the plans.

360 Sound barrier wall posts shall be placed vertical with a tolerance of 1/2 in. per 10 ft (13 mm per 3 m) on each axis. Sound barrier wall posts shall be placed at the distance indicated on the plans with a tolerance of 1 in. (25 mm) from centerline to centerline. Sound barrier wall posts shall be aligned to within 1 in. (25 mm) when measured from a straight line from the 2 adjacent posts. Sound barrier wall posts shall be at the height as shown on the plans. The posts shall project above the top sound barrier wall panel by 1 1/2 in. \pm 1/2 in. (37 mm \pm 13 mm). The top of the sound barrier wall shall be at or above the acoustical profile. Steel posts embedded in concrete shall have bottom cover of 8 in. \pm 4 in. (200 mm \pm 100 mm). Field-cut steel posts shall be primed with an organic zinc primer and painted in accordance with 619.

After post erection the area shall be backfilled to within 6 in. (150 mm) of the required final grade or as specified in the plans. The aggregate pad shall be placed as required. Positive drainage of the work area shall be maintained.

370 An aggregate pad of No. 5 or No. 8 coarse aggregate shall be included that extends 4 in. (100 mm) outside of each side of the panel and 4 in. (100 mm) below the bottom of the panel.

The sound barrier system and sound barrier system components shall be maintained until final acceptance. Elements of the sound barrier system that are damaged or destroyed, including due to graffiti or other vandalism, shall be repaired or

replaced as directed by the Engineer. Repairs and repainting shall be conducted in accordance with the manufacturer's guidance and 620.02.

380 After construction of the sound barrier system the site shall be restored to the original condition with grading, seeding and sodding in accordance with the plans.

(a) Construction Requirements for Precast Panels

Sound barrier wall panels shall be placed in accordance with the plans and centered between adjacent posts. The sound barrier wall panels shall be of sufficient length to span the entire length between posts less 1/2 the width of the smallest retaining flange.

390 Panels may be field-cut to facilitate erection in accordance with the manufacturer's recommendation. Field-cut panels shall be cut to have the least impact on any patterns present in the textured or colored finish. Field-cut panels or other field cut components shall be painted in accordance with the manufacturer's guidance.

(b) Construction Requirements for Masonry

All grouting and reinforcing work for masonry block systems shall be performed by masonry craftworkers holding current International Masonry Institute (IMI) Grouting and Reinforcing Certification. Proof of certification shall be submitted prior to the beginning of work.

400 **620.07 Acceptance**

The Contractor shall submit 2 ft x 2 ft (0.6 m x 0.6 m) sound barrier panel samples or 5 masonry block units in the colors and textures proposed and a 2 ft (0.6 m) sample of painted support post, prior to the approval of the working plans. Once approved, these samples will be used as a control sample to verify delivered products meet the aesthetic requirements. The sound barrier system will be accepted for color based on a visual comparison between the control sample and the color of the wall as constructed in place.

410 The sound barrier system will be accepted for quality based on a visual inspection of the components of the system by the Engineer. The sound barrier system shall be subject to rejection due to failure to be in accordance with the requirements specified herein. In addition, the following defects may also be sufficient cause for rejection:

(a) Defects that indicate imperfect fabrication

(b) Defects in physical appearance such as cracks, checks, dents, scrapes, chips, stains, or color variations.

420 The Engineer will determine whether a defective sound barrier shall be repaired or shall be cause for rejection. Repair, if permitted, shall be completed by the Contractor and will be approved by the Engineer.

620.08 Method of Measurement

440

450

Partial payment will be made for sound barrier panels stockpiled on the project site or at the Contractor's approved storage location within the State of Indiana. Partial payment will be based on the delivered cost of the sound barrier panels, as verified by invoices that include freight charges. The Contractor shall furnish the invoices and all required certifications. Partial payment will not exceed 75% of the contract unit price for bridge mounted, ground mounted or wall mounted sound barrier panels. Prior to authorizing the partial payment, verification will be obtained that all required inspection has been made and that the panels are acceptable.

460

Pay Item

Sound Barrier Design and Layout LS
Sound Barrier Erection, _____, _____.....SFT (m2)
 mounting type,* type**
Sound Barrier Panels, _____, _____.....SFT (m2)
 mounting type,* type**

470

The cost of sound barrier panel materials including vertical support posts, coping, aggregate pad mortar, grout and joint reinforcement for masonry block, fasteners, closures, expansion plates, openings and incidentals shall be included in the cost of the sound barrier panels for the type of sound barrier panels.

480 *Substituting type 2 wall for type 1 wall or substituting type 1 or type 2 wall for type 3 wall shall be at no cost to the Department.*

The cost of the selected texture and selected color shall be included in the cost of the sound barrier panel for the type of sound barrier panels.

The cost of all labor and materials to prepare and erect the sound barrier shall be included in the cost of sound barrier erection for the type of sound barrier panels.

490 *The cost of foundation preparation and construction with associated work shall be included in the cost of sound barrier, ground mounted.*

The cost of removal or construction of concrete barrier walls is not included in the cost of sound barrier erection, wall mounted.
