

723-R-589 WWR USED IN THREE-SIDED STRUCTURES

(Adopted 11-16-11)

The Standard Specifications are revised as follows:

SECTION 723, BEGIN LINE 72, DELETE AS FOLLOWS:

Unless otherwise specified herein, reinforcement may consist of either reinforcing bars or welded wire reinforcement, WWR. If specified to be coated, WWR shall be coated with either galvanized coating or epoxy coating, and reinforcing bars shall be coated with epoxy coating. ~~Epoxy coated WWR shall be coated with Type I coating with Class A minimum coating thickness in accordance with ASTM A 884. Galvanized WWR shall be coated in accordance with ASTM A 123 and shall have a minimum coating grade of 35.~~ For WWR, material with minimum yield strength of 65 ksi (448 MPa) shall be used.
