

## 702-B-304 PERMANENT DECK FORM ANGLES

(Adopted 03-16-17)

The Standard Specifications are revised as follows:

SECTION 702, BEGIN LINE 657, INSERT AS FOLLOWS:

Form sheets shall not rest directly on the top of the beam flanges. Sheets shall be securely fastened to *the* form supports and shall have a minimum bearing length of 1 in. at each end. All attachments shall be made by welds, bolts, clips, or other approved means. Except as amended by these specifications, welding and welds shall be in accordance with the requirements of 711.32 pertaining to fillet welds. However, 1/8 in. fillet welds will be allowed. *The vertical leg of angles used as form supports shall not extend higher than the top of the permanent metal form.*

---