

## 718-R-639 UNDERDRAIN OUTLETS

*(Adopted 06-16-16)*

The Standard Specifications are revised as follows:

SECTION 718, BEGIN LINE 71, DELETE AND INSERT AS FOLLOWS:

**718.05 Underdrain Outlets**

If the underdrain pipe and the outlet pipe are of different sizes, an increaser of the same material as the outlet pipe shall be installed ~~between the transition pipe and~~ *2 ft from the 45° elbow and prior to the transition pipe*. If a single outlet pipe is to be skewed at 45°, a second 45° elbow and an elbow-connector pipe are not required.

---