

211-R-819 B BORROW AND STRUCTURE BACKFILL

*(Adopted 04-16-26)*

The Standard Specifications are revised as follows:

SECTION 211, BEGIN LINE 75, INSERT AS FOLLOWS:

Where B borrow or structure backfill is required as backfill at culverts, retaining walls, sewers, manholes, catch basins, and other miscellaneous structures, it shall be compacted in accordance with 211.04. B borrow *or structure backfill* consisting of ACBF or GBF shall not be used within 2 ft of the free water level.

---